

RESOLUTION NO. 24-9391

A RESOLUTION OF THE CITY OF SANTA CLARA, CALIFORNIA, APPROVING THE CITY'S POTABLE AND RECYCLED WATER SYSTEM RULES AND REGULATIONS

WHEREAS, a reliable minimum supply of potable water is essential to the public health, safety and welfare of the people and economy of the City of Santa Clara;

WHEREAS, Section 7583 et seq. of Title 17 of the California Code of Regulations for cross-connections specifies the minimum requirements for backflow prevention devices that must be installed to protect the public drinking water system from contaminants;

WHEREAS, the City of Santa Clara (City) incorporates the requirements of Title 17 in the Water Service and Use Rules and Regulations (Rules and Regulations);

WHEREAS, the City of Santa Clara wishes to clarify the implementation of Title 17 and other requirements of the Rules and Regulations for new development projects;

WHEREAS, Section 2 of Article X of the California Constitution and Section 100 of the California Water Code declare that the general welfare requires water resources be put to beneficial use, waste or unreasonable use or unreasonable method of use of water be prevented, and conservation of water be fully exercised with a view to the reasonable and beneficial use thereof;

WHEREAS, Section 7 of Article XI of the California Constitution declares that a city or county may make and enforce within its limits all local, policy, sanitary, and other ordinances and regulations not in conflict with general laws;

WHEREAS, the adoption and enforcement of the updates to the Rules and Regulations is necessary to protect and manage the City's potable water supply, water distribution system and ensure a reliable and sustainable minimum supply of water for the public health, safety and welfare; and

WHEREAS, the City Council has reviewed the updated Rules and Regulations and the information accompanying the Report to Council concerning the proposed updates.


NOW THEREFORE, BE IT RESOLVED BY THE CITY OF SANTA CLARA AS FOLLOWS:

1. That the findings set forth above are hereby adopted.
2. That the updated Water Service and Use Rules and Regulations presented in the presented in the accompanying Report to Council and attached hereto in final form, are hereby adopted. The City Council also hereby renames the Water Service and Use Rules and Regulations to the "Potable and Recycled Water System Rules and Regulations."
3. Effective date. This resolution shall become effective immediately.

I HEREBY CERTIFY THE FOREGOING TO BE A TRUE COPY OF A RESOLUTION PASSED AND ADOPTED BY THE CITY OF SANTA CLARA, CALIFORNIA, AT A REGULAR MEETING THEREOF HELD ON THE 19TH DAY OF NOVEMBER, 2024, BY THE FOLLOWING VOTE:

AYES:	COUNCILORS:	Becker, Chahal, Hardy, Jain, Park, and Watanabe, and Mayor Gillmor
NOES:	COUNCILORS:	None
ABSENT:	COUNCILORS:	None
ABSTAINED:	COUNCILORS:	None

ATTEST:



NORA PIMENTEL, MMC
ASSISTANT CITY CLERK
CITY OF SANTA CLARA

Attachments incorporated by reference:

1. Updates to the City's Water Service and Use Rules and Regulations



POTABLE AND RECYCLED WATER SYSTEM

RULES AND REGULATIONS

CITY OF SANTA CLARA

TABLE OF CONTENTS

TABLE OF CONTENTS	I
1. GENERAL STATEMENT AND DEFINITIONS	1
1.A ESTABLISHMENT OF RULES AND REGULATIONS.....	1
1.B GENERAL STATEMENT.....	1
1.C WATER USE RESTRICTIONS AND PROHIBITIONS	1
1.D INCORPORATION OF MUNICIPAL SERVICES DIVISION UTILITY SERVICES RULES AND REGULATIONS.....	2
1.E INCORPORATION OF WATER MASTER PLAN AND MANAGEMENT PLAN	2
1.F INCORPORATION OF TITLE 17 AND TITLE 22.....	3
1.G INCORPORATION OF AWWA STANDARDS	3
1.H INCORPORATION OF STANDARD DETAILS AND SPECIFICATIONS	3
1.I DEFINITIONS	3
2. NOTICES	8
2.A NOTICES TO THE CUSTOMER	8
2.B NOTICES TO THE CITY.....	8
3. APPLICATION FOR WATER SERVICE	9
3.A SERVICE ORDER APPLICATIONS.....	9
3.B CHANGES IN WATER SERVICE.....	9
3.C DISCONTINUANCE OF WATER SERVICE.....	9
4. RATES 10	
4.A RATES.....	10
4.B TEMPORARY RATE SCHEDULE.....	10
4.C ESTABLISHMENT OF NEW OR OPTIONAL RATES	10
4.D REASSESSMENT OF RATE SCHEDULE QUALIFICATION	10
4.E SERVICE BY FACILITIES PURCHASED FROM OTHER UTILITIES	10
5. METER TEST AND ADJUSTMENT OF BILLS FOR METER ERROR	11
5.A METER TEST	11
5.B METER TEST - CUSTOMER REQUEST	11
5.C ADJUSTMENT OF BILLS FOR METER ERROR	11
6. APPEAL FROM THE APPLICATION, REQUIREMENTS, OR INTERPRETATION OF THESE RULES AND REGULATIONS	12
6.A REQUEST FOR APPEAL.....	12
6.B SUBSEQUENT APPEAL.....	12
6.C APPEAL COMPONENTS.....	12
6.D APPEAL TIMEFRAME	12
6.E HEARING NOTICE	12
6.F HEARING	12
6.G APPEAL DECISION	13
7. NEW DEVELOPMENT	14
7.A WATER SUPPLY ASSESSMENTS	14
7.B DEVELOPMENT IMPACT ANALYSIS.....	14
7.C PUBLIC WATER MAINS.....	14
7.D MAXIMIZING RECYCLED WATER USE	14
7.E RECYCLED WATER CONVERSION	14
7.F RECYCLED WATER READY.....	14
7.G GRAYWATER READY	15
7.H MAIN EXTENSIONS AND UPSIZING REQUIRED FOR FIRE DEMAND USE.....	15
7.I MAIN EXTENSIONS FOR RECYCLED WATER USE	15
7.J MAIN REPLACEMENT.....	15
7.K WATER MAIN TIE-INS TO THE CITY'S WATER SYSTEM.....	15
7.L WORK OUTSIDE OF THE CITY'S NORMAL WORK HOURS	16
7.M DEVELOPMENT SHALL INSTALL BACKFLOW PREVENTION DEVICES	16
7.N UPGRADING SERVICE CONNECTIONS TO MEET CURRENT STANDARD.....	16
7.O SEPARATE SERVICES	17
7.P MINIMUM SERVICE SIZE FOR SINGLE-FAMILY HOMES.....	17
7.Q SUBMETERING	17
7.R PRIVATE WELLS.....	17
7.S DEVELOPMENT REVIEW.....	17
7.T UTILITY CLEARANCES.....	18

7.U	RELOCATION OF EXISTING FACILITIES	18
7.V	RIGHTS OF WAY	18
7.W	OBLIGATION TO PROTECT EXISTING PUBLIC UTILITIES.....	18
7.X	DEMOLITION PERMITS.....	19
7.Y	NEW SERVICE APPLICATIONS	19
7.Z	RECORD DRAWINGS	19
8.	AFFORDABLE HOUSING PROJECTS	20
8.A	DEFINITIONS	20
8.B	PRIORITY IN THE EVENT OF SERVICE LIMITS	20
8.C	PROHIBITION ON DENIAL OR CONDITIONING OF SERVICE	20
9.	ACCESS, INTERFERENCE, TAMPERING, AND THEFT.....	21
9.A	CITY RIGHT OF ACCESS.....	21
9.B	WORK OUTSIDE CITY'S OPERATING CONVENIENCE.....	21
9.C	INTERFERENCE	21
9.D	TAMPERING	21
9.E	THEFT	22
9.F	FRAUD	22
9.G	LIABILITY, PENALTY, PROSECUTION AND PUNISHMENT FOR VIOLATION.....	22
9.H	CIVIL ACTION	22
10.	TEMPORARY WATER SERVICE	23
10.A	TIME LIMIT	23
10.B	CHARGE FOR WATER SERVED	23
10.C	INSTALLATION CHARGE AND DEPOSITS	23
10.D	REFUNDS.....	23
10.E	TEMPORARY WATER PERMIT	23
11.	SHORTAGE OF SUPPLY AND INTERRUPTION OF DELIVERY	25
11.A	WATER SUPPLY	25
11.B	TEMPORARY WATER SERVICE SUSPENSION	25
11.C	APPORTIONMENT OF WATER SUPPLY	25
12.	DESCRIPTION OF STANDARD WATER SERVICE.....	26
12.A	NUMBER OF SERVICES TO SEPARATE PREMISES	26
12.B	SERVICE TO MULTIPLE UNITS.....	26
12.C	SINGLE METER SERVICE TO MULTIPLE TENANTS/UNITS	26
13.	RESPONSIBILITY FOR EQUIPMENT AND PROTECTIVE DEVICES	28
13.A	RESPONSIBILITY FOR EQUIPMENT	28
13.B	PROTECTIVE DEVICES	28
14.	SERVICE CONNECTIONS AND METERS	29
14.A	SERVICE CONNECTIONS.....	29
14.B	METERS.....	29
14.C	CHANGES IN LOCATION OF METERS AND SERVICE CONNECTIONS	29
14.D	CHANGES IN SIZE OF METER.....	29
14.E	SUBMETERING	30
14.F	OWNERSHIP	30
14.G	MAINTENANCE	30
14.H	SPLIT SERVICE CONNECTIONS.....	30
15.	FIRE SERVICE CONNECTIONS.....	31
15.A	PURPOSE	31
15.B	REQUEST AND APPLICATION.....	31
15.C	BACKFLOW PREVENTION DEVICES FOR FIRE SERVICE CONNECTIONS	31
15.D	MINIMUM SIZE FOR SINGLE-FAMILY HOMES WITH FIRE SPRINKLERS	31
15.E	INSTALLATION CHARGES FOR CITY WORK.....	31
15.F	QUANTITATIVE CHARGES.....	32
15.G	TESTING	32
15.H	VIOLATION OF RULES AND REGULATIONS.....	32
15.I	OWNERSHIP OF CONNECTION	32
15.J	PRESSURE AND SUPPLY	32
15.K	FIRE FLOW AND DEVELOPMENT IMPACT REQUESTS	32
15.L	RATES.....	33
16.	FIRE HYDRANTS	34
16.A	USE OF AND DAMAGE TO FIRE HYDRANTS.....	34
16.B	MARKING OR COLOR CODING OF FIRE HYDRANTS	34
16.C	MODIFICATION OR RELOCATION OF FIRE HYDRANTS.....	34

16.D	WATER FROM FIRE HYDRANTS	34
17.	SWIMMING POOLS AND TANKS	36
17.A	FILLING SWIMMING POOLS AND TANKS	36
18.	CONTROL VALVES	37
18.A	WATER SUPPLY CONTROL	37
18.B	CURB STOP	37
19.	CROSS-CONNECTIONS	38
19.A	HEALTH REGULATIONS	38
19.B	CITY REQUIREMENTS	38
19.C	APPROVED BACKFLOW PREVENTION DEVICES	38
19.D	TYPES OF APPROVED BACKFLOW PREVENTION DEVICES REQUIRED	38
19.E	EXISTING SERVICES WITHOUT A DEVICE	39
19.F	EXISTING SERVICES WITH A NON-COMPLIANT DEVICE	39
19.G	PLUMBING CHANGES REQUIRED	39
19.H	RELIEF VALVE REQUIRED	40
19.I	BACKFLOW PROTECTION ON ADDITIONAL WATER SUPPLY LINES	40
19.J	INSPECTION OF BACKFLOW PREVENTION DEVICES	40
19.K	INSTALLATION OF BACKFLOW PREVENTION DEVICES	40
19.L	INSTALLATION OF FACILITIES ON PRIVATE PROPERTY	40
19.M	REMOVAL OR MODIFICATION OF BACKFLOW PREVENTION DEVICES	41
19.N	DISCONTINUANCE OF SERVICE FOR DEFECTIVE APPARATUS	41
20.	ONSITE RECYCLED WATER USE	42
20.A	ABBREVIATIONS	42
20.B	DEFINITIONS	43
20.C	SUMMARY OF ONSITE INSTALLATION REQUIREMENTS	45
20.D	FEES AND PERMIT	47
20.E	THE CITY AS THE LOCAL AUTHORITY	47
20.F	AUTHORIZED USES FOR RECYCLED WATER	47
20.G	NON-APPROVED USE AREAS	48
20.H	AMENDMENTS	48
20.I	PROTECTION OF PUBLIC HEALTH	48
20.J	RIGHT TO TERMINATE SERVICE	48
20.K	SEVERABILITY	49
21.	DESIGN, INSTALLATION AND INSPECTION OF SYSTEMS FOR USE OF RECYCLED WATER	50
21.A	DESIGN APPROVAL	50
21.B	REQUIRED ONSITE RECYCLED WATER SERVICE PLANS	50
21.C	BASIS FOR DESIGN REVIEW CRITERIA	51
21.D	SUMMARY OF DESIGN REVIEW CRITERIA	51
21.E	PRELIMINARY CROSS-CONNECTION TEST EXISTING SITES	53
21.F	CONSTRUCTION INSPECTION	53
21.G	FIELD TESTING AND INSPECTION	53
21.H	TEMPORARY CONNECTION TO POTABLE SERVICE	53
21.I	FINAL CROSS-CONNECTION TEST	54
21.J	FINAL INSPECTION	55
21.K	FINAL APPROVAL	55
21.L	RECORD DRAWINGS	55
22.	OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER	56
22.A	CONDITIONS OF SERVICE	56
22.B	SYSTEM RESPONSIBILITY	56
22.C	HOURS OF OPERATION	56
22.D	DESIGNATION OF CERTIFIED SITE SUPERVISOR	57
22.E	PERSONNEL TRAINING	58
22.F	VEHICLE IDENTIFICATION	58
22.G	MAINTENANCE	ERROR! BOOKMARK NOT DEFINED.
22.H	ANNUAL SELF-INSPECTIONS AND REPORTS	59
22.I	PERIODIC PROGRAM INSPECTIONS	59
22.J	MODIFICATIONS	60
22.K	PERIODIC CROSS-CONNECTION TESTING	60
22.L	SYSTEM NOT IN COMPLIANCE	60
22.M	NOTIFICATION	60
22.N	EMERGENCY PROCEDURE	61
22.O	EMERGENCY CROSS-CONNECTION RESPONSE PLAN	61

POTABLE AND RECYCLED WATER SYSTEM RULES AND REGULATIONS

City Council Resolution No. 24-9391

Latest Revision: 11/19/24

22.P	FORMS.....	63
23.	WATER EFFICIENT LANDSCAPE ORDINANCE.....	68
23.A	PURPOSE	68
23.B	APPLICABILITY	68
24.C	DEFINITIONS	70
23.D	COMPLIANCE WITH LANDSCAPE DOCUMENTATION PACKAGE	74
23.E	PENALTIES.....	75
23.F	COMPONENTS OF THE LANDSCAPE DOCUMENTATION PACKAGE	75
23.G	WATER EFFICIENT LANDSCAPE WORKSHEET	76
23.H	SOIL MANGEMENT REPORT	77
23.I	LANDSCAPE DESIGN PLAN	78
23.J	IRRIGATION DESIGN PLAN	81
23.K	GRADING DESIGN PLAN.....	85
23.L	CERTIFICATE OF COMPLETION	85
23.M	IRRIGATION SCHEDULING	86
23.N	LANDSCAPE AND IRRIGATION MAINTENANCE	87
23.O	IRRIGATION AUDIT, SURVEY AND WATER USE ANALYSIS	88
23.P	IRRIGATION EFFICIENCY.....	88
23.Q	RECYCLED WATER	88
23.R	GRAYWATER SYSTEMS	89
23.S	STORMWATER MANAGEMENT AND RAINWATER RETENTION.....	89
23.T	PUBLIC EDUCATION	90
23.U	ENVIRONMENTAL REVIEW.....	90
23.V	IRRIGATION AUDIT, SURVEY AND WATER USE ANALYSIS OF EXISTING LANDSCAPES	91
23.W	WATER WASTE PREVENTION.....	91
23.X	EFFECTIVE PRECIPITATION.....	91
23.Y	REPORTING.....	92
23.Z	APPENDICES.....	93

1. GENERAL STATEMENT AND DEFINITIONS

1.A ESTABLISHMENT OF RULES AND REGULATIONS

The following rules and regulations, rates and charges governing the Water and Recycled Water system furnished by the City of Santa Clara, California are hereby established.

1.B GENERAL STATEMENT

The City of Santa Clara Water and Sewer Utilities Department, referred to as the "Water Utility," shall furnish Water and Recycled Water Service in accordance with the Municipal Services Division's Utility Services Rules and Regulations and the regulations hereinafter set forth, and in accordance with all other applicable ordinances, to any property within the corporate limits of the City and to such areas outside the City limits as the City Council may designate.

All water used must be taken through a water meter unless a Permit is first obtained in compliance with the regulations contained in these Rules and Regulations.

Applications for service to Premises for which a Service Connection has already been installed may be made in accordance with the Utility Services Rules and Regulations, which are incorporated herein by reference as though set forth in full. Such applications will signify the Customer's willingness and intention to comply with all applicable Rules and Regulations and rates duly adopted, and to make payment for Water Service rendered.

If application is made for service to property where no Service Connection has been installed, but a distribution Main is adjacent to the property, the applicant, in addition to making application for service, shall comply with the regulations governing the installation of Service Connections. Where an extension of the distribution Main is necessary or a substantial investment is required to furnish service, the applicant shall be informed by the City of the applicable provisions of the Code and these Rules and Regulations governing the extension of distribution Main and facilities.

1.C WATER USE RESTRICTIONS AND PROHIBITIONS

1. The Water Use Restrictions and Prohibitions below are specific measures which prevent water waste and achieve reasonable, yet substantial, reductions in water use by all users in the City. The following uses of water are prohibited by the City:
 - (a) Wasting water, which includes but is not limited to, the flooding or Runoff on City sidewalks, gutters, and streets,
 - (b) Cleaning or washing of sidewalks, driveways, patios, parking lots, or other paved or hard-surfaced areas,
 - (c) Washing cars, buses, boats, trailers, or any vehicle by use of a hose unless that hose is fitted with an operating automatic shutoff valve.
 - (d) Water waste due to broken or defective plumbing, fire system, irrigation system, or any Appurtenance thereto; or to open or to leave open any stopcock or faucet so as to permit water waste,
 - (e) Service of water by any restaurant unless requested by a patron,
 - (f) Installation of a single-pass cooling system,
 - (g) Installation and/or use of a non-recirculating, decorative fountain,

POTABLE AND RECYCLED WATER SYSTEM RULES AND REGULATIONS No. 1

1. GENERAL STATEMENT AND DEFINITIONS (Continued)

- (h) Construction of a non-recirculating conveyor car wash,
 - (i) Overhead Spray Irrigation using Sprinkler Heads, Spray Heads and/or rotors between the hours of 9 a.m. and 6 p.m.,
 - (j) Watering lawns during or within 48 hours of measurable precipitation,
 - (k) Irrigating Non-Functional Turf (Decorative Grass) on public street Medians
 - (l) Applying Potable Water to Non-Functional Turf at commercial, industrial or institutional (CII) sites, including common areas of homeowners' associations (HOAs),
 - (m) Irrigation of landscapes outside of newly constructed homes and buildings in a manner inconsistent with regulations or other requirements established by California Building Standards Commission and the Department of Housing and Community Development,
 - (n) Street cleaning or construction site preparation, if Recycled Water is available.
2. To further prevent the waste of Potable Water, the installation of Non-Functional Turf is prohibited in new and existing Non-Residential Landscape Projects and multifamily Landscape Projects.
- (a) The use of Potable Water is not prohibited to the extent necessary to ensure the health of trees and other perennial non-Turf plantings or to the extent necessary to address immediate health and safety, sanitation, or fire protection needs as determined by the fire marshal. Unless otherwise permitted by the fire marshal, the watering permitted under this section 1.C.2(a) must be completed in a manner that prevents Runoff.
3. In addition to the above water use prohibitions and to promote efficient water use, hotels/motels shall provide guests with the option of choosing not to have towels and linens laundered daily. Notice of this option shall be displayed prominently in each guestroom using easily understood terms and language.

1.D INCORPORATION OF MUNICIPAL SERVICES DIVISION UTILITY SERVICES RULES AND REGULATIONS

These Rules and Regulations hereby incorporate by reference all Rules and Regulations of the Municipal Services Division of the Department of Finance, hereinafter referred to as "Utility Services Rules and Regulations," of the City of Santa Clara. Rules governing the establishment of credit, rendering and payment of bills, financial aspects of temporary service or discontinuance of service for water are contained in the Utility Services Rules and Regulations.

1.E INCORPORATION OF WATER SUPPLY MASTER PLAN AND URBAN WATER MANAGEMENT PLAN

These Rules and Regulations hereby incorporate by reference the Water Supply Master Plan and the Urban Water Management Plan adopted by the Water and Sewer Utilities Department, collectively the "Master Plans." All Developments and construction shall conform with the requirements of such Master Plans in effect at the time of construction.

1. GENERAL STATEMENT AND DEFINITIONS (Continued)

1.F INCORPORATION OF TITLE 17 AND TITLE 22

These Rules and Regulations hereby incorporate by reference all applicable regulations of the State of California Division of Drinking Water (DDW) of the State Water Resources Control Board including Title 17 and Title 22 and all successor regulations. In the event of any disagreement between the City's Rules and Regulations and DDW regulations, the most conservative requirement between them shall apply.

1.G INCORPORATION OF AWWA STANDARDS

These Rules and Regulations hereby incorporate by reference all American Water Works Association (AWWA) Standards in effect at the time of Permit approval. In the event of any disagreement between the City's Rules and Regulations and the AWWA Standards, the most conservative requirement between them shall apply.

1.H INCORPORATION OF STANDARD DETAILS AND SPECIFICATIONS

These Rules and Regulations hereby incorporate by reference all Water Standards, henceforth "Standards," adopted by the Water and Sewer Utilities Department which include the Water and Sewer Utilities Standard Drawings and Specifications, the Public Works Standards Details, the Public Works Standards Specifications, and the Public Works Design Criteria. All water infrastructure materials and construction methods shall conform with the requirements of such Standards in effect at the time of building Permit issuance.

1.I DEFINITIONS

Terms appearing with an initial letter capitalized are defined terms. The definitions set forth in the Utility Services Rules and Regulations for the Municipal Services Division, Department of Finance, are incorporated by reference as set forth in full, and those definitions are not repeated here; reference should be made to Section 1.B of Utility Services Rules and Regulations. Unless the particular provision or context otherwise requires, the definitions and provisions contained in the Water and Recycled Water system Rules and Regulations Sections 1.I and 20.B and the Utility Services Regulations Section 1.B, shall govern the construction, meaning, and application of words and terms used in these Rules and Regulations. The singular of a word or term shall include the plural and the plural shall include the singular. Such words or terms as defined in these Rules and Regulations Section 1.I and 20.B shall be initially capitalized when used in context of these Rules and Regulations.

Appurtenances: Assets associated with the water distribution system that are additional to the pipe assets themselves such as valves, meters, Backflow preventers, meter boxes, joints, tees, elbows, etc.

Auxiliary Water: A water supply on or available to the Premises from a source other than the City's Potable Water supply. This may include water from another Local Water Purveyor, a natural source such as a well or stream, or water that may originate in the City's Potable Water supply, but passes through an Appurtenance such as a fire hydrant, Backflow device, fire department connection, etc., or is stored on the site such as a private pipe network or a tank.

Backflow: The reverse flow of water or any other fluid or substance or any combination or mixture thereof from the Customer's system into the City's water distribution system.

1. GENERAL STATEMENT AND DEFINITIONS (Continued)

Backflow Prevention Device: A City-approved device that prevents Backflow into the City's water distribution system. The types of Backflow devices accepted by the City include:

- **Reduced Pressure Principle Backflow Prevention Assembly (RP):** A device incorporating two or more check valves and an automatically operating differential relief valve located between the two checks, two shutoff valves, and equipped with necessary Appurtenances for testing. The device shall operate to maintain the pressure in the zone between the two check valves, less than the pressure on the public water supply side of the device.
- **Reduced Pressure Principle Detector Backflow Prevention Assembly (RPDA):** A device that includes a bypass containing a City specific water meter and an approved reduced-pressure principle Backflow Prevention Device. The City meter shall register accurately for only very low Flow Rates, up to three gallons per minute, and shall show a registration for all rates of flow.
- **Double Check Detector Assembly (DCDA):** A device composed of a line-size double check valve device with a bypass containing a specific water meter and an approved double check valve device.

Best Management Practice: A policy, program, practice or rule aimed at more efficient use or conservation of the water resources of the City and State.

City: The City of Santa Clara, California, acting through its elected officials or its duly authorized officers, employees, agents, or fictitious business names.

City Code: The Code of the City of Santa Clara, California.

City Equipment: Any property, facility, apparatus, or material associated with providing one or more utility services including, but not limited to, City's electric distributions system, water distribution system, pipes, ducts, conduits, valves, meters, Backflow Prevention Devices, transformers, protective devices, wiring, switches, meters and other Appurtenances required to provide a utility service to Customer's Premises.

City Employee: Any authorized City Employee, agent or representative.

City's Operating Convenience: The utilization of facilities or practices which contribute to the overall efficiency, safety or reliability of the Water Utility operations. City's Operating Convenience does not refer to Customer convenience or adoption of practices required to comply with applicable ordinances, rules and regulations, or similar requirements of public authorities.

City's Water System: The water supply and distribution system and all Appurtenances thereto owned and operated by the City, including all Service Connections to the City's water Mains.

Commercial Service: Provision of water to Premises where the Customer is engaged in trade.

Cross-Connection: An unprotected actual or potential physical connection between any part of a water system used or intended to supply water for drinking purposes and any source or system containing unapproved water or substance that is not or cannot be approved as safe, wholesome, and potable for human consumption. Direct piping between the two systems, bypass arrangements, jumper connections, removable sections, swivel or changeover devices, or other devices through which Backflow could occur are Cross-Connections and are prohibited, regardless of the presence of valves, Backflow Prevention Devices or other Appurtenances.

Customer: The Person, Persons, firm, association, governmental agency, corporation or other legal entity who use, are entitled to use, or benefit from the use of City of Santa Clara Utilities.

1. GENERAL STATEMENT AND DEFINITIONS (Continued)

Development: The subdivision, construction or improvement of Premises that requires an application for an Entitlement or Permit from the City. This shall include new construction, remodeling of existing buildings, and tenant improvements.

Dual Plumb: A system of plumbing installations used to supply both Potable and Recycled Water to a home or business. Under this system, two completely separate water piping systems are used to deliver water to the fixture.

Entitlement: The approval of a City of Santa Clara planning application.

Fire Service: Fire protection service through fire hydrants connected to the water distribution system and made available to the City Fire Department. Private Fire Service is the provision of water to Premises for Fire Service Connections.

Flow Rate: The rate at which water flows through the pipes, valves and emission devices. (gallons per minute, cubic feet per second, gallons per hour).

Graywater: Untreated wastewater that has not been contaminated by any toilet discharge, has not been affected by infectious, contaminated, or unhealthy bodily wastes, and does not present a threat from contamination by unhealthful processing, manufacturing, or operating wastes. Graywater includes, but is not limited to, wastewater from bathtubs, showers, bathroom washbasins, clothes washing machines, and laundry tubs, but does not include wastewater from kitchen sinks or dishwashers. Health and Safety Code Section 17922.12.

Industrial Service: Provision of water to Premises for use in manufacturing or processing activities.

Infiltration Rate: The rate at which soil accepts water as applied, expressed in inches per hour.

Landscape Project: An undertaking of landscape design and installation on a particular area of land. A Landscape Project may be associated with an individual lot, a building project, or a multi-phased Development. It may also be a larger, comprehensive landscape scheme that is not coupled with an individual building project.

Local Water Purveyor: Any entity, including a public agency, city, county, or private water company that provides retail Water Service.

Main Extensions: Extension of distribution pipelines including all necessary Appurtenances, exclusive of Service Connections, beyond existing facilities.

Mains: Distribution pipelines, which are used to service the general public, and are located in streets, highways, public rights of way or easements through private lands.

Median: Area between opposing lanes of traffic that may be unplanted or planted with trees, shrubs, perennials, and ornamental grasses.

Meter Rate Service: Provision of water in measured quantities through metered service.

Non-Potable Water: Water that has not been treated for human consumption in conformance with the latest edition of the United States Public Health Service Drinking Water Standards, the California Safe Drinking Water Act, or any other applicable Standards.

Non-Residential Landscape: Landscapes in commercial, institutional, industrial and public settings that may have areas designated for recreation or public assembly. It also includes portions of common areas of Common Interest Developments with designated Recreational Areas and multifamily homes where landscaping is managed by a homeowners' association or other common interest Development.

1. GENERAL STATEMENT AND DEFINITIONS (Continued)

Overhead Spray Irrigation/Devices: Devices that deliver water through the air (e.g., Spray Heads and rotors).

Owner: Property or building Owner and authorized agents.

Permit: Any Permit issued by the City of Santa Clara Building Department, Fire Department, Department of Public Works, or Water and Sewer Utilities Department.

Potable Water: That water that is pure and wholesome, does not endanger the lives or health of human beings, and conforms to the latest edition of the California Safe Drinking Water Act, or other applicable Standards.

Premises: Any building, lot, parcel, real estate, land, or portion of land, whether improved or unimproved, occupied or unoccupied, including adjacent streets, sidewalks, pathways, parking strips, all structures, equipment or portions thereof occupied or operated by a Customer or tenants of a Customer and situated on an integral parcel of land undivided by a public highway, street or railway to which one or more utility services is or could be provided.

Public Use: Provision of water for Public Uses.

Recycled Water: Non-Potable, tertiary-treated water in compliance with the California Code of Regulations (CCR), Title 22, Division 4, Environmental Health Water Recycling Criteria and used for approved purposes.

Regulatory Agencies: Those public agencies legally constituted to protect the public health and water quality, such as the State DDW, the State RWQCB and the County EHS.

Runoff: Potable or Recycled Water that is not absorbed by the soil or landscape to which it is applied and flows outside the approved irrigation area. Runoff may result from water that is applied at too great a rate (application rate exceeds Infiltration Rate) or when there is a slope.

Separate Service Connection: A Service Connection used for a single land use and water use.

Service Connection: The connection of City of Santa Clara water, Recycled Water or sewer equipment to Customer equipment for the purpose of providing utility services. This includes, but is not limited to, all or any portion of the water pipe and Appurtenances, including the meter, between the City distribution line and an individual Customer's system.

Service Order: Customer request for the connection or discontinuance of Water Service.

Sprinkler Head or Spray Head: A device that delivers water through a nozzle.

Standards: The Standard Details, Standard Specifications, and Design Criteria adopted by the City of Santa Clara and in effect at the time of building Permit issuance.

Submeter: A secondary device beyond a meter that measures water consumption of individual units or buildings within Premises that have multiple units or buildings.

Swimming Pool: A Water Feature intended for swimming, recreational bathing or wading that contains water over 24 inches (24") deep. This includes in-ground, above ground, and on-ground pools; hot tubs; spas and fixed-in-place wading pools.

Tamper: To rearrange, bypass, damage, alter, interfere with, break, prevent normal function of equipment in any way, prevent access to equipment, or hinder a City Employee in the performance of their duties.

Temporary Water Service: Service for an enterprise or activity which is temporary in character, where it is known in advance that service will be of limited duration, or the permanency of which has not been established.

1. GENERAL STATEMENT AND DEFINITIONS (Continued)

Total Cost: The sum of all fully located expenses including overheads, all labor, material and use of City Equipment to complete a particular repair or addition to the system, and the cost of associated resources consumed.

Turf: A groundcover surface of non-native, ornamental grass or a groundcover surface of mowed grass. Cool season grasses may include annual bluegrass, Kentucky bluegrass, perennial ryegrass, Red Fescue, and Tall Fescue. Warm season grasses may include Bermuda grass, Kikuyu grass, Seashore Paspalum, St. Augustine grass, Zoysia grass, and Buffalo grass.

- **Functional Turf:** Turf located in a recreational use area or community space, including sports fields and Turf used regularly for human recreational purposes or community events. Turf enclosed by fencing or other barriers to permanently preclude human access for recreation or assembly is not Functional Turf.
- **Non-Functional Turf (Decorative Grass):** Turf that is solely ornamental and does not serve a community or neighborhood function, including use for recreational purposes or civic or community events.

Utility Connection Point: Point of delivery determined by the City Water Department.

Utility Services Rules and Regulations: The rules and regulations of the Municipal Services Division of the City of Santa Clara Department of Finance.

Water Feature: A design element where open water performs an aesthetic or recreational function. Water Features include ponds, lakes, waterfalls, fountains, artificial streams, spas, and Swimming Pools (where water is artificially supplied). The surface area of Water Features is included in the high water use Hydrozone of the Landscape Area. Constructed wetlands used for onsite wastewater treatment or Stormwater Best Management Practices that are not irrigated and used solely for water treatment or Stormwater retention are not Water Features and, therefore, are not subject to the water budget calculation for landscapes.

Water Service: Provision of either Potable or Recycled Water to a Customer's property or Premises through a metered Service Connection.

Water Utility: The City of Santa Clara Water and Sewer Utilities Department. The Water Utility and the City are one and the same.

2. NOTICES

2.A NOTICES TO THE CUSTOMER

Notice, under and pursuant to the effective Rules and Regulations of the City, from the City to a Customer may be given by written notice, either delivered by the City or properly enclosed in a sealed envelope and deposited in any United States Post Office postage prepaid, addressed to the Customer's last known address.

2.B NOTICES TO THE CITY

Requests for Permits or licenses pursuant to the effective Rules and Regulations of the City and notices from any Water Service Customer to the City regarding a relocation of Water Service, an increase in size of Water Service, or any material change either in the amount or type of appliances or equipment installed upon the Premises shall be presented by the Customer or authorized agents through completion of an appropriate application prior to any modification to the existing Water Service Connections or change in water use. The request shall be made, in person, or sent by postal mail or email to the following addresses, respectively:

City of Santa Clara
Water and Sewer Utilities
1500 Warburton Ave.
Santa Clara, CA 95050

Email: Water@SantaClaraCA.gov

3. APPLICATION FOR WATER SERVICE

3.A SERVICE ORDER APPLICATIONS

Application is required by the Municipal Services Division Office for any Premises on which one or more utility services are to be provided when Water Service is desired. By applying for any Water Service, an applicant indicates their willingness and intention to comply with all applicable Rules and Regulations, and to make payment for such utility services when due and in accordance with applicable rates. Application for Water Service does not in itself bind the City to serve any applicant except under reasonable conditions as determined by the City, nor does it bind the applicant to take Water Service for a longer period than the minimum requirements of the appropriate rate schedule(s).

Applications for residential, Commercial, Institutional and Industrial Service (CII) will be accepted online, by telephone or in person at the Municipal Services Division.

For new Service Connections, no meter shall be installed prior to the submittal of a utility services application. The Director of Water and Sewer Utilities may require the separation or modification of any Service Connection in order to comply with these Rules and Regulations or to facilitate the maintenance and operation of the public system.

3.B CHANGES IN WATER SERVICE

When a Customer intends to make any material change either in the amount or type of the equipment installed upon the Premises to be supplied with water by the City, the Customer shall immediately provide written notice to the City Water Utility. Failure to comply may result in a discontinuance of Water Service without notice.

Customer will be liable for damages to City Equipment and facilities resulting from the Customer's failure to provide written notification to, and approval of, the City Water Utility prior to the addition of water demand.

Customer may be subject to reassessment of rate schedule qualification as provided by these Rules and Regulations.

3.C DISCONTINUANCE OF WATER SERVICE

Only authorized City Employees are allowed to disconnect the Service Connection from City Systems. A Customer desiring termination of one or more utility Service Connections must give the Municipal Services Division not less than two (2) working days' notice and state the date on which the termination is to become effective. The Customer will be responsible for all charges associated with all utility Service Connections furnished at the Premises until such time as that utility Service Connection has been discontinued. The City may discontinue Water Service for any one or more of the reasons identified in the Utility Services Rules and Regulations, in compliance with the Water Shutoff Protection Act, Health and Safety Code Sections 116900 et. seq. related to residential customer water shutoffs for non-payment.

4. RATES

4.A RATES

The rates to be charged by and paid to the City for Water Service shall be the rates legally in effect and on file with the City Clerk, where they shall be available for public inspection.

4.B TEMPORARY RATE SCHEDULE

An applicant for Water Service may be assigned a temporary rate schedule until qualification parameters for a customary rate schedule are met. The qualification period shall not exceed twelve (12) months and any change in rate schedule due to new Water Service qualification will apply retroactive to the date of qualification under applicable rate schedule then in effect. The selection of the temporary rate shall be made by the Municipal Services Division and based on historical usage for the Premises, historical usage of the Customer, (an estimate if historical usage is not available), or as provided for by these Rules and Regulations.

4.C ESTABLISHMENT OF NEW OR OPTIONAL RATES

If the City adopts new or optional schedules or rates, the City shall take such measures as may be reasonable to advise those of its Customers who may be affected by the change.

In the case where the City adopts new rate schedules which allow a Customer to qualify for more than one rate or schedule, the Customer may request which applicable rate or schedule is desired. Upon request, the Municipal Services Division shall assist the Customer to select the most appropriate rate or schedule, or in the absence of a request, the Municipal Services Division shall have the authority to make the selection based on the available information.

4.D REASSESSMENT OF RATE SCHEDULE QUALIFICATION

A Customer may request a reassessment of their qualification for a particular rate schedule. A change to a different applicable schedule, as approved by the Municipal Services Division, shall become effective for service rendered after the next regular meter reading following the date of approval by the City. The effective date may be delayed if a change in Water Service hardware, water meter or other associated equipment is required. Notices shall be served as indicated in Water and Recycled Water system Rules and Regulations Section 2 herein.

4.E SERVICE BY FACILITIES PURCHASED FROM OTHER UTILITIES

Where the City has purchased Water Service facilities from other water utilities, the Customer shall be placed on the applicable City rate schedule.

5. METER TEST AND ADJUSTMENT OF BILLS FOR METER ERROR

5.A METER TEST

Each meter will be tested at regular intervals which shall be determined by the Water Utility.

5.B METER TEST - CUSTOMER REQUEST

1. Any Customer may, after giving not less than one (1) week's notice, request the City to test the meter serving their Premises.
2. Except as provided herein, the City may require from the Customer a fee to cover the cost of the test.
3. The fee will be refunded to the Customer if the meter is found, upon test, to register more than two (2%) percent fast under conditions of normal operation. The deposit will be retained by the City to cover test costs if the meter is less than two (2%) percent fast. The Customer will be notified, not less than five (5) days in advance of the time and place of the test.
4. A Customer shall have the right to require the City to conduct the test in their presence, or in the presence of their representative. A written report giving the results of the test will be supplied to the Customer within ten (10) days after completion of the test.

5.C ADJUSTMENT OF BILLS FOR METER ERROR

1. **Fast Meters:** When, as a result of any test, a meter is found to be registering more than two (2%) percent fast under conditions of normal operation, the City will make necessary adjustments to the Customer's bill (credit or charge) to correct the overcharge in accordance with Utility Services Rules and Regulations Section 6.H.3.
2. **Slow Meters:** Upon testing, if a meter under normal conditions is found to register less than ninety-eight percent (98%) of the actual consumption, Municipal Services Division may bill the Customer for the undercharge based on the corrected meter readings (100% actual consumption) for the period in which the meter was in use in accordance with Utility Services Rules and Regulations Section 6.H.3.
3. **Non-Registering Meters:** Municipal Services Division may bill the Customer for water consumed while the meter was not registering. At Municipal Services Division's option, the bill will be computed on an estimate of consumption based on the Customer's use during the same season of the preceding year or based on an alternate method of estimation determined by Municipal Services Division, which includes, but is not limited to, the City's experience with Customers' usage on the same rate schedule; and the general characteristics of the Customer's operations.

6. APPEAL FROM THE APPLICATION, REQUIREMENTS, OR INTERPRETATION OF THESE RULES AND REGULATIONS

6.A REQUEST FOR APPEAL

Unless California law, this Code, or an ordinance or resolution of the City prescribes an alternative procedure, any Customer may request an appeal from an interpretation, requirement or application of the Rules and Regulations. The appeal may be made by submitting a written Request for Appeal to the Director of Water and Sewer Utilities. Upon receipt of a Request for Appeal, the Director shall review the request and notify the appellant in writing of their decision within forty-five (45) days of the request. Appeal from the application, requirements or interpretation of the Utility Services Rules and Regulations shall be made in accordance with those Rules and Regulations.

6.B SUBSEQUENT APPEAL

A Customer may further appeal the Director's determination regarding the appeal from the application, requirements, and/or interpretation of these Rules and Regulations to the City Manager. Such a subsequent appeal must be made in writing and received by the City Clerk within seven (7) calendar days after receipt of the written decision by the Director.

6.C APPEAL COMPONENTS

The appeal to the City Manager shall consist of a written notice of the appeal, written details explaining the grounds on which the appeal is based, and the payment of an appeal fee set by resolution of the City Council.

6.D APPEAL TIMEFRAME

The appeal to the City Manager shall be heard within forty-five (45) days from the filing of said notice. If an address is not provided in the notice of appeal, such notice need not be given to the Customer.

6.E HEARING NOTICE

Written notice of such hearing informing the appellant of the date and time of the hearing shall be personally served upon the appellant, or on any person employed in the place where the business in question, or activity, is maintained. If service cannot be made in the foregoing manner, then a copy of such notice may be mailed to the appellant at their place of business or their last address known to the City Clerk, at least five (5) days prior to the hearing. The time of such notice may be shortened by the City Manager with the written consent of the appellant.

6.F HEARING

At the hearing, an opportunity will be afforded to the appellant and the City to make statements for the record regarding the facts in dispute and the circumstances surrounding the matter being appealed. A record of the hearing will be established.

6. APPEAL FROM THE APPLICATION, REQUIREMENTS, OR INTERPRETATION OF THESE
RULES AND REGULATIONS (continued)

6.G APPEAL DECISION

The City Manager shall render their decision within forty-five (45) days after the conclusion of said hearing. In their decision, the City Manager may reverse, set aside, affirm, amend or modify the decision of the Director. The decision of the City Manager shall be final insofar as the administrative hearing process is concerned.

7. NEW DEVELOPMENT

7.A WATER SUPPLY ASSESSMENTS

New Developments may be required to complete a Water Supply Assessment (WSA) as mandated by the State Water Code and pay for any applicable fees. All Development projects shall submit a WSA form to determine the project's demands and whether a WSA will be required unless otherwise waived by the City.

7.B DEVELOPMENT IMPACT ANALYSIS

All Developments shall request a Development Impact Analysis (DIA) from the City to determine the available fire flow capacity and residual pressure for public hydrants and onsite private fire system connections (unless waived by the Director of Water and Sewer Utilities) and pay any applicable fees. If the existing City system cannot supply the Development with the required fire flow, the Developer shall install the required infrastructure needed to supply the required fire flow at the Developer's expense.

7.C PUBLIC WATER MAINS

All new public water Mains shall be located within the paved areas of public streets and shall meet all City and State separation requirements. Onsite water Mains will not be accepted by the City, nor will easements be granted unless otherwise allowed by the Director. All existing onsite public water Mains shall be converted to a private system and all services shall be reconnected to the public system unless otherwise allowed by the Director.

7.D MAXIMIZING RECYCLED WATER USE

All Developments including multifamily and non-residential buildings shall use Recycled Water for all Non-Potable, permitted uses including, but not limited to, irrigation, Dual Plumbing, cooling, and any other commercial, industrial or institutional use as permitted. Recycled Water shall be used for all construction activities for Developments.

7.E RECYCLED WATER CONVERSION

All Developments that are required to use Recycled Water shall convert any existing non-domestic water use that is eligible for Recycled Water into an approved Onsite Recycled Water system at the Developer's expense.

7.F RECYCLED WATER READY

Where Recycled Water is not available, as determined by the Director, the project shall be designed to receive Recycled Water in the future. All onsite plumbing for non-domestic water uses (irrigation, industrial processes, cooling, etc.) shall be designed for Recycled Water use and shall comply with all Recycled Water regulations.

7. NEW DEVELOPMENT (continued)

7.G GRAYWATER READY

When a Development chooses to use a Graywater dual drainage laundry plumbing system, alternative plumbing piping shall be installed to permit the discharge from the clothes washer or other fixtures to be used for an irrigation system in compliance with the California Plumbing Code.

7.H MAIN EXTENSIONS AND UPSIZING REQUIRED FOR FIRE DEMAND USE

Applicants, subdividers or property Developers may be conditioned to extend and/or upsize a water Main in order to comply with the City's design and fire protection criteria. The size and extent of the upsize and/or extension shall be determined by the results of the DIA and shall be installed at the Developer's expense.

7.I MAIN EXTENSIONS FOR RECYCLED WATER USE

Applicants, subdividers or property Developers may be conditioned to extend a Recycled Water Main at the Developer's expense in order to comply with the City's requirement to maximize the use of Recycled Water permitted on the Premises. The limit of the extension shall be determined by the Director of Water and Sewer Utilities.

7.J MAIN REPLACEMENT

Main replacement for the water and Recycled Water system for new Developments shall be required where additional services are expected to accelerate the loss of integrity of the existing water or Recycled Water Main. The limits of the replacement shall extend between the nearest valves located beyond the project frontage or as required by the Director.

7.K WATER MAIN TIE-INS TO THE CITY'S WATER SYSTEM

1. Tie-ins to the City's Water System shall not be performed without the authorization of the Water Utility and under the observation of a representative from the Water Utility.
2. Contractor shall notify the Water Utility of all proposed tie-ins and shall provide a tie-in plan which includes, at a minimum, the location and sequence of all tie-in connections, the proposed sampling locations, a disinfection plan, a directional flushing plan, a shutdown plan, all City Water System valves that will be utilized, a list of all Customers that will be impacted by the tie-in plan along with supporting exhibits and an implementation schedule prior to the initiation of construction.
3. The tie-in plan shall reduce or eliminate the number of non-isolated tie-ins planned in favor of using isolated tie-ins to the City's Water System.
4. The City cannot guarantee a complete water shutdown; Contractor is responsible for providing adequate dewatering efforts to complete tie-in work.
5. Contractor shall be responsible for providing temporary water connections to critical services that are required to stay in service during the tie-in or where a tie-in duration will affect a critical service's normal operation.
6. All tie-ins shall be restrained in accordance with City Standards.

7. NEW DEVELOPMENT (continued)

7. Bacteriological testing will be provided by the City for all initial sampling approved by the City. It is the Contractor's responsibility to pass all bacteriological testing. Any additional disinfection, sampling, flushing, or chlorination performed by City forces or consultants, including any overtime needed, in response to a failed bacteriological test shall be charged to the Contractor. No bacteriological testing shall be performed on Thursday, Friday, Saturday or Sunday unless otherwise approved by the Director.
8. Contractor shall notify all impacted users ten (10) calendar days prior to any approved shutdown and provide the City with a sample of the notification and a summary of the outreach performed.

7.L WORK OUTSIDE OF THE CITY'S NORMAL WORK HOURS

1. The Water Utility does not regularly work outside of normal working hours, but in rare and exceptional circumstances, the City may consider it pursuant to the following conditions.
2. Construction work for the installation of water infrastructure shall not be performed outside of normal City work hours without the written authorization of the Director. Contractor shall exhaust all options prior to requesting work outside of normal City work hours.
3. Requests for work outside of normal City work hours must be submitted to the Water Utility six (6) weeks prior to the proposed date of the work. The request shall discuss the options considered by the Contractor and the reasons why work cannot be performed within normal work hours and shall include a tie-in plan if the work will involve a shutdown of a portion of the City's Water System.
4. Contractor shall pay all applicable fees for work outside of normal work hours prior to the proposed date of work.

7.M DEVELOPMENT SHALL INSTALL BACKFLOW PREVENTION DEVICES

Unless otherwise required by Title 17 or any successor regulation, all Developments except single-family homes, duplexes and Accessory Dwelling Units (ADUs), shall install a Backflow device that meets City's current standard on every Potable Water Service Connection to the Premises.

7.N UPGRADING SERVICE CONNECTIONS TO MEET CURRENT STANDARD

Unless otherwise required by Title 17 or any successor regulation, all Developments except single-family home remodels, with existing Backflow Prevention Devices which do not meet the City's current Standard or, in the opinion of the Director, do not provide adequate protection from Backflow, shall be upgraded at the Developer's expense. Upgrading may include complete replacement and relocation of the Backflow Prevention Device and meter assembly, installation of additional devices and /or correction of any onsite Cross-Connection hazards. All upgrades to Fire Service Connections shall require the approval of the City Fire Department prior to installation.

7. NEW DEVELOPMENT (continued)

7.O SEPARATE SERVICES

All Developments shall provide Separate Service Connections for each type of water and Recycled Water use, such as, but not limited to, domestic, fire, irrigation, Dual Plumbing, cooling, industrial water use, and for each type of land use such as, but not limited to, residential, commercial, industrial use on the Premises, each separately metered and tapped at the water Main. Multiple water uses shall not be served by a single Service Connection. All services shall be metered separately.

7.P MINIMUM SERVICE SIZE FOR SINGLE-FAMILY HOMES

The minimum meter and service size for a new single-family home, remodel or ADU with a fire sprinkler shall be a one-inch (1") meter and Service Connection.

7.Q SUBMETERING

All Developments shall comply with the Submetering requirements of the California Water Code, Health and Safety Code and Building Code. All requests for exemptions shall be submitted to the City's Building Official.

7.R PRIVATE WELLS

1. It shall be the responsibility of the Owner/Developer to disclose the existence of all water wells on the property to be developed. The locations of all existing wells shall be shown on all site plans and included with Permit applications to the City for any onsite modifications or construction.
2. All Developments with existing private wells shall be assessed for Cross-Connection hazard and may be required to be removed if deemed a "high hazard" by the City.
3. Developments that are required to remove existing wells shall destroy all existing wells in accordance with all applicable regulations prior to connection to the City's Water System whether expressly stated or not.
4. The well or wells shall be sealed in accordance with the Standards promulgated by Santa Clara Valley Water District. A copy of the Destruction Permit issued by the District, indicating that the well or wells have been properly sealed, shall be submitted to the City as evidence thereof.

7.S DEVELOPMENT REVIEW

Prior to submitting any projects for Water Service, the Developer shall submit a site plan showing all existing utilities, trees, structures and easements to the Water Utility. Developer shall then contact the City Water Utility for requirements and prepare the site plan resolving coordination of all utilities. Charges for new Service Connections are payable in advance and shall be in accordance with the applicable sections of the City Code.

7. NEW DEVELOPMENT (continued)

7.T UTILITY CLEARANCES

The Developer shall maintain a minimum of one foot (1') of vertical clearance measured from outside diameter to outside diameter at all Water Service crossings with other utilities, and the following required minimum horizontal clearances, measured from outside diameter to outside diameter of edge, from Water Services:

- (a) ten feet (10') from sanitary sewer utilities,
- (b) ten feet (10') from Recycled Water utilities,
- (c) eight feet (8') from storm drain utilities,
- (d) five feet (5') from fire and other water utilities,
- (e) three feet (3') from abandoned Water Services,
- (f) five feet (5') from gas and electric utilities,
- (g) seven feet (7') from high pressure gas mains,
- (h) five feet (5') from the edge of the proposed or existing driveway, and
- (i) five feet (5') from structures, poles and fountains.

All trees, existing and proposed, shall maintain a minimum clearance of ten feet (10') from any existing or proposed water facilities. If tree root barriers are used, clearance from trees reduces to five feet (5') measured from the edge of the tree root barrier to the edge of water facilities. Existing trees that conflict shall be removed. Trees shall not be planted in water easements or public utility easements.

No structures (fencing, foundation, etc.) or treatment facilities (biofiltration swales, etc.) shall be placed over utilities and utility easements.

7.U RELOCATION OF EXISTING FACILITIES

No existing City facility shall be relocated prior to the authorization of the City and the cost of the relocation shall be paid for by the Developer.

7.V RIGHTS OF WAY

Water easements shall be provided by Customer for all City Water Utility facilities located outside of the public right of way. City will determine the location of easements and prepare document(s) at Customer's expense, for Customer's signature, unless easements are dedicated on a Tract or Parcel map. The City is not obligated to accept an easement or any public improvement installed within an easement on private property.

7.W OBLIGATION TO PROTECT EXISTING PUBLIC UTILITIES

Any Contractor performing any work within the public right of way or within 10 feet of an existing public water or Recycled Water Main, service, Appurtenance or facility shall be responsible to locate the facility and protect it in place prior to construction activity.

Contractor shall not proceed with any construction activity within a public right of way or easement that includes an existing public water or Recycled Water Main, service, Appurtenance or facility prior to receiving approval from the Water Utility.

7. NEW DEVELOPMENT (continued)

If any existing public utility Main, service, Appurtenance or facility is damaged as a result of the Contractor's activity, Contractor shall be responsible for the repair and/or replacement of the damaged utility infrastructure and all associated costs including, but not limited to, bypass improvements, shutdowns, monitoring, mitigations for discharges into the storm or sewer system, overtime charges, traffic control, Permitting, inspection and reporting to Regulatory Agencies.

7.X DEMOLITION PERMITS

Contractor and Owner shall disconnect all existing Water Services prior to issuance of onsite construction Permits and commencement of onsite demolition work. Demolition work shall not commence without prior verification that utility services have been disconnected.

7.Y NEW SERVICE APPLICATIONS

1. Contractor Owner shall submit new Water Service applications to the Water Utility for all Service Connections prior to the issuance of any encroachment Permit which will install or modify a Water Service Connection. New meters will not be released or installed if a complete Customer account is not on file with the City at the time of meter installation.
2. Contractor or Owner shall be billed for all water usage generated from the date of meter installation.

7.Z RECORD DRAWINGS

Record Drawings shall be prepared to show all utility improvements as constructed and shall include all changes in work constituting departures from the City approved design drawings. Record Drawings shall be submitted to the City for review and approval prior to building occupancy. A GIS-compatible file shall be submitted with the Record Drawings which contains geospatial data of the new improvements that can be directly incorporated into the City's GIS system.

8. AFFORDABLE HOUSING PROJECTS

8.A DEFINITIONS

“Proposed Developments that include housing units affordable to lower income households” shall have the same meaning as set forth in Government Code Section 65589.7(d)(1).

8.B PRIORITY IN THE EVENT OF SERVICE LIMITS

In the event the City experiences service limitations due to constraints in water supply or in wastewater treatment and disposal capacity or regulatory restriction, the City shall grant a priority for the provision of future water and sewer service to proposed Developments that include housing units affordable to lower income households. The City shall apply the following priorities in descending order:

1. Continued service to existing connections and Customers.
2. Existing commitments contained in Development agreements.
3. Proposed Developments that include housing units affordable to lower income households.
4. New Developments on existing in-fill, developable parcels.
5. Other new Developments.

8.C PROHIBITION ON DENIAL OR CONDITIONING OF SERVICE

The City shall not deny or condition the approval of an application for services to, or reduce the amount of services applied for by, a proposed Development that includes housing units affordable to lower income households unless the City makes specific written findings that the denial, condition, or reduction is necessary due to the existence of one or more of the following:

1. The City does not have “sufficient water supply,” as defined in Government Code Section 66473.7(a)(2), or is operating under a water shortage emergency as defined in Water Code Section 350, or does not have sufficient water treatment or distribution capacity to serve the needs of the proposed Development, as demonstrated by a written engineering analysis and report.
2. The City is subject to a compliance order issued by the State Department of Health Services that prohibits new water connections.
3. The City does not have sufficient treatment or collection capacity, as demonstrated by a written engineering analysis and report on the condition of the treatment or collection works, to serve the needs of the proposed Development.
4. The City is under an order issued by a State Water Resources Control Board that prohibits new sewer connections.
5. An applicant has failed to agree to reasonable terms and conditions relating to the provision of service generally applicable to Development projects seeking service from the City, including, but not limited to, the requirements of local, state or federal laws and regulations or payment of a fee or charge imposed pursuant to Government Code Section 66013.

9. ACCESS, INTERFERENCE, TAMPERING, AND THEFT

9.A CITY RIGHT OF ACCESS

The City shall have immediate and unhindered access, without notice, to and from a Customer's Premises for any purpose reasonably connected with the furnishing of Water Services, including but not limited to the abatement of water waste, inspection, reading, testing, maintenance, removal, and replacement of City Equipment. The Water Utility and Municipal Services Division jointly and singly retain the authority to enforce these provisions.

When access is not immediate and unhindered, the City may issue citations with the following graduated levels: notice of denied access, warning of impending citation, citation, warning of impending civil/criminal action, or any other enforcement remedy provided for in the City Code. The City may require the Customer to provide, without cost to the City, a new approved location for equipment or to re-establish the immediate and unhindered access to the previously approved location.

9.B WORK OUTSIDE CITY'S OPERATING CONVENIENCE

When requested by the Customer, and where circumstances permit some flexibility in scheduling of necessary repairs or improvements, the City may at its sole option perform the work during other than normal City working hours for the increased convenience of the Customer, providing that the Customer acknowledges in writing, prior to the performance of said work, their willingness to pay for any costs incurred by the City as a result of performing said work at other than during normal City working hours.

9.C INTERFERENCE

Any person preventing or interfering with any City Employee in the lawful discharge of duties is subject to penalties, prosecution, and punishment.

9.D TAMPERING

To rearranging, bypassing, damaging, altering, breaking, preventing normal function of equipment in any way, or preventing access to Service Connection or other City owned facilities may be considered Tampering. It shall be unlawful for, and the City may immediately discontinue Water Service and bring a criminal action against, any person, firm, corporation or association that commits, authorizes, solicits, aids, abets or attempts to:

1. Change the intended course or path of Water Services without authorization from the City.
2. Make, or cause to be made, any connection or restoration with property owned or used by the City to provide Water Services.
3. Prevent any water meter, or other device used to determine the amount of water consumed by a Customer, from accurately performing its measuring function.
4. Tamper with, or otherwise access without permission from the City Water Utility, any property owned or used by the City to provide Water Services.
5. Use or receive Water Service without consent of the City or payment of all lawful charges.

9. ACCESS, INTERFERENCE TAMPERING AND THEFT (continued)

9.E THEFT

It is unlawful for any person to use, divert, receive or take water from the City Water System from any public fire hydrant, blow-off valve, water Main, Water Service lateral or other City facility or connection to a City facility without the authorization of the City.

9.F FRAUD

The City may discontinue the Service Connection without notice if a Customer's actions or the conditions of the Premises indicate the Customer's intent to defraud the City.

9.G LIABILITY, PENALTY, PROSECUTION AND PUNISHMENT FOR VIOLATION

1. Legal liability and responsibility, for violation of these Rules and Regulations, lies with the Customer of record and/or any additional recipient who benefits from the Water Service.
2. For violation of the Rules and Regulations set forth regarding interference, Tampering or theft, the City shall levy a charge set forth in the City of Santa Clara Municipal Fee Schedule, adopted by resolution of the City Council.

9.H CIVIL ACTION

In any civil action brought, the City may recover three times the amount of actual damages, plus the cost of the suit, reasonable attorney's fees and any other amounts allowed by law. In addition, the City may bring an action to enjoin and restrain any violation of these Rules and Regulations.

10. TEMPORARY WATER SERVICE

Temporary Water Service, as herein considered, refers to service of a temporary nature or of questionable permanency. The City shall, if no undue hardships result therefrom, furnish temporary service under the following conditions:

10.A TIME LIMIT

Temporary Service Connections shall be disconnected and terminated within twelve (12) months after installation unless an extension of time is granted in writing by the City. (See Chapter 13, Article II of the City Code for rules and regulations concerning temporary service from fire hydrants.)

10.B CHARGE FOR WATER SERVED

Charges for water furnished through a Temporary Water Service Connection shall be at the established rates for regular Customers.

10.C INSTALLATION CHARGE AND DEPOSITS

The applicant for temporary service will be required:

1. To pay to the City in advance the estimated cost of installing and removing all facilities necessary to furnish such service, unless other arrangements are approved by the City Council. If service is supplied through a fire hydrant and hydrant meter, the applicant will be charged in accordance with the established rate schedule in effect at the time application is made.
2. To deposit with the Municipal Services Division an amount sufficient to cover bills for water during the entire period such temporary service may be used, and as set forth in the City's Municipal Fee Schedule service deposits in effect at the time.
3. Nothing in these Rules and Regulations shall limit or affect the right of the City to collect from the Customer any other or additional sums of money which may become due and payable to the City from the Customer by reason of the Temporary Water Service furnished or to be furnished. The City may refuse Water Service if, in the judgment of the City, unsafe or hazardous conditions exist.

10.D REFUNDS

A refund of the Temporary Water Service deposit less applicable fees or charges will be applied to the Temporary Water Service closing bill. An Owner of the Premises, executive officer of corporation, or business, with an unpaid closing bill can transfer the outstanding balance to any existing or future accounts without regard to Customer class.

10.E TEMPORARY WATER PERMIT

1. Any person or company desiring to use water drawn from a fire hydrant for the purpose of spraying, jetting or dust control or for any other reason must first obtain a temporary water Permit by applying to the Water Utility. (See Section 16.D.)
2. It is specifically prohibited to operate the valve of any fire hydrant other than by the use of a spanner wrench designed for this purpose.

10. TEMPORARY WATER SERVICE (Continued)

3. It is unlawful for any person, except the City's Fire Department, to take water from any City fire hydrant or any City Water facilities, without first obtaining a Permit and complying with the City's Potable and Recycled Water System Rules and Regulations.

11. SHORTAGE OF SUPPLY AND INTERRUPTION OF DELIVERY

11.A WATER SUPPLY

The City will exercise reasonable diligence and care to furnish and deliver a continuous and sufficient supply of Water Services to the Customer, but does not guarantee continuity or sufficiency of supply. The City will not be liable for any damage resulting from the interruption, shortage, or insufficient supply of Water Services to the Customer.

11.B TEMPORARY WATER SERVICE SUSPENSION

The City will have the right to suspend temporarily the delivery of Water Service whenever necessary to make repairs or improvements to its system. Reasonable notice, as circumstances permit, will be given to the Customers, and the repairs or improvements will be completed as rapidly as possible during normal City working hours, and where possible, with the least inconvenience to the Customers.

11.C APPORTIONMENT OF WATER SUPPLY

If a shortage of supply occurs, the City will make an apportionment of the available supply of water among Customers as ordered or directed by the City Council. In the absence of an order or direction by the City Council, the City Manager will apportion the available supply of water among Customers in a reasonable manner.

12. DESCRIPTION OF STANDARD WATER SERVICE

12.A NUMBER OF SERVICES TO SEPARATE PREMISES

Except as otherwise provided in Section 12.B below, separate Premises under single control or management shall normally be supplied through Separate Service Connections. The Customer may request a single Service Connection with a master meter, whereupon the City shall evaluate Customer's request and, at City's option, accept a single service.

12.B SERVICE TO MULTIPLE UNITS

1. Separate residential houses, apartments or other multifamily accommodations, or business establishments on the same Premises or on adjoining Premises under a single control or management may be served by the following methods, as detailed below:
 - (a) Through a single metered Service Connection to the entire Premises, as provided in Rate Schedule.
 - (b) Through separate metered Service Connections to each or any group of units, provided that the system from each service is independent and not interconnected with any others.
 - (c) If a master meter is used to serve multiple residential or commercial units, then the Owner shall install Submeters to measure the quantity of water used by each unit and shall comply with all applicable State regulations.
2. For Developments other than ADUs, the City may select the methods listed above in Section 12.B.1(a) or 12.B.1(b), taking into consideration the Customer's preference.
3. ADUs constructed on lots with single-family zoning or on lots with an existing single-family dwelling shall be served by the method described in Section 12.B.1(a) above.
 - (a) Notwithstanding the foregoing, ADUs shall be served by the method described in Section 12.B.1(b) if the ADU(s) is constructed at the same time as a new single-family dwelling, or in the event the property Owner requests to have Separate Service Connections.

12.C SINGLE METER SERVICE TO MULTIPLE TENANTS/UNITS

1. When separate domestic and/or Commercial Services are served on the same Premises through a single-metered Service Connection (master meter), the Owner may resell water to tenants of the Premises at rates identical with the rates of the City that would apply if that Water Service was supplied to the individual tenants or units directly by the City, regardless of the rate the Owner is charged, provided the Owner complies with either 12.C.1(a), 12.C.1(b) or 12.C.1(c). Within thirty (30) days upon written request by the City, the Owner must submit four (4) consecutive quarterly water billing summaries to the City for compliance auditing purpose.
 - (a) Water is separately metered to the individual tenants or units.

12. DESCRIPTION OF STANDARD WATER SERVICE (Continued)

- (b) Water is not separately metered. The Owner shall be responsible for purchase of all water used for landscape irrigation and other common area uses. The tenants shall receive separate bills for the water used by the tenants alone without any incremental charges (service or handling) billed to tenants' accounts. For residential accounts, the charge to the tenants for water shall be derived from a consistent formula for allocation that includes the number of individuals in each household (e.g., 100% occupancy or 50% occupancy and 50% square footage). For non-residential master-metered accounts, the amount allocated to each tenant shall be consistently calculated based on a formula that includes a reasonable standard for water use at each business type and square footage of each tenant's unit.
 - (c) The charge to the tenants for such water is absorbed in the rental charges for that individual tenant or unit with no separate identifiable charge for water, and the rent does not vary with water consumption.
- 2. If water is resold otherwise than provided for above, the City may discontinue service to the Owner, or furnish water directly to the individual tenants or units through separate meters installed at the sole cost of the Owner.
- 3. Under these Rules and Regulations, the responsibility for payment for all Water Services furnished to individual tenants or units on the same Premises and supplied through a single Service Connection shall be the obligation of the Owner. It shall further be the Owner's responsibility to inform individual tenants or units of the method of metering Water Services. The City will have no contractual relationship with tenants of individual units where a Customer receives service through a single metered connection, nor a relationship created by payments made directly to the City on behalf of the Owner by tenants or other third parties.
- 4. As a condition of service for single metered service, the Owner has agreed to be governed by the applicable City Rules and Regulations. As a further condition of service for single metered service, the Owner has agreed that the City may inspect and examine the Owner's billing procedures from time to time to determine that such service is made in accordance with these Rules and Regulations, or as otherwise may be authorized by the City.

13. RESPONSIBILITY FOR EQUIPMENT AND PROTECTIVE DEVICES

13.A RESPONSIBILITY FOR EQUIPMENT

1. The Customer shall, at the Customer's risk and expense, furnish, install and keep in good and safe condition equipment and suitable housings that may be required for receiving, controlling, applying and utilizing water, regardless of the location of the meters, or other City Equipment, and the City shall not be responsible or liable for any loss or damage caused by the improper installation of such water equipment, or the negligence, want of proper care or wrongful act of the Customer or of any of the Customer's tenants, agents, employees, contractors, licensees or Permittees in installing, maintaining, using, operating, Tampering, or interfering with such equipment. The City shall not be responsible or liable for damage to Customer's property and/or equipment, either when the water is turned on originally or when turned on after a temporary shutdown, during normal operating conditions, times of local or system trouble and/or after restoration. The City shall not be responsible or liable for damage to, or the failure of, any component of the Customer's equipment due to a defect in Customer's equipment or failure to maintain adequate protection as described in these Rules and Regulations.
2. The Customer shall exercise reasonable care to prevent City Equipment on the Customer's Premises from being Tampered or interfered with, damaged, or destroyed. The Customer shall be liable for damage to City Equipment arising from negligence, want of proper care, or wrongful act of the Customer or Customer's tenants, agents, employees or contractors. If any defect is discovered by the Customer, the Customer shall promptly notify the City.

13.B PROTECTIVE DEVICES

1. It is the Customer's responsibility to furnish, install, inspect and keep in good and safe condition at that Customer's own risk and expense, all appropriate protective devices of any kind or character, which may be required to properly protect the Customer's facilities and equipment from any event caused without negligence by the City or from any event caused by another Customer. The City is not responsible or liable for any loss or damage occasioned or caused by the negligence, or wrongful act of the Customer, or of any of that person's agents, employees or licensees in omitting, installing, maintaining, using, operating or interfering with any such protective devices.
2. It is the Customer's responsibility to select and install such protective devices as may be necessary to coordinate properly with the City's protective devices to avoid exposing other Customers to unnecessary Water Service interruptions. Failure to provide appropriate protective devices or to properly coordinate said equipment with the City's protective devices may result in discontinuance of Water Service.

14. SERVICE CONNECTIONS AND METERS

14.A SERVICE CONNECTIONS

Water Service Connections will be installed in the size and at the location desired by the applicant where such requests are reasonable and in accordance with City Standards. Service Connections will be made only to property abutting on public streets or to such distribution Mains as may be constructed in alleys or rights-of-way at the convenience of the City. Charges for new Service Connections are payable in advance and shall be in accordance with applicable sections of the Code.

14.B METERS

1. A separate Water Service Connection is required for each water use on a Customer's Premises including, but not limited to, domestic, fire, irrigation, cooling, industrial processes and other uses.
2. A separate Water Service Connection is required for each land use on a Customer's Premises including, but not limited to, residential, commercial, industrial and other uses.
3. All Service Connections shall be individually metered with the exception of Fire Service Connections.
4. The minimum meter and service size for any new service shall be a one-inch (1") meter and Service Connection.
5. Existing services that remain on new Development projects or tenant improvement projects shall be reviewed for compliance with AWWA minimum sizing requirements.
6. When an authorized service entrance has been established, meters will normally be furnished and installed between the curb and the property line. The charges for meters shall be in accordance with applicable sections of the Code.
7. No rent, or other charge, will be paid by the City for a meter or other facility, including housing and connections, located on a Customer's Premises.
8. All meters will be sealed by the City at the time of installation, and no seal shall be Tampered with or broken by the Customer at any time thereafter.
9. The City reserves the right to meter any and all services and to apply the established metered rates to the quantity of water measured by them.

14.C CHANGES IN LOCATION OF METERS AND SERVICE CONNECTIONS

Meters or services moved for the convenience of the Customer will be relocated at the Customer's expense.

14.D CHANGES IN SIZE OF METER

Upon request of a Customer and subject to the approval of the Director, the size of an existing meter may be changed at the Customer's expense. After the meter change is made, the monthly rates shall be adjusted to reflect the change in meter size.

14. SERVICE CONNECTIONS AND METERS (Continued)

14.E SUBMETERING

All Developments shall comply with the Submetering requirements of the California Water Code, Health and Safety Code and Building Code. All requests for exemptions shall be submitted to the City's Building Official.

14.F OWNERSHIP

The Service Connection, whether located on public rights-of-way or easements through private property, is the property of the City; the City reserves the right to repair, replace and maintain it, and to remove it upon discontinuance of service.

14.G MAINTENANCE

The Service Connection, including the meter and the meter box, will be repaired and maintained by the City at its expense except for damages as set forth in Section 13. The City is not responsible for the installation and/or maintenance of water lines beyond the end of its Service Connections and/or meter.

14.H SPLIT SERVICE CONNECTIONS

The City, in several locations, has installed in residential subdivisions two meters on a common service, known as a "split service." In the event that a Customer wishes a single service to replace the split service, the charges will be in accordance with the City Code for a new one-inch (1") service including street opening fees.

15. FIRE SERVICE CONNECTIONS

15.A PURPOSE

A Fire Service Connection of four-inch (4") diameter or larger, up to one size increment smaller than the size of the connected Main, will be permitted in accordance with City Standards only if adequate provision is made to prevent the use of water from such Service Connection for purposes other than fire extinguishing.

15.B REQUEST AND APPLICATION

1. All requests for Fire Service Connections shall require an encroachment Permit from the Department of Public Works and shall be approved by the Water Utility.
2. All new Fire Services or existing services that will install a new Backflow Prevention Device or upgrade an existing Backflow Prevention Device require the approval of the City Fire Department.
3. The Permit submittal shall meet the requirements of the Development review and Permitting process and shall, at a minimum, include a location map with a job title and the date the service is needed.
4. The Contractor or Owner shall submit an encroachment Permit application for the Fire Service at the Department of Public Works and shall also submit an application for all necessary fire Permits with the City Fire Department.

15.C BACKFLOW PREVENTION DEVICES FOR FIRE SERVICE CONNECTIONS

1. An approved Backflow Prevention Device is required for all Fire Service Connections to Premises receiving water from the City. The Backflow Prevention Device shall be placed at the Service Connection or at a location approved by the City. Backflow Prevention Devices shall comply with all requirements of Section 19, Cross-Connections, of these Rules and Regulations and the City's Standard Details.
2. The applicant shall design the onsite fire suppression system to accommodate the available pressures and flow downstream of the Backflow Prevention Device and shall make any necessary modifications to an existing system to ensure that it complies with the requirements of the City Fire Department.

15.D MINIMUM SIZE FOR SINGLE-FAMILY HOMES WITH FIRE SPRINKLERS

The minimum size Service Connection for single-family homes and ADUs with an automatic fire sprinkler system is a one-inch (1") Service Connection and meter.

15.E INSTALLATION CHARGES FOR CITY WORK

If the applicant requests that the City installs the Fire Service Connection, the applicant will be required to make payment of the fees as specified in the Code for the Fire Service in advance of installing the Service Connection.

15. FIRE SERVICE CONNECTIONS (Continued)

15.F QUANTITATIVE CHARGES

1. Water for Fires: No charge will be made for water used to extinguish fires.
2. Water for Fire Storage Tanks: Occasionally water may be obtained from an automatic sprinkler service for filling a storage tank connected with Fire Service, but only if written permission is secured from the Water Utility in advance and an approved means of measurement is available. The rates for general use will be applied.
3. Other: Water lost through leakage or in unauthorized testing or used in violation of these Rules and Regulations shall result in an imposition of regular Water Service rates on the Fire Service account for a minimum of three billing cycles or longer, until such time as illicit use of water through the Fire Service Connection is discontinued.

15.G TESTING

The Owner shall request the authorization of the Water Utility for testing or use of a Fire Service Connection prior to scheduling. The request shall be in writing and may be delivered in person or by email to Water@SantaClaraCA.gov. The water used shall be tracked and reported to the Water Utility and shall be charged at the regular Water Service rate.

15.H VIOLATION OF RULES AND REGULATIONS

If water is used from a Fire Service in violation of the agreement or of these Rules and Regulations, the City may, at its option, discontinue and remove the service.

15.I OWNERSHIP OF CONNECTION

The Service Connection and all equipment Appurtenant thereto shall be the sole property of the City, and no part of the cost thereof will be refunded to the applicant.

15.J PRESSURE AND SUPPLY

The City assumes no responsibility for loss or damage because of lack of water or pressure and merely agrees to attempt to furnish such quantities and pressures as are available in its general distribution system. The service is subject to shutdowns and variations required by the operation of the system or due to accidents beyond the ability of the City to control.

15.K FIRE FLOW AND DEVELOPMENT IMPACT REQUESTS

1. Applications for fire flow data and Development Impact Analysis (DIA) may be submitted to the Water Utility in person or by email to Water@SantaClaraCA.gov.
2. Fees for the fire flow analysis and/or DIA are payable in advance and shall be in accordance with the applicable section of the Code.
3. The City performs all fire flow analysis and DIA on a hydraulic model.
4. Fire flow data and DIA results may vary over time due to changes in the City's Water System or discrepancies between in-field fire flow results and fire flow results from hydraulic modeling.

15. FIRE SERVICE CONNECTIONS (Continued)

5. The applicant or Owner is responsible for meeting the requirements of the City Fire Department and Water Utility at all times and may be required to modify their fire sprinkler system based on the most current fire flow data in order to meet the Fire Department's requirements and the Water Utility's requirements.

15.L RATES

Monthly charges furnished for fire sprinkler service shall be at the established rates.

16. FIRE HYDRANTS

16.A USE OF AND DAMAGE TO FIRE HYDRANTS

No person or persons, other than those designated and authorized by proper authority, shall open any fire hydrant, attempt to draw water from it or in any manner damage or Tamper with it. Any violation of this regulation is punishable by law, and in accordance with City Code.

16.B MARKING OR COLOR CODING OF FIRE HYDRANTS

1. Public Hydrants: All public hydrants including, but not limited to, hydrants which are municipally installed, operated, controlled and maintained shall have white barrels or bodies with the color coding, marking, or stenciling as required by the State Fire Marshal.
2. Private Hydrants: All private hydrants shall have the barrel, top, and nozzle caps painted "safety yellow" to distinguish them from public hydrants.

16.C MODIFICATION OR RELOCATION OF FIRE HYDRANTS

1. The City, at its sole discretion, reserves the right to install a new fire hydrant or to relocate an existing fire hydrant to a new location within the right of way or along the frontage of a Customer's Premises.
2. If a property Owner, or other party of a developed or redeveloped Premises, desires a change in the size, type or location of an existing fire hydrant, said Owner or other party shall bear all costs of such changes, without refund.
3. Any change in the location of a fire hydrant must be approved by the Water Utility and the Fire Chief.

16.D WATER FROM FIRE HYDRANTS

1. Permit to Use Water is Required: It shall be unlawful for any person to take water from any City fire hydrant or any City water facility without first obtaining a Permit and complying with these Rules and Regulations.
2. Application; Issuance and Deposit: The Permits required by the preceding section will be issued by the Water Utility. Applications for the temporary use of water from a public fire hydrant shall be filed with the Water Utility Office at City Hall. The application shall include an exhibit showing the location(s) of the fire hydrant(s) that will be used.

After application to and approval of the Water Utility , the applicant shall pay a deposit to the Municipal Services Division Office, a portion of which is non-refundable. (The refundable portion of a deposit is not normally required of other public agencies or utilities.) A copy of the receipt confirming payment shall then be provided to the Water Utility.

3. Denial or Revocation: The City shall have the right to refuse or revoke any Permit issued pursuant to these Rules and Regulations.

16. FIRE HYDRANTS (Continued)

4. Issuance of Equipment; Manner of Using Water; Water Meters Generally: An appointment will be scheduled for the Water and Sewer Utilities Meter Shop to issue and install the portable water meter and Backflow Prevention Device with hose adapter for connection to the City fire hydrants. No other equipment, tools or accessories shall be furnished by the City. All water used must be taken through the water meter and Backflow Prevention Device. The water meters and Backflow Prevention Device assemblies shall be locked by the City. The Permittee shall not make any modifications, Tamper, remove or relocate the portable water meter and Backflow Prevention Device without the prior approval of the Water and Sewer Utilities Meter Shop.

The Water Utility shall have the right to test and inspect these devices to ensure that they are working in a satisfactory manner. All meters shall be tested by the Water and Sewer Utilities Meter Shop every six (6) months, at a minimum. Service of water shall be immediately discontinued by the Water Utility if the Backflow Prevention Device is not installed, if the relief valve is Tampered with or dumping, if it is found that the Backflow Prevention Device has been removed or bypassed, if unprotected Cross-Connections exist on the Premises, or if the Customer fails to timely report their meter reading or pay any charges due here under. Service will not be restored until such conditions are corrected.

The applicant shall immediately notify the Water and Sewer Utilities Meter Shop at the time the hydrant meter is no longer being used. An appointment will be scheduled for the Water and Sewer Utilities Meter Shop to remove the portable water meter and Backflow Prevention Device from the hydrant.

5. Reading of Water Meters and Rendering of Accounts; Water Drawn for Use Outside City
 - (a) Meters provided for in the preceding section shall be read monthly. The meter reading shall be recorded and sent to the Water Utility by email at Water@SantaClaraCA.gov by the fifth (5th) of each month (20th).
 - (b) Accounts whose meters are not read during this period shall be billed the monthly minimum for a three-inch (3") meter and this amount shall not be applicable as payment toward water used, either previously or thereafter. In addition to the monthly minimum, the Permittee remains responsible for the full amount of water actually used. Accounts shall be billed monthly for water used at the rates established therefore by the City. Water drawn for use in projects outside the City shall be billed and paid for at one and one-half (1.5) times the established City rates.
6. Return of Equipment to City; Final Billing, etc.: When water is no longer needed, the water meter and other equipment shall be returned to the Water Utility corporation yard and checked in. The deposit, less the cost of any damage to the meter or hydrant that was used and less the final billing on water usage, shall be returned to the Permittee.
7. Additional Penalty for Violation of Article; Duties of the Director of Water and Sewer Utilities: In addition to the penalty provided in the City Code, any person violating any provision of the article may be required to pay two (2) times the rate for the water taken, based on an estimate of the quantity of water taken. Such estimate shall be made by the Director.

17. SWIMMING POOLS AND TANKS

17.A FILLING SWIMMING POOLS AND TANKS

The use of Swimming Pools shall be subject to the requirements of Title 17 and all successor regulations.

When an abnormally large quantity of water is desired for filling a Swimming Pool or for other purposes, arrangements may be required prior to taking such water. Permission to take water in unusual quantities will be given only if it can be safely delivered through the City's facilities, if other Customers are not inconvenienced, and if there is no mandatory water rationing in effect at the time of the request. All water used shall be metered and billed for in accordance with prevailing rate schedules.

1. All heated or unheated Swimming Pools and spas that are newly constructed or undergoing additions or alterations within the property lines of a parcel with a single-family Residential dwelling shall be equipped with a non-liquid vapor retardant cover having a manual or power-operated reel system.
 - (a) For irregular-shaped Swimming Pools and spas for which it is infeasible to cover 100 percent (100%) of the Swimming Pool or spa with a reel system due to its irregular shape, other types of covers may be allowed.
 - (b) Additions or alterations to existing Swimming Pools and spas with a valuation not exceeding \$25,000 are exempt from this section.

18. CONTROL VALVES

18.A WATER SUPPLY CONTROL

The Customer shall install a suitable square or a tee head stop on the private riser to the building (or, for multiple buildings, as close to the meter location as practicable) which will operate to control the entire water supply from the Service Connection.

18.B CURB STOP

Operation by the Customer of the curb stop in the meter box is not permitted except in extreme emergencies. Should the Customer damage the curb stop, they shall reimburse the City for any and all cost of repair or replacement.

19. CROSS-CONNECTIONS

19.A HEALTH REGULATIONS

Regulations of the California State Division of Drinking Water (DDW) Standards of the United States Public Health Service, including Title 17 and any successor regulation, prohibit unprotected Cross-Connections between the public water supply and any other source of water.

19.B CITY REQUIREMENTS

Backflow Prevention Devices shall be required at the Service Connection or at a location approved by the City for Premises receiving water from the City and falling in one or more of the following categories:

1. Premises having an Auxiliary Water supply;
2. Premises on which any substance is handled under pressure in such a fashion as to permit possible entry into the City's water distribution system, including water originating in the City's system that is then boosted in pressure;
3. Premises where the Customer's system has more than one Service Connection coming from different streets, or having internal Cross-Connections that cannot be permanently corrected to meet State and local Standards;
4. Premises and/or Customer's systems where, in the opinion of the City or its representative, there is the potential for pollution or contamination of the City Water System in the event of Backflow or back-siphonage.
5. Premises receiving Recycled Water;
6. Premises and or Customer's systems receiving Recycled Water where additives are introduced to the Onsite system. An approved Backflow device shall be added on to the Recycled Water Service Connection to protect the City's Recycled Water system.
7. Premises not receiving Water Service from the City are exempt from the requirements until they receive Water Service from the City.

19.C APPROVED BACKFLOW PREVENTION DEVICES

Only approved Backflow Prevention Devices will be accepted. An approved device is any device that has been manufactured and installed in full conformance with the Standards established by the Foundation for Cross-Connection Control and Hydraulic Research of the University of Southern California and that has received the approval of the City for use in Santa Clara.

19.D TYPES OF APPROVED BACKFLOW PREVENTION DEVICES REQUIRED

The type of assembly required to prevent Backflow into the City's Water System shall be one of the four types listed below. A single check valve assembly is not accepted as a Backflow Prevention Device by the City.

1. An Air-Gap Separation (AG).

19. CROSS-CONNECTIONS (Continued)

2. A Reduced Pressure Principle Backflow Prevention Assembly (RP). A device incorporating two or more check valves and an automatically operating differential relief valve located between the two checks, two shutoff valves, and equipped with necessary Appurtenances for testing. The device shall operate to maintain the pressure in the zone between the two check valves, less than the pressure on the public water supply side of the device.
3. Reduced Pressure Principle Detector Backflow Prevention Assembly (RPDA). A device that includes a bypass containing a City specific water meter and an approved RP. The City meter shall register accurately for only very low Flow Rates, up to three gallons per minute, and shall allow a registration for all rates of flow.
4. If permitted by the California Code of Regulations Title 17, a Double Check Detector Assembly (DCDA) may be accepted for the retrofit of an existing Service Connection in order to accommodate the hydraulic need of an existing onsite fire suppression system subject to the approval of the Director of Water and Sewer Utilities. The entire assembly shall meet the design and performance specifications and approval of a recognized and City approved testing agency for Backflow Prevention Devices. To be approved, these devices must be readily accessible for the in-line maintenance and testing and be installed per City Standards. The City reserves the right to require an RPDA on any service in order to protect the safety of the City's Water System.

19.E EXISTING SERVICES WITHOUT A DEVICE

Excluding detached single-family homes, Customers with no Backflow Prevention Device are required to install an approved Backflow Prevention Device (RP or RPDA) per California Code of Regulations Title 17 on all existing water connections (commercial, industrial, domestic, irrigation, fire, etc.) at the Customer's expense within 90 days of notification by the City. Customers seeking Entitlement or Permit approval shall be required to install an approved Backflow Prevention Device to any existing Service Connection to comply with this requirement as a condition of approval.

19.F EXISTING SERVICES WITH A NON-COMPLIANT DEVICE

Customers with single check detectors or other non-compliant devices are required to install an approved Backflow Prevention Device on existing water connections (commercial, industrial, domestic, irrigation, fire, etc.) at the Customer's expense within 90 days of notification by the City. Customers seeking Entitlement or Permit approval shall be required to upgrade their existing Service Connection to comply with this requirement as a condition of approval.

19.G PLUMBING CHANGES REQUIRED

In special circumstances, when the Customer is engaged in the handling of especially dangerous or corrosive liquids or industrial or process waters, the City may require the Customer to eliminate certain plumbing or piping connections as an additional precaution and protection to the Backflow Prevention Devices. In making the required plumbing connections, the Customer shall comply with local or State plumbing ordinances and codes.

19. CROSS-CONNECTIONS (Continued)

19.H RELIEF VALVE REQUIRED

Suitable pressure relief valves shall be installed and maintained by the Owner in accordance with the requirements of local or state plumbing codes and ordinances.

19.I BACKFLOW PROTECTION ON ADDITIONAL WATER SUPPLY LINES

Whenever Backflow protection has been found necessary on a water supply line entering a Customer's Premises, then any and all water supply lines from the City's Main entering such Premises, buildings or structures shall be protected by an approved Backflow device per State Cross-Connection requirements including Title 17 and any successor regulations unless the Director determines otherwise.

19.J INSPECTION OF BACKFLOW PREVENTION DEVICES

The City will be responsible for inspecting and testing all Backflow Prevention Devices, as well as making any necessary repairs identified through inspection and testing. Inspection and testing will be done on at least an annual basis. Fees for this service will be established from time to time.

19.K INSTALLATION OF BACKFLOW PREVENTION DEVICES

1. New Service Connections. At the time an application for a new service is made by a potential Customer, in accordance with City's policies and regulations, the City will review said application to determine the need for a Backflow Prevention Device on the Customer's service. If Backflow prevention is determined to be required, the Customer shall install a new Backflow Prevention Device or request that the City install a new Backflow Prevention Device and pay the City in advance in accordance with City's established installation fee schedule.
2. Existing Service Connections without Backflow Prevention Devices. The City will inspect, from time to time, the Premises of existing Service Connections that, in the opinion of the City or its representative, may require Backflow prevention. If it is determined that a Backflow Prevention Device is required, such determination by the City shall be final, and the installation of a Backflow Prevention Device shall be a condition of continued Water Service.
3. Upgrading the existing Backflow Prevention Device. An existing Backflow Prevention Device that, in the opinion of the City, does not provide adequate protection, shall be upgraded at the Customer's expense. Upgrading may include repair, complete replacement of the Backflow Prevention Device, or correction onsite of Cross-Connection hazards.

19.L INSTALLATION OF FACILITIES ON PRIVATE PROPERTY

1. Backflow Prevention Devices may be installed on private Premises by the City under agreement entered into by the Customer and the City.
2. All City services and Appurtenances located on private Premises shall require the offer and acceptance of an easement for use by the Water Utility prior to activation of service.

19. CROSS-CONNECTIONS (Continued)

19.M REMOVAL OR MODIFICATION OF BACKFLOW PREVENTION DEVICES

Backflow Prevention Devices shall not be removed or modified by the water user unless approved in advance by the City.

19.N DISCONTINUANCE OF SERVICE FOR DEFECTIVE APPARATUS

The service of water to any Premises may be immediately discontinued by the City if defects are found in any protective device installation, or if it is found that unprotected Cross-Connections exist. Service will not be restored until necessary corrections are made.

20. ONSITE RECYCLED WATER USE

Certain uses of Recycled Water are permitted by the State of California. The requirements for such use are defined by CCR, Title 22, Division 4, of the California Administrative Code and all successor regulations. The use of Recycled Water within the City is further defined under a Permit issued by the California Regional Water Quality Control Board. Wherever the City Rules and Regulations are inconsistent or in conflict with the requirements of Title 22 or of the RWQCB Permit, these Rules and Regulations shall be subordinate.

Since codes, laws, statutes and regulations can change without prior approval or knowledge of the City or South Bay Water Recycling (Program), the City, Program or Water Utility do not assume any liability for errors in this document. It is the responsibility of the Customer to check with the Program before initiating any operational or physical changes to the Recycled Water system.

20.A ABBREVIATIONS

Abbreviations used throughout Sections 20, 21 and 22 are listed below for reference. Definitions for terms are listed in Section 20.B (below).

AG: Air Gap

AWWA: American Water Works Association

County EHS: County of Santa Clara Environment Health Services

DC Assembly: Double Check Backflow Prevention Assembly

Program: South Bay Water Recycling Program, administered by City of San José for the San José - Santa Clara Regional Wastewater Facility

RP: Reduced Pressure Principle Backflow Prevention Assembly

State DDW: California State Water Resources Control Board – Division of Drinking Water

State RWQCB: California Regional Water Quality Control Board

20. RECYCLED WATER USE (Continued)

20.B DEFINITIONS

Whenever the following terms, or pronouns used in their place, occur in Sections 20, 21, or 22 herein, the intent and meaning shall be interpreted as follows:

Air Gap: A physical separation between the free-flowing discharge end of a water supply pipeline and an open or non-pressure receiving vessel. An approved Air Gap shall be at least twice the diameter of the water supply pipe measured vertically above the overflow rim of the vessel (in any case, no less than one inch (1")).

Applicant: Any entity that applies for Recycled Water Service under terms of the appropriate regulations. The approved Recycled Water Customer may be a different party than the Applicant, but must be specified in the Recycled Water Use Permit.

Application for Recycled Water Services: An agreement issued by the Water Utility to a Recycled Water Service Applicant after the satisfactory completion of the service application procedures. This Agreement forms a service agreement between the Recycled Water Customer and the Water Utility that legally binds the Recycled Water Customer to all conditions stated in the Agreement and all applicable Regulatory Agency requirements.

Approved Backflow Prevention Assembly: A device approved by the State of California which is installed to protect any water supply (recycled, potable, Public, private, or Onsite) from contamination through Backflow of a substance containing a potential hazard.

Approved Use: An application of Recycled Water in a manner, and for a purpose, designated in a Recycled Water Use Permit issued by the Program and in compliance with all applicable Regulatory Agency requirements.

Approved Use Area: A site with well-defined boundaries, designated on the approved Onsite Recycled Water Service Plans, to receive Recycled Water for an Approved Use and acknowledged by all applicable Regulatory Agencies.

Cross-Connection (chapters 20-22 only): A physical connection between any part of a water system used or intended to supply water for drinking purposes and any source or system containing water or substance that is not or cannot be approved as safe, wholesome and potable for human consumption. This includes direct piping between the two systems, regardless of the presence of valves, Backflow Prevention Devices, or other Appurtenances.

Certified Site Supervisor: The Recycled Water Customer shall designate a Certified Site Supervisor with the approval of the Program to provide a liaison with the Program, the City, and Water Utility. This person shall be available to the Program at all times, shall have the authority to carry out any requirements of the Water Utility, the City and the Program, and shall be responsible for the installation, operation and maintenance of the Recycled and Potable Water systems and also prevention of potential hazards.

Drip Irrigation System: any non-spray Low Volume Irrigation system utilizing emission devices with a Flow Rate measured in gallons per hour. Low Volume Irrigation systems are specifically designed to apply small volumes of water slowly at or near the root zone of plants.

Emitters: Drip irrigation fittings that deliver water slowly from the system to the soil.

Impoundment: A body of Recycled Water used for aesthetic enjoyment or which otherwise serves a function not intended to include routine Public contact.

20. RECYCLED WATER USE (Continued)

Inspector: Any person authorized by the Water Utility, the City, the Program or the local health agencies to perform inspections on or off the Recycled Water Customer's site before construction, during construction, after construction and during operation.

Intermittently Pressurized Line: Any irrigation piping downstream of the last valve.

Irrigation Period: The time, from start of water flow to cessation, which a specific area receives Recycled Water by direct irrigation application, no matter how often the specific area is irrigated, e.g., length of the duty cycle.

Irrigation Use: An Approved Use of Recycled Water for landscape irrigation as defined under the California Code of Regulations (CCR), Title 22, Division 4, Article 4.

Offsite: Designates or relates to Recycled Water facilities up to and including the water meter.

Onsite: Designates or relates to facilities owned and operated by a Recycled Water Customer.

Operations Personnel: Any employee of a Recycled Water Customer, whether permanent or temporary, or any contracted worker whose regular or assigned work involves the supervision, operation or maintenance of equipment on any portion of Onsite facilities using Recycled Water.

Operator: Any person, persons or firm, who, by entering into an agreement with a Recycled Water Customer, is responsible for operating Onsite facilities.

Owner (chapters 20-22 only): Any holder of legal title, contract purchaser, or lessee under a lease with an unexpired term of more than one (1) year for property for which Recycled Water Service has been requested or established.

Point of Connection: The point where the Recycled Water Customer's system ties to the Water Utility's system. This is usually at the water meter at the Service Connection.

Ponding: Retention of Recycled Water on the surface of the ground or other natural or manmade surface for a period following the cessation of an approved Recycled Water use activity.

Program (South Bay Water Recycling): South Bay Water Recycling (SBWR) is the regional permit holder for recycled water in San José, Santa Clara and Milpitas, ensuring compliance with State regulations for recycled water quality and use. SBWR is a recycled water wholesaler to four retailers: San José Water Company, San José Municipal Water, City of Santa Clara, and City of Milpitas. Customers buy recycled water from the retailer in their location.

Public: Any person or persons at large who may come in contact with facilities and/or areas where Recycled Water is approved for use.

Rate and Fee Schedule: The schedule of all rates, charges, fees and assessments to be made concerning the use of Recycled Water served by the Water Utility as approved or as amended by the City Council.

Recycled Water Customer: Any person, persons or firm including any Public utility, municipality or other Public body or institution issued a Recycled Water Use Permit by the Program. The Recycled Water Customer may be the Owner, tenant, or property manager as appropriate. The City's Rules and Regulations for the Use of Recycled Water apply to all Recycled Water Customers located within the City's boundaries.

Recycled Water Use Permit: A Permit issued by the Program to the Recycled Water Customer, which outlines monitoring, self-inspection, reporting, and site-specific requirements. This Permit is required by the California RWQCB for the use of Recycled Water.

Restrained Joint: Mechanically restrained pipe joint; also, solvent welded for PVC joints.

20. RECYCLED WATER USE (Continued)

Santa Clara County Environmental Health Services: The local health protection agency for most areas of Santa Clara County.

Standard Pipe Length: 18 to 20 feet.

State of California Division of Drinking Water: Shall be the State Division of Drinking Water Field Operations Branch - Santa Clara District 17.

Unauthorized Discharge: Any release of Recycled Water that violates the Rules and Regulations of the Water Utility, the City, the Program or any applicable Federal, State or local statutes, regulations, ordinances, contracts or other requirements.

Violation: Non-compliance with any condition or conditions of the User Agreement by any person, action or occurrence, whether willfully or by accident.

Windblown Spray: Dispersed, airborne particles of Recycled Water that can be transmitted through the air to locations other than those approved for the direct application of Recycled Water.

20.C SUMMARY OF ONSITE INSTALLATION REQUIREMENTS

1. Onsite installation requirements are described in detail in the Program's Rules and Regulations for Design and Operation of Onsite Recycled Water Facilities. However, the following is a summary of the basic requirements:
2. **No Cross-Connections.** No Cross-Connections are allowed between the Recycled Water system and the Potable Water system.
3. **Backflow Preventers.** In order to protect the public drinking water system from accidental Cross-Connections, a Reduced Pressure Principle Backflow Prevention Assembly is required at all **potable** meters on a site where Recycled Water is present.

In most cases, Backflow Prevention Devices are **not** required on the **Recycled Water** Service. However, where there is a particular threat to the quality of the Recycled Water, such as a direct connection to an industrial process or an Impoundment of water, the Program may require a Backflow Prevention Device on the Recycled Water Service.
4. **No Hose Bibs.** Generally, hose bibs are not allowed on the Recycled Water system. In most cases, hose bibs can be replaced by quick coupling valves.
5. **No Runoff.** The irrigation system must be configured and operated to prevent Runoff outside the Approved Use Area (the boundaries of the site).
6. **No Ponding.** The irrigation system must be configured and operated so that Ponding does not occur. This does not apply to approved and intended Impoundments.
7. **No Windblown Spray.** The irrigation system must be configured and operated to prevent Windblown Spray from passing outside the approved area.
8. **Pipe Identification.** All new Recycled Water piping below or above grade and all existing piping above grade must be labeled with purple tape with the imprinted words "CAUTION – RECYCLED WATER". Purple colored pipe with the required wording is an acceptable alternative.
9. New above grade Potable Water piping used for drinking water systems must also be labeled with blue tape and the words "**POTABLE WATER.**"

20. RECYCLED WATER USE (Continued)

10. **Horizontal Pipe Separation.** Where possible, a minimum horizontal separation of ten feet (10') between parallel buried Recycled and Potable Water pipelines should be maintained. If a ten-foot (10') horizontal separation cannot be maintained, then four-foot (4') minimum separation is allowed with Restrained Joint pipe and subject to the requirements of South Bay Water Recycling. In no case shall a horizontal separation of less than four feet (4') or same trench construction be allowed.
11. **Vertical Pipe Separation.** Recycled Water constant water pressure pipelines must be a minimum of one foot (1') below the Potable Water pipelines. Recycled Water constant pressure pipelines are allowed over potable pipelines with a minimum of one foot (1') vertical separation if a full Standard Pipe Length is centered over the crossing, or the recycled pipeline is sleeved for the same length. Intermittently Pressurized Recycled Water pipelines are allowed over potable pipelines with a minimum of one foot (1') vertical separation.
12. **Signs.** Signs must be posted in conspicuous areas Onsite which contain the words "RECYCLED WATER – DO NOT DRINK – NO TOMAR" indicating that Recycled Water is used for irrigation (or other) purposes. Generally, signs must be located at all entrances to the facility or use area.
13. **Warning Tags, Stickers and Labels.** All valve boxes (automatic and manual), quick couplers, Recycled Water storage tanks, air/vacuum relief valves, pressure reducing valves, pumps, Backflow Prevention Devices, system controller boxes, or other Appurtenances on the Recycled Water system must be labeled with warning tags, stickers or other labels. The labels, tags or stickers must include the words "RECYCLED WATER – DO NOT DRINK – NO TOMAR" on a purple background.
14. **Onsite (Land) Observation Reports.** At least once a year the site must be inspected for the items listed below while the system is in use. The observations must be submitted to the Program on a report form. The Recycled Water Customer may be required to perform this inspection, or, in some cases, the Program may perform the inspection. The items for the inspection are as follows:
 - (a) Is there evidence of Runoff of Recycled Water from the site? Show affected area on a sketch and estimate volume.
 - (b) Is there an odor of wastewater origin at the irrigation site? If yes, indicate apparent source, characterization, direction of travel, and any Public Use areas or Offsite facilities affected by the odors.
 - (c) Is there evidence of Ponding of Recycled Water, and/or evidence of mosquitoes breeding within the irrigation due to ponded water?
 - (d) Are warning signs, tags, stickers, and above ground pipe markings properly posted to inform the Public that irrigation water is Recycled Water, which is not suitable for drinking?
 - (e) Is there evidence of leaks or breaks in the irrigation system piping or tubing?
 - (f) Is there evidence of broken or otherwise faulty Drip Irrigation System Emitters or spray irrigation Sprinkler Heads or Spray Heads?
 - (g) What corrective actions are being taken to correct any problems noted above?

20. RECYCLED WATER USE (Continued)

15. The Recycled Water Customer may also be required to conduct a visual inspection of the system during the off-season. Specific requirements will be included in the Recycled Water Use Permit.
16. **Emergency Cross-Connection Response Plan.** If a Cross-Connection or Backflow incident occurs between the Potable and Non-Potable Water systems, an emergency response plan must be implemented.

20.D FEES AND PERMIT

1. **Recycled Water Use Permit.** The State RWQCB requires that a Recycled Water Use Permit be issued by the Program to all Recycled Water Customers within the Program area. The Recycled Water Use Permit indicates any special site-specific requirements in addition to the requirements specified in this document. The Application for a Recycled Water Use Permit is submitted to the City or the Program with the Onsite Recycled Water Service Plans. The Program processes the application and issues a Recycled Water Use Permit with final approval for the use of Recycled Water at the site. The Applicant is responsible to obtain all necessary Permits and pay all associated fees. The Applicant should contact the City for information on the cost of Permits.
2. **Application for Recycled Water Services.** The Water Utility also requires an Application for Recycled Water Service, similar to application for Potable Water Service.

20.E THE CITY AS THE LOCAL AUTHORITY

1. The City is the entity that has the responsibility of enforcing these Rules and Regulations for the end use of Recycled Water. The City has authority to issue plumbing Permits, building requirements, and planning criteria.
2. The Rules and Regulations enforced by the City are derived from those established by the State RWQCB, the State DDW, County EHS, the Program and the City. These Rules and Regulations govern certain permitted uses of Recycled Water. All facilities using Recycled Water shall be designed and operated to meet the Standards of the local governing codes, rules and regulations.

20.F AUTHORIZED USES FOR RECYCLED WATER

The uses of Recycled Water may include, but not by way of limitation: landscape irrigation; agricultural irrigation; construction water; industrial process water; water for flushing toilets and urinals in non-residential buildings; replacement water in cooling towers; and recreational Impoundments. Each such use shall be explored by the Recycled Water Customer for applicability to the Development and considered for approval by the City on a case-by-case basis. The City may determine, in its discretion, whether it is necessary or desirable to furnish Recycled Water for the specific use involved. Determinations as to specific uses to be allowed shall be in accordance with the Standards of treatment and water quality requirements set forth in CCR, Title 22, Division 4, of the California Administrative Code. Prior to approving such uses, the City may, in its discretion, set forth specific requirements as conditions to providing such services and/or require specific prior approval from the appropriate Regulatory Agencies. Data centers authorized to use Recycled Water for process water shall design and construct a redundant backup Potable Water system in the event of a service interruption to maintain system operation.

20. RECYCLED WATER USE (Continued)

20.G NON-APPROVED USE AREAS

1. **Runoff Conditions.** The irrigation systems shall be designed, constructed and operated to prevent Runoff outside the Approved Use Area.
2. **Ponding Conditions.** The irrigation systems shall be designed, constructed and operated to minimize Ponding outside or within the Approved Use Area. This does not apply to approved Impoundments such as decorative Water Features, golf course water-hazards or lakes. At no time shall Recycled Water be applied at a rate greater than the soil Infiltration Rate.
3. **Windblown Spray Conditions.** The irrigation systems shall be designed, constructed and operated to minimize Windblown Spray from passing outside the Approved Use Area.
4. **Unapproved Uses.** Use of Recycled Water for any purposes other than those explicitly approved by the Water Utility in conformance with the Rules and Regulations of the Program, the State DDW, the County EHS, or the State RWQCB, or use of Recycled Water in areas other than those specifically shown on the approved plans, is strictly prohibited.
5. **Disposal in Unapproved Areas.** Disposal of Recycled Water for any purpose, including Approved Uses, in areas other than those explicitly approved in the current effective Recycled Water Use Permit issued by the Program and without the prior knowledge and approval of the appropriate Regulatory Agencies, is strictly prohibited.

20.H AMENDMENTS

From time to time there may be amendments to the existing Rules and Regulations and design manual. These amendments may be made without the consent of the Recycled Water Customer. These amendments will be enforced upon their effective date.

20.I PROTECTION OF PUBLIC HEALTH

The Water Utility, the City and the Program reserve the right to take any action necessary with respect to the operation of the Recycled Water Customer's system to safeguard the Public health.

20.J RIGHT TO TERMINATE SERVICE

1. If at any time during construction or operation of the Recycled Water system, real or potential hazards are evidenced, such as Cross-Connections with the potable system, improper tagging, signing, or marking, or unapproved/prohibited uses, the Water Utility reserves the right and has the authority to terminate immediately, without notice, Recycled Water Service in the interest of protecting the Public health. The Water Utility may elect to temporarily replace the Recycled Water supply water with Potable Water only after the Recycled Water Customer's system has been disinfected and approval has been granted by the Program and the State DDW. All modifications required to replace the Recycled Water supply with Potable Water shall be at the Recycled Water Customer's expense.
2. The Recycled Water Customer has the right to terminate service if there are no longer suitable uses at that site. The Recycled Water Customer cannot substitute Potable Water where Recycled Water can be used.

20. RECYCLED WATER USE (Continued)

20.K SEVERABILITY

If any section, subsection, clause, or phrase of these Rules and Regulations is for any reason held to be invalid or unconstitutional, such decision shall not affect the remaining portions of these Rules and Regulations. The City Council declares that it would have passed said Rules and Regulations by section, subsection, sentence, clause, or phrase thereof.

21. DESIGN, INSTALLATION AND INSPECTION OF SYSTEMS FOR USE OF RECYCLED WATER

21.A DESIGN APPROVAL

Before the construction of any new Recycled Water system, major modifications of an existing Recycled Water system, or retrofit of an existing system for Recycled Water use, Onsite Recycled Water Service Plans must be prepared by the Recycled Water Customer and approved by the Program and the State DDW. Approval shall be contingent upon evidence that all applicable design requirements, rules and regulations for a Recycled Water system are satisfied (see *Basis for Design Review Criteria* below).

21.B REQUIRED ONSITE RECYCLED WATER SERVICE PLANS

Plans must be stamped by a registered Landscape Architect or civil engineer and include, but not be limited to, the following:

1. Site plan drawn to scale which clearly shows the boundaries of the intended use area, adjacent streets, and locations of all major improvements on the site, water meters (Recycled Water and Potable Water), Backflow Prevention Devices, drinking fountains, and all Public facilities supplied with Recycled or Potable Water Service. Public facilities include, but are not limited to, restrooms, outdoor eating areas, snack bars, Swimming Pools, wading pools, decorative fountains and showers. If there are no Public facilities located in the defined use area, then a note on the plans must indicate that no Public facilities exist. Additionally, any wells, lakes, ponds, reservoirs, or other water Impoundments located Onsite or within 100 feet (100') of the site must be shown on the site plan.
2. Piping plan which shows the complete Potable and Recycled Water systems. All sources of Recycled Water and Potable Water must be indicated on the plan. The location and type of all existing and new Backflow Prevention Devices and water meters must be clearly marked on the piping plan. For existing facilities converting to Recycled Water use, the piping plan must indicate which piping and other devices are existing and which piping and other devices will be installed as part of the retrofit work. The proper separation requirements between Potable and Recycled Water lines (for new piping) must be indicated. The piping plan can be combined with the site plan if space permits.
3. Detail drawings of areas where special installation or retrofit procedures are required, such as cutting and capping to separate potable and recycled systems, installation of Backflow Prevention Devices, special construction where pipe separation criteria cannot be met, etc.
4. Any other items required by the Design, Installation, and Inspection Criteria section of the Recycled Water Customer Onsite Manual, and Section 23.Q of this document.
5. Preparation of Onsite Recycled Water Service Plans does not exempt the Applicant from submitting other Onsite improvement plans normally required by the City. Other improvement plans required by the City must still be submitted in accordance with the City's Standard procedures.

21. DESIGN, INSTALLATION AND INSPECTION OF SYSTEMS FOR USE OF RECYCLED WATER (Continued)

21.C BASIS FOR DESIGN REVIEW CRITERIA

1. Review of Onsite Recycled Water Service Plans conducted by the Program and the State DDW will consist of checking for conformance with various regulations and guidelines governing distribution of Recycled Water. Even though the City/Program and the State DDW perform a plan check, the Applicant is not relieved of responsibility to meet all requirements. A brief description of this criteria is provided below. Copies of these criteria will be provided by the City or the Program upon request.
2. **CCR, Title 22, Division 4, Chapter 3, "Water Recycling Criteria"**. These regulations are written by the State DDW and specify the Approved Uses and use area requirements, such as hose bib restrictions, prohibition of irrigation near wells, etc. These regulations govern both the Water Utility's distribution system as well as the Recycled Water Customer's Onsite system.
3. **CCR, Title 17, "Drinking Water Supply - Backflow Prevention"** CCR, Title 17 specifies requirements intended to protect the Public drinking water supply from contamination. Some requirements specified in CCR, Title 17 include Backflow Prevention Devices, designation of a Certified Site Supervisor, and Cross-Connection testing requirements.
4. **AWWA, California-Nevada Section, Guidelines for Distribution of Non-Potable Water**. This document provides recommended guidelines for planning, designing, constructing, and operating Non-Potable Water systems, including Recycled Water systems. The guidelines themselves are not regulations but many agencies have adopted them as general requirements. The document covers both installation of the Water Utility distribution systems and Onsite use systems.
5. **International Association of Plumbing and Mechanical Officials (IAPMO) Uniform Plumbing Code**. The Uniform Plumbing Code sets forth requirements when Recycled Water is used within buildings in a Dual Plumbed system for Non-Potable domestic uses such as toilet and urinal flushing. The Uniform Plumbing Code does not apply to irrigation sites, where the Recycled Water system is located outside buildings, or industrial sites, where the Recycled Water is used for non-domestic industrial purposes. In addition, the pipe separation regulations indicated in this Guide are different than and take precedence over the IAPMO.

21.D SUMMARY OF DESIGN REVIEW CRITERIA

Although the plan review conducted by the Program, the State DDW and/or the City may include checking for compliance with any of the existing regulations or guidelines referenced above, the following summaries are provided to give the designer of the Recycled Water system a general idea of the major items which will be checked during plan review. The summary is compiled as a "punch list" so that it can easily be referenced by the plan designer. However, compliance with every item on the punch list does not guarantee that the plans will be approved without comment since regulations and policies may change and some sites may require special provisions. In addition, even though the Program, the State DDW and/or the Local Authorities perform a plan review, the Applicant is still responsible for meeting all applicable requirements, even if those requirements are not shown on the approved plans. Please note that the plan requirements are slightly different for new facilities and existing facilities converting to Recycled Water use.

21. DESIGN, INSTALLATION AND INSPECTION OF SYSTEMS FOR USE OF RECYCLED WATER (Continued)

1. Do plans include a site/piping plan and details of connection points as indicated under *Required Plans* (Section 21.B)?
2. Are all items listed under *Required Plans* (Section 21.B) shown on the site/piping and details plans?
3. Is the use area shown on the site an Approved Use Area?
4. Is the total Recycled Water irrigation area included to the nearest 10th (0.1) of an acre?
5. At **new facilities**, are all Onsite Recycled Water pipelines located ten feet (10') horizontally from Potable Water pipelines where possible (minimum of four-foot (4') horizontal separation allowed if special construction details are incorporated)?
6. At **new facilities**, where Recycled and Potable Water lines cross, are the pressurized Recycled Water pipelines located at least one foot (1') below the Potable Water lines?
7. At **existing facilities** converting to Recycled Water use, does all new piping meet the Potable/Recycled Water pipeline separation criteria indicated above?
8. Do the plans indicate that Recycled Water and Potable Water systems are completely separated and there is no common trenching?
9. At **existing facilities** converting to Recycled Water use, are all locations where future Recycled Water piping must be separated from the Potable Water piping clearly indicated on the plans?
10. Are the proper Backflow Prevention Devices shown in the proper location for protection of the Public Potable Water system? RPs should be shown located as close as possible to all Potable Water meters and at least one foot (1') above grade.
11. If the Onsite Recycled Water system is interconnected with industrial process piping, fertilizer injection systems, or a Non-Potable drinking water source (such as an irrigation water storage pond), is the proper Backflow Prevention Device shown in the proper location for protection of the Public Recycled Water distribution system? In such cases, usually an RP device is required at the Recycled Water meter, at least one foot (1') above grade.
12. Are the proper Backflow Prevention Devices shown in the proper locations for protection of Onsite Potable Water supply per standard UPC and CCR, Title 17 requirements? Though not specifically related to Recycled Water, these devices should be shown on the plans. Backflow Prevention Devices are required at non-Air-Gap Points of Connection to ponds, wading pools, Swimming Pools, fountains, etc., where the Impoundment is supplied by the Potable Water Onsite piping. Usually atmospheric vacuum breakers located near the Point of Connection are adequate, unless there is a valving downstream of the protection device, in which case pressure vacuum breakers are required.
13. If there are wells located Onsite or near the use site, are the wells separated from all Recycled Water Irrigation Use areas by at least 50 feet (50') and from all Recycled Water Impoundments by at least 100 feet (100')?
14. If plans are used for construction, do plans show all necessary details to properly construct the system?
15. Do plans identify that materials are appropriate for Recycled Water use? (For example, purple pipe, proper signing and tagging, etc.)

21. DESIGN, INSTALLATION AND INSPECTION OF SYSTEMS FOR USE OF RECYCLED WATER (Continued)

- 16. Do plans identify work requiring inspection by the Program representatives?
- 17. Do plans include a detail for Air Gap if a backup source is used?
- 18. Do plans specify no hose bibs on the Recycled Water system?

21.E PRELIMINARY CROSS-CONNECTION TEST EXISTING SITES

At all existing sites which are converting to Recycled Water use, a preliminary Cross-Connection test may be required and shall be coordinated by the Recycled Water Customer prior to retrofit work or construction. The Recycled Water Customer must notify the Program prior to the Cross-Connection test so that the Program, the Water Utility, the City, and Regulatory Agency representatives can be present if they wish. The preliminary Cross-Connection test should follow the general Cross-Connection testing guidelines outlined in Section 21.I. The purpose of the test is to determine if there are any unknown connections between the existing irrigation system and the domestic water system prior to construction. If unknown connections are discovered, then further testing or potholing must be conducted in order to determine where the connections are located. The retrofit plans must be revised to reflect any changes required to eliminate the connections, and the revised plans must be resubmitted to the Program and the State DDW for review. At new Development sites, a preliminary Cross-Connection test is generally not necessary since the systems have been designed for Recycled Water use.

21.F CONSTRUCTION INSPECTION

The State RWQCB requires that the Program, the City, or designated representatives conduct Onsite inspections during the construction phase to ensure that materials, installation and procedures are in accordance with the approved plans, specifications, and all applicable regulations. Accordingly, the Recycled Water Customer shall notify the Program of the schedule for all phases of planning, construction and start up so that inspections can be scheduled.

21.G FIELD TESTING AND INSPECTION

All systems shall conform to the requirements of the UPC Sections 103.5.1 through 103.5.4.2 except intermittent pressure piping. During the coverage test with Recycled Water, the irrigation system shall be inspected for proper use of full, half, and quarter Spray Heads, proper atomizing, and irrigation spray on non-Approved Use Areas.

21.H TEMPORARY CONNECTION TO POTABLE SERVICE

A jumper to the potable system is allowed up to and during the final Cross-Connection test. At that time the jumper shall be replaced by the Recycled Water meter. Jumpers providing water from the Public Recycled Water system into the Onsite Recycled Water system are prohibited at all times.

21. DESIGN, INSTALLATION AND INSPECTION OF SYSTEMS FOR USE OF RECYCLED WATER (Continued)

21.1 FINAL CROSS-CONNECTION TEST

The Recycled Water Customer must conduct a final Cross-Connection test before connecting the Recycled Water Customer's system to the Water Utility's Recycled Water system at any use-site where both Recycled and Potable Water are present in separate piping systems. This test is to ensure the absolute separation of the Recycled and Potable Water systems. The Recycled Water Customer must notify the Program at least 48 hours prior to the test so that members of the appropriate agencies may be present. The Cross-Connection test shall be done under the supervision of the Program representatives by an AWWA-certified Cross-Connection control specialist hired by the Applicant. The Certified Site Supervisor (see *Designation of Certified Site Supervisor*, herein) must be present at the test. Periodic testing must be performed after that (see *Periodic Cross-Connection Testing Program*, herein). A written report documenting the test results shall be submitted by the certified Cross-Connection control specialist to the Certified Site Supervisor and the Program following completion. The following are general test guidelines and may be modified with the approval of the Program.

1. **General Cross-Connection Test Procedures:** Cross-Connection tests shall be performed as specified in the UPC Appendix J 8 (2) and J 8 (3), with the exception that intermittent piping will not be activated and pressurized as specified in Appendix J 8 (2)(vi), and that the required pressurization time will be one (1) hour or as otherwise specified by the Cross-Connection specialist. The City of Santa Clara's Cross-Connection test procedures are summarized as follows:
2. **Minimum Requirements for Cross-Connection Testing:** The Cross-Connection test shall be done with the Certified Site Supervisor present, under the supervision of a City representative by an AWWA-certified Cross-Connection control specialist. The Cross-Connection test shall include the following steps:
 - (a) For Premises with irrigation systems originally constructed with a potable service, all Potable Water supply points to the irrigation system are to be disconnected and capped. These points shall remain open to view until after a visual inspection by the City. This step may be deferred until after the following steps are completed, that is, the Cross-Connection test may be completed with Potable Water being supplied to the recycled piping.
 - (b) When the recycled service is ready to be activated, while still OFF: City Inspectors shall determine that there is no water being supplied to the irrigation system. This may be by use of a pressure gauge installed on the normally pressurized portion of the irrigation system, or by a visual inspection of the irrigation Spray Heads. This procedure is to ensure no Potable Water source is supplying water to the irrigation system.
 - (c) After the Recycled Water Service is activated and turned ON, the potable service to the property is to be turned OFF and de-pressurized. A pressure gauge will be connected to the potable service at the building to measure the potable system pressure during this test. While the potable system is not in use, there shall be no observed increase in pressure for at least 15 minutes. For multi-story buildings, maximum pressure at the ground floor is not to exceed static pressure equal to elevation pressure to the top floor or roof of the building (the highest point of the internal plumbing).

21. DESIGN, INSTALLATION AND INSPECTION OF SYSTEMS FOR USE OF RECYCLED WATER (Continued)

21.J FINAL INSPECTION

The State DDW requires a final Onsite inspection to be conducted by the Program or its designated representatives. Accordingly, a final inspection will be performed by the Program or its designated representatives before the Recycled Water system is connected to ensure all requirements have been met. This inspection will be coordinated with the final Cross-Connection test so that the inspection can be done with Potable Water charging the irrigation system at Recycled Water pressure prior to connection of Recycled Water. The Program's Inspector will check to see that the proper equipment was used and that all required tags, labels, and signs are in place. This inspection shall precede the coverage test which will be performed with Recycled Water. This will allow the Inspector to determine if conditions which create Runoff or Windblown Spray outside the Approved Use Area, Ponding within the use area do not exist. Spray patterns will be checked to see they do not encroach upon Public facilities such as drinking fountains, outside eating areas, or areas outside the Approved Use Area.

21.K FINAL APPROVAL

Final approval must be granted by the Program before Recycled Water can be supplied to the site. Final approval will be granted when construction has been completed in accordance with approved plans and specifications, all Cross-Connection tests have been performed, a final Onsite inspection has been conducted, and all requirements have been met satisfactorily. After the Recycled Water Use Permit has been finalized by the Program, the Water Service Agreement is approved by the Water Utility, and all applicable fees have been paid, the Water Utility will authorize the installation of the Recycled Water meter. (The coverage test will be performed after the meter has been set) the Program will be forwarded a copy of all test and inspection reports as well as notification that Recycled Water Service has been started. During the lifetime of the Recycled Water system, the City or the Program will periodically inspect the Recycled Water system to ensure compliance with all applicable rules and regulations (see *Annual Self-Inspections*, herein). Additionally, the Recycled Water Customer shall conduct a Cross-Connection test every four years if required by the Recycled Water Use Permit.

21.L RECORD DRAWINGS

All conceptual or major design changes shall be approved before implementing the change in the construction contract. Record Drawings shall be prepared to show the recycled system as constructed and shall include all changes in work constituting departures from the original contract drawings including those involving both constant pressure and Intermittent-Pressure Lines and Appurtenances.

22. OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER

22.A CONDITIONS OF SERVICE

All requirements outlined in this section shall be Conditions of Service, unless modified in the Recycled Water Use Permit. By accepting Recycled Water Service, the Recycled Water Customer agrees to comply with all Conditions of Service.

22.B SYSTEM RESPONSIBILITY

1. It shall be the responsibility of the Recycled Water Customer to maintain and operate their Recycled Water system downstream of the Service Connection. It is the responsibility of the Recycled Water Customer to ensure that the Recycled Water is being applied in accordance with all rules and regulations regarding the use of Recycled Water. The Recycled Water Customer is also responsible for the following:
 - (a) Maintaining the Onsite Recycled Water system, signs, markings, and tags in accordance with all rules and regulations.
 - (b) Ensuring all materials used during the repair and maintenance of the system are approved or recommended for Recycled Water use.
 - (c) Obtaining all Permits and payment of all fees required for the operation and maintenance of the Recycled Water Customer's system. Permitting and/or fee assistance may be available from the City or the Program.
 - (d) Reporting all Violations and emergencies to the required local governing agencies.
 - (e) Obtaining prior authorization from the Water Utility and the Program before making any modifications to the approved Recycled Water system. This includes converting any piping used at any time for conveyance of Recycled Water back to Potable Water, that is switching a Recycled Water system to a backup Potable Water system. The Program will notify the Recycled Water Customer if approval is also required from any additional Regulatory Agencies and if disinfection procedures are required.

22.C HOURS OF OPERATION

Hours of operation shall be specified in the Recycled Water Use Permit.

22. OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER
(Continued)

22.D DESIGNATION OF CERTIFIED SITE SUPERVISOR

It is the responsibility of the Recycled Water Customer to provide surveillance and supervision of the Recycled Water system in a way that assures compliance at all times with current regulations. In order to accomplish this, the Recycled Water Customer shall designate, with the approval of the Program, a Certified Site Supervisor to provide liaison with the City, the Water Utility and the Program. This person may represent the Owner, tenant, or property manager as appropriate; however they must be a permanent employee responsible for the Recycled Water system at the site who is available at all times and has the authority to carry out any requirements of the Program, the City, and the Water Utility. The Certified Site Supervisor should be permanently stationed at the use site, or at a minimum, make frequent visits to the use site as specified in the Recycled Water Use Permit. Installation, operation, maintenance, and prevention of potential hazards on the Recycled and Potable Water systems are the responsibility of the Certified Site Supervisor. The Certified Site Supervisor's primary responsibility is to ensure that there are no Cross-Connections made between the Potable and Recycled Water systems. The Certified Site Supervisor must be present at the final Cross-Connection test and periodic Cross-Connection tests. The Certified Site Supervisor shall inform the Program of all failures, Violations, and emergencies that occur involving the Recycled or Potable Water systems. The Certified Site Supervisor is also responsible to be knowledgeable of the provisions contained in CCR, Title 17 and CCR, Title 22 relating to the safe use of Recycled Water and the maintenance of accurate records. The Certified Site Supervisor must be familiar with the basic concepts of Backflow and Cross-Connection prevention, system testing and relating emergency procedures. The Recycled Water Customer must notify the Program immediately of any change in personnel for the Certified Site Supervisor position.

22.G MAINTENANCE

1. To ensure the Recycled Water system remains in compliance, the Recycled Water Customer shall begin a preventative maintenance program including, but not limited to, the following:
 - (a) Regular inspections shall be conducted by the Recycled Water Customer of the entire Recycled Water system including Spray Heads, Drip Irrigation Emitters, spray patterns, lakes, piping and valves, pumps, storage facilities, controllers, etc. Immediately correct any leaks, breaks, or discrepancies in Permit requirements.
 - (b) All warning signs, tags, stickers, and above grade pipe markings shall be checked for their proper placement and legibility. Replace damaged, unreadable or missing signs, tags, stickers, and pipe markings.
 - (c) Special attention should be given to spray patterns to eliminate Ponding, Runoff and Windblown Spray conditions. If Runoff is noted, affected areas should be indicated on a sketch and the volume should be estimated. If unauthorized Ponding is detected, evidence of mosquitoes breeding within the Ponding should be noted and immediately eliminated.
 - (d) Establish and maintain an accurate record keeping system of all inspections, modifications and repair work.

22. OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER
(Continued)

- (e) Broken Spray Heads, faulty spray patterns, leaking pipes or valves, or any other noted condition which violates the use requirements shall be repaired immediately after the malfunction or condition becomes apparent.

22.E PERSONNEL TRAINING

It is the responsibility of the Recycled Water Customer to train all Operations Personnel, in order to be familiar with the use of Recycled Water. Any training program should include, but not limited to, the following:

1. Operations Personnel must be aware of the emergency procedure.
2. Operations Personnel must be aware that Recycled Water, though highly treated, is Non-Potable Water.
3. Operations Personnel must understand the requirements and restrictions pertaining to Ponding, Windblown Spray and Runoff.
4. Good personal hygiene must be followed.
5. Recycled Water shall never be used for human consumption.
6. Operations Personnel must understand that working with Recycled Water is safe if good common sense is used and appropriate regulations are followed.
7. Operations Personnel must understand that there is **never** to be a connection between the Recycled Water system and the Potable Water system.
8. Operations Personnel must understand the health/safety aspects of CCR, Title 17 and CCR, Title 22 requirements.
9. All new employees shall be trained in the proper use of Recycled Water. Supervisory personnel and the Certified Site Supervisor should be held accountable to ensure that employees are not using Recycled Water carelessly or hazardedly.

22.F VEHICLE IDENTIFICATION

1. Any vehicle used to transport Recycled Water shall be clearly marked with labels or signs. These labels or signs shall contain the words "RECYCLED WATER – DO NOT DRINK – NO TOMAR" in black two-inch (2") high minimum letters on a purple background. The Program may also require the label to include translations into foreign language(s) if appropriate, as specified in the Recycled Water Use Permit. One label or sign shall be placed on the tank closest to the driver's door. One label or sign shall be placed on the rear surface of the tank. All labels and signs shall be placed where they can easily be seen by the personnel using the vehicle.
2. The "Do Not Drink" symbol (refer to the Recycled Water Customer Onsite Design Manual) shall be present on all vehicles used to carry Recycled Water. Any vehicles used for the transportation or storage of Recycled Water must not be reused for the transportation or storage of Potable Water.

22. OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER
(Continued)

22.H ANNUAL SELF-INSPECTIONS AND REPORTS

1. **Standard Onsite (Land) Observation Report.** The State RWQCB requires that the Recycled Water Customers in the Program conduct a standard observation inspection at least once a year at a time when the Recycled Water system is in use. In general, the standard observations correlate with the preventative maintenance self-inspections. The Recycled Water Customer must submit the results of the observations along with a description of any corrective actions taken in a written report to the Program (see *22.P Forms*). The schedule and deadlines for submittal of this report is indicated in the Recycled Water Use Permit. The seven items for inspection are as follows:
 - (a) Is there evidence of Runoff from the site? Show affected area on a sketch and estimate volume.
 - (b) Is there an odor of wastewater origin at the irrigation site? If yes, indicate apparent source, characterization, direction of travel, and any Public Use areas or Offsite facilities affected by the odors.
 - (c) Is there evidence of Ponding Recycled Water, and/or evidence of mosquitoes breeding within the irrigation area due to Pondered water?
 - (d) Are warning signs, tags, stickers, and above ground pipe markings properly posted to inform the Public that irrigation water is Recycled Water, which is not suitable for drinking?
 - (e) Is there evidence of leaks or breaks in the irrigation system piping or tubing?
 - (f) Is there evidence of broken or otherwise faulty Drip Irrigation System Emitters or Overhead Spray Irrigation?
 - (g) What corrective actions are being taken to correct any problems noted above?
2. **Off-Season Inspection Report.** The State RWQCB also requires that the Program Recycled Water Customers conduct a thorough inspection of all irrigation lines, Overhead Spray Irrigation, and Drip System Emitters at least once a year during the dormant season. The findings of this inspection, along with any significant repairs or modifications must be submitted in a report to the Program (see *22.P Forms*). The schedule and deadlines for submittal of this report are indicated in the Recycled Water Use Permit.

22.I PERIODIC PROGRAM INSPECTIONS

1. The State RWQCB also requires that the Program conduct periodic inspections of Recycled Water Customer use sites. These inspections shall include, at a minimum, the visual inspection of all Backflow Prevention Devices, pump rooms, exposed piping, valves, pressure reducing stations, Points of Connection, Overhead Spray Irrigation, Drip System Emitters, controllers, lakes, storage facilities, signs, labeling, tags, etc. The Certified Site Supervisor's maintenance records shall be inspected to review all maintenance since the last inspection. The Program, the Local Authority, and RWQCB reserve the right to make unannounced inspections of the facility during reasonable hours of operation.
2. Upon completion of the inspection, a report form will be signed and dated by both the Certified Site Supervisor and the Program Inspector. The original shall be maintained by the Program with copies to the Certified Site Supervisor, the City, the Water Utility and any required Regulatory Agency.

22. OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER
(Continued)

3. Should a Cross-Connection be discovered during any inspection by the Recycled Water Customer or an outside Inspector, the **Emergency Cross-Connection Response Plan** shall be immediately invoked by the Certified Site Supervisor.

22.J MODIFICATIONS

1. No modifications shall be made by the Recycled Water Customer to any Recycled Water system without the prior approval of the Program. This includes modifications to the approved plans, or to an operational system. Detailed plans of any modifications must be submitted to the Program and the modifications inspected by the Program before being completed.
2. Emergency modifications or repairs can be made by the Recycled Water Customer to the system without the prior approval of the Program to prevent contamination, damage or a Public health hazard. As soon as possible after the modification, but not to exceed three (3) days, the Recycled Water Customer must notify the Program of the emergency modifications and file a written report.

22.K PERIODIC CROSS-CONNECTION TESTING

At Dual Plumbed use sites (sites where the Recycled Water is used within a building in conjunction with a Potable Water system), the Recycled Water Customer shall be responsible for conducting a periodic Cross-Connection test as required in the Recycled Water Use Permit unless visual inspections reveal a requirement for more frequent testing. Generally, the periodic Cross-Connection test for a Dual Plumbed use site is required once every four (4) years. This test shall be done by an AWWA-certified Cross-Connection specialist. The Program must be notified at least 48 hours in advance of the test so that a Program representative can be present. The Certified Site Supervisor must be present at the test. A sample Test Notification Form is located in *22.P Forms*. The following are general guidelines for periodic cross-testing and may be modified with the approval of the Program

22.L SYSTEM NOT IN COMPLIANCE

If at any time the Recycled Water system is found to be out of compliance, the Program shall issue an Order specifying the corrections required to bring the system into compliance. A site inspection shall be scheduled after a reasonable period of time to ensure compliance with the Order. If it is known or suspected that a Backflow incident or contamination has occurred, then the *Emergency Cross-Connection Response Plan* shall be invoked.

22.M NOTIFICATION

It is the responsibility of the Certified Site Supervisor to notify the Program of any failure or Cross-Connection in said Recycled Water or Potable Water system, whether or not they believe a Violation has occurred. It is also the responsibility of the Certified Site Supervisor to notify the Program of any Violation that might occur because of any action the Recycled Water Customer personnel might take during the operation of said Recycled Water or Potable Water systems. If there are any doubts whether a Violation has occurred, it is the responsibility of the Certified Site Supervisor to report each occurrence to the Program so a decision can be made.

22. OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER
(Continued)

22.N EMERGENCY PROCEDURE

1. In case of a major earthquake, flood, fire, tornado, structural failure, or other incident which could likely damage the Recycled or Potable Water systems, the Certified Site Supervisor should inspect the domestic and Recycled Water systems for damage, as soon as it is safe to do so. If either system appears damaged, the domestic or Recycled Water system with damage should be shut off at their Points of Connection. If the Certified Site Supervisor cannot inspect the site and damage is expected, then both water systems should be shut off at their Points of Connection. The Supervisor should immediately contact the Program for further instruction.
2. **Emergency Modifications.** Emergency modifications or repairs may be made by the Recycled Water Customer to said system without the prior approval of the Program to prevent contamination, damage or a Public health hazard. As soon as possible after the modification, but not more than three (3) days after the modification, the Recycled Water Customer shall notify the Program of the emergency modifications and file a written description of action taken.
3. **Unauthorized Discharge.** It is the responsibility of the Recycled Water Customer to report to the City all system failures that result in an Unauthorized Discharge of Recycled Water. An immediate oral report is required at which time the City will specify if a written report is required. The Recycled Water Customer must make every effort to contain the Unauthorized Discharge prior to discharge to the storm drains. Contact the Program for field review and disposal instructions.
4. **Contamination of Drinking Water.** In case of contamination of the Potable Water system due to a Cross-Connection on the Recycled Water Customer's Premises, the Program and State DDW shall be immediately notified by the Recycled Water Customer. The Recycled Water Customer is to immediately invoke the *Emergency Cross-Connection Response Plan*.

22.O EMERGENCY CROSS-CONNECTION RESPONSE PLAN

In the event that a Backflow incident or Cross-Connection is suspected or occurs, the following procedures shall be implemented immediately.

1. Notify the Water Utility and the State DDW by phone. This notification is to be followed by written notice within 24 hours. The written notice is to include an explanation of the nature of the Cross-Connection, date and time discovered, and the steps taken to mitigate the Cross-Connection(s).
2. Keep the Potable Water system pressurized and post "Do Not Drink" signs at all Potable Water fixtures and outlets.
3. Immediately shut down the Recycled Water supply to the facility at the meter.
4. Provide bottled water for employees until the Potable Water system is deemed safe to drink.
5. Collect water samples from the Potable Water system and perform a 24-hour bacteriological analysis. Water samples should be collected from the closest acceptable point to the Cross-Connection. The Water Utility may supply the appropriate sample bottles, obtain the samples, and arrange for laboratory analysis. See the *Water Utility Supplementary Guidelines* for additional information.

22. OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER
(Continued)

6. Identify the cause and location of Backflow and eliminate the Cross-Connection(s).
7. Conduct a Cross-Connection test as outlined in Section 21.E-K to verify that all Cross-Connections were eliminated.
8. Obtain approval from the Program and the State DDW before bringing the Recycled Water system back into service.
9. If the bacteriological analysis conducted in Step 5 is positive, chlorinate the Potable Water system maintaining a chlorine residual of at least 50 mg/l for 24 hours. Otherwise proceed to Step 11.
10. Flush the Potable Water system after 24 hours and perform Standard bacteriological analysis.
11. If the results from Step 10 are acceptable, proceed to Step 12. Otherwise, repeat Steps 9-10.
12. Obtain final approval from the Program and the State DDW before removing signs.

22. OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER
(Continued)

22.P FORMS



Recycled Water Use Permit Application

3025 Tuers Road San Jose, CA 95121 408-277-3671 www.sanjoeca.gov/sbwr

SERVICE ID

PROJECT INFORMATION	ALL FIELDS REQUIRED		RETAILER:		
	4 DIGIT SITE ID:				PROJECT ID
	METER BOX ID (single letter):				
	MODIFICATION ## (original is "0"):				
	☐ IRRIGATION		☐ INDUSTRIAL	☐ AGRICULTURAL	
	PROJECT NAME				
	USE AREA SQUARE FOOTAGE				
	PROJECT DESCRIPTION				
CERTIFIED SITE SUPERVISOR	STREET ADDRESS		CITY	ZIP CODE	
	OWNER NAME		EMAIL		
	PHONE				
	NAME				
	CERTIFICATION #				
	COMPANY / ENTITY				
	PHONE				
	EMAIL				
RETAILER INFO	Each site must have a designated Certified Site Supervisor present at all Cross-Connection tests to obtain a Use Permit. Visit the South Bay Water Recycling website www.sanjoeca.gov/sbwr to view the schedule of upcoming Site Supervisor training classes.				
	☐ PROPOSED USE REQUEST		☐ RECYCLED WATER USE PERMIT REQUEST		
	ESTIMATED ANNUAL USE OF RECYCLED WATER (IN GALLONS)				
	RETAILER REPRESENTATIVE		DATE		
	☐ NEW DEVELOPMENT	☐ RETROFIT / MODIFICATION	☐ ENHANCEMENT OWNERS	☐ PODIUM	
	☐ DUAL PLUMBING	☐ COOLING TOWER	☐ HOME OWNERS ASSOCIATION		
	☐ THE SERVICE ID LISTED ABOVE HAS BEEN VERIFIED TO BE IN COMPLIANCE WITH ITS PERMIT (existing sites only)				
	WILL SBWR CROSS CONNECTION TEST PROCESS BE USED? YES ☐ NO ☐				
SBWR	(IF NO, PLEASE SUBMIT YOUR CROSS CONNECTION TEST PROCEDURE TO THE RETAILER FOR APPROVAL BEFORE TESTING)				
	CROSS-CONNECTION DATE				
	SBWR REPRESENTATIVE				
	PERMIT ISSUE DATE				

SUBMIT TO: SBWRPERMIT@SANJOSECA.GOV

REVISION 3.1.19

LOCAL CONTACTS	
Site:	
Location:	
Certified Site Supervisor:	
Title:	
Email:	
Work Phone:	Mobile Phone:

22. OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER
(Continued)

Recycled Water Cross Connection Test

3025 Tuers Road San Jose, CA 95121 408-277-3671 www.sanjoseca.gov/sbwr

XXX	####	X
-----	------	---

SERVICE ID

PROPERTY SITE INFORMATION	METER BOX LOCATION side of _____ of _____	
	SITE NAME _____	STREET _____ FEET _____ STREET _____
	ADDRESS _____	CITY _____ ZIP _____ METER ADDRESS (IF APPLICABLE) _____
	DESCRIPTION _____	
REQUIRED ATTENDEES	SBWR REPRESENTATIVE _____ COMPANY/ENTITY _____ PHONE _____	
	RETAILER REPRESENTATIVE _____ COMPANY/ENTITY _____ PHONE _____	
	CERTIFIED SITE SUPERVISOR (CSS) _____ COMPANY/ENTITY _____ CERT # _____ PHONE _____	
CROSS CONNECTION SPECIALIST	_____, AWWA CROSS CONNECTION SPECIALIST #: _____, _____ CROSS CONNECTION SPECIALIST NAME CERTIFICATION #	
	After carefully reviewing this recycled water system, and performing a Cross-Connection test in accordance with SBWR's Rules and Regulations, I find no indication of a cross-connection with this recycled water system, at the property site listed above.	
	THE CROSS-CONNECTION TEST WAS CONDUCTED ON _____ DATE (s) _____ TIME _____	
	CROSS CONNECTION SPECIALIST NAME _____ DATE _____	
	COMPANY _____ PHONE _____	
	ADDRESS _____ CITY _____ ZIP CODE _____	
TEST DETAILS	DESCRIBE THE TESTING PROCEDURE USED, THE DOCUMENTS SUPPLIED BY THE RETAILER AND CSS, THE RECYCLED WATER SYSTEMS TESTED, AND WHICH PROJECTS WERE INCLUDED. ☐ VISUAL TEST ONLY	
RETAILER	RETAILER APPROVAL _____ DATE _____	

SUBMIT TO: SBWRPERMIT@SANJOSECA.GOV

REVISION: 3.1.19

22. OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER
(Continued)



Recycled Water Inspection Checklist: Construction

XXX	####	X	P	MOD#
-----	------	---	---	------

3025 Tuers Road San Jose, CA 95121 408-277-3671 www.sanJoseca.gov/sbwr

PROJECT ID

USE CLASS	☐ IRRIGATION ☐ INDUSTRIAL ☐ AGRICULTURAL		
SITE LOCATION & SITE SUPERVISOR	SITE NAME		
	SITE ADDRESS		ZIP
	CITY		
	CERTIFIED SITE SUPERVISOR (CSS)		CERTIFICATION #
	CSS PHONE		CSS EMAIL
INSPECTION TASKS		DATE (VERIFIED/COMPLETED)	INITIALS
	1) DDW APPROVED PLANS / ENGINEERING REPORT SIGNATURE		
	2) HORIZONTAL AND VERTICAL SEPARATION MATCH THE DDW APPROVED PLANS		
	3) ADVISORY SIGNS, TAGS AND LABELING MATCH THE DDW APPROVED PLANS		
	4) CROSS CONNECTION TEST PASSED		
	5) RETAILER NOTIFIED OF ANY ON SITE POTABLE WATER METERS		
	6) REMOVAL OF ALL TEMPORARY AND / OR PERMANENT POTABLE WATER CONNECTIONS TO RECYCLED WATER SYSTEMS		
	7) METER (S) INSTALLED Serial Number (s) METER 1 # METER 2 #		
	8) ON SITE SYSTEM CONNECTED TO RECYCLED WATER METER SEPARATION HAS BEEN MAINTAINED BETWEEN THE RECYCLED AND POTABLE WATER SYSTEMS		
	9) IF A RECYCLED WATER COOLING TOWER IS PRESENT, FILL OUT THE INSPECTION CHECKLIST FOR COOLING TOWERS		
10) DOES THE RECYCLED WATER SYSTEM BUILT EXACTLY MATCH THE DDW APPROVED PLANS? ☐ YES ☐ NO IF NOT, SHOW THE DIFFERENCES ON THE RECORD DRAWINGS AND EXPLAIN THEM BELOW			
COMMENTS:			
INSPECTOR NAME			
DATE			
RETAILER / SBWR AGENT REPRESENTATIVE			
DATE			

SUBMIT TO: SBWRPERMIT@SANJOSECA.GOV

REVISION: 3.1.19

22. OPERATION AND MAINTENANCE OF SYSTEMS FOR USE OF RECYCLED WATER
(Continued)



Recycled Water Inspection Checklist: Cooling Tower

XXX	####	X	P	MOD#
-----	------	---	---	------

PROJECT ID

3025 Tuers Road San Jose, CA 95121 408-277-3671 www.sanjoeca.gov/sbwr

USE CLASS	INDUSTRIAL			
SITE LOCATION & SITE SUPERVISOR	SITE NAME			
	SITE ADDRESS			
	CITY		ZIP	
	CERTIFIED SITE SUPERVISOR (CSS)		CERTIFICATION #	
	CSS PHONE		CSS EMAIL	
INSPECTION TASKS	1)	DDW APPROVED PLANS / ENGINEERING REPORT SIGNATURE	DATE (VERIFIED/COMPLETED)	INITIALS
	2)	BIOCIDE USED PER ENGINEERING REPORT		
	3)	DRIFT ELIMINATOR IS INSTALLED PER PLAN		
	4)	POTABLE WATER SUPPLY (IF PRESENT) HAS AN AIR GAP PER PLAN		
	5)	RECYCLED WATER SUPPLY HAS AN AIR GAP PER PLAN		
	6)	COOLING TOWER MODEL NUMBER MATCHES THE ENGINEERING REPORT		
	7)	PROVIDE COOLING TOWER MANUFACTURER'S NAMEPLATE INFO (SERIAL NUMBER, MANUFACTURING DATE, ETC):		
	COMMENTS:			
	INSPECTOR NAME			DATE
	RETAILER / SBWR AGENT REPRESENTATIVE			DATE

SUBMIT TO: SBWRPERMIT@SANJOECA.GOV

REVISION: 3.1.19

23. WATER EFFICIENT LANDSCAPE ORDINANCE

23.A PURPOSE

Upon the effective date of the revision of the State of California's Model Water Efficient Landscape Ordinance (MWELO), it will supersede the regulations in this Chapter 23, Water Efficient Landscape Ordinance.

Upon the City's adoption of a separate Santa Clara Water Efficient Landscape Ordinance, this Chapter 23, Water Efficient Landscape Ordinance, is rendered null and void.

1. The purpose of these Rules and Regulations is to promote efficient water use in landscaping by promoting use of region-appropriate plants that require minimal supplemental irrigation, and by establishing Standards for Irrigation Efficiency.
2. These Rules and Regulations establish a structure for planning, designing, installing, maintaining and managing water efficient landscapes in New Construction and rehabilitated projects by encouraging the use of a watershed approach that requires cross-sector collaboration of industry, government and property Owners to achieve the many benefits possible.
3. These Rules and Regulations establish provisions for water management practices and water waste prevention for existing landscapes.
4. Efficient water use without waste shall be achieved by setting a Maximum Applied Water Allowance as an upper limit for water use and reducing water use to the lowest practical amount. Irrigation efficiencies are accomplished through proper landscape design, installation and management techniques appropriate to Santa Clara's growing conditions.
5. Landscapes planned, installed, managed and maintained in accordance with these Rules and Regulations will improve conditions in urban Santa Clara by:
 - (a) Enhancing soil tilth;
 - (b) Minimizing energy use;
 - (c) Conserving water wherever possible
 - (d) Protecting air quality
 - (e) Protecting existing habitat and creating new habitat through the use of Native Plants and climate appropriate plants wherever possible.
6. These Rules and Regulations implement the California Water Conservation in Landscaping Act, Government Code Section 65591 et. seq.

23.B APPLICABILITY

1. These Rules and Regulations shall apply to the following Landscape Projects:
 - (a) New construction projects with an aggregate Landscape Area equal to or greater than 500 square feet requiring a Permit, plan check, or design review
 - (b) Rehabilitated Landscape Projects with an aggregate Landscape Area equal to or greater than 2,500 square feet requiring a Permit, plan check, or design review.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (c) Existing landscapes limited to Sections 493, 493.1, 493.2 in Division 2, Title 23 of the California Code of Regulations; and in sections 23.V and 23.W of these Rules and Regulations.
 - (d) Cemeteries. Recognizing the special landscape needs of cemeteries, new and rehabilitated cemeteries, are limited to sections 23.V and 23.W of these Rules and Regulations.
- 2. Any project with an aggregate Landscape Area of 2,500 square feet or less may comply with the performance requirements of this ordinance or conform to the prescriptive measures contained in Appendix D.
- 3. For projects using treated or untreated Graywater or rainwater captured on site, any lot or parcel within the project that has less than 2,500 square feet of landscape and meets the lot or parcel's landscape water requirement (ETWU) entirely with treated or untreated Graywater or through stored rainwater captured on site is subject only to Appendix D Section (5).
- 4. These Rules and Regulations shall not apply to:
 - (a) Registered local, state or federal historical sites;
 - (b) Any Ecological Restoration Project that does not require a permanent irrigation system;
 - (c) Mine Reclamation Projects that do not require a permanent irrigation system;
 - (d) Community gardens or plant collections, as part of botanical gardens and arboretums open to the public;

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

23.C DEFINITIONS

Terms used in this Section of these Rules and Regulations have the meaning set forth below:

Applied Water: The portion of water supplied by the irrigation system to the landscape.

Automatic (Irrigation) Controller: An automatic mechanical or solid-state timing device, capable of remotely controlling Irrigation Valve Stations that operate an irrigation system. Automatic Irrigation Controllers schedule irrigation events using Evapotranspiration or Soil Moisture data to set days and length of time of irrigation.

Certificate of Completion: The document required under 23.L

Certified Irrigation Designer: A person certified to design irrigation systems by an accredited academic institution, a professional trade organization, or other program such as the U.S. Environmental Protection Agency's WaterSense irrigation designer certification program, or the Irrigation Association's Certified Irrigation Designer program.

Certified Landscape Irrigation Auditor: A person certified to perform landscape Irrigation Audits by an accredited academic institution, a professional trade organization or other program such as the US Environmental Protection Agency's WasterSense Irrigation Auditor Certification Program and Irrigation Association's Certified Landscape Irrigation Auditor Program.

Check Valve or Anti-Drain Valve: A valve located under a Spray Head, or other location in the irrigation system, to hold water in the system to prevent drainage from Spray Heads when the system is off.

Common Interest Developments: Community apartment projects, condominium projects, planned Developments, and stock cooperatives per Civil Code Section 1351.

Compost: The safe and stable product of controlled biologic decomposition of organic materials that is beneficial to plant growth.

Conversion Factor (0.62): The number that converts the Maximum Applied Water Allowance from acre-inches per acre per year to gallons per square foot per year.

Distribution Uniformity: The measure of the uniformity of irrigation water over a defined area.

Ecological Restoration Project: A project where the site is intentionally altered to establish a defined, indigenous, historic ecosystem.

Effective Precipitation (EPPT): The portion of total precipitation that is available for plants. Precipitation is not a reliable source of water but can contribute to some degree toward the water needs of the landscape.

Established Landscape: The point at which plants in the landscape have developed roots into the soil adjacent to the root ball.

Establishment Period: The first year after installing the plant in the landscape or the first two years if irrigation will be terminated after establishment. Native habitat mitigation areas and trees may need three to five years for establishment.

Estimated Total Water Use (ETWU): The annual total amount of water used for the landscape as described in Section 23.G.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

Evapotranspiration Adjustment Factor (ETAF): The factor of 0.55 for residential areas and 0.45 for non-residential areas, that, when applied to Reference Evapotranspiration (ET_o), adjusts for Plant Factors and Irrigation Efficiency, two major influences upon the amount of water that needs to be applied to the landscape. The ETAF for new and existing (non-rehabilitated) Special Landscape Areas shall not exceed 1.0. The ETAF for existing non-Rehabilitated Landscapes is 0.8.

Evapotranspiration Rate (ET): A quantity of water evaporated from adjacent soil and other surfaces and transpired by plants during a specific time.

Flow Sensor: An inline device installed at the supply point of the irrigation system that produces a repeatable signal proportional to Flow Rate. Flow Sensors must be connected to an Automatic Irrigation Controller, or flow monitor capable of receiving flow signals and operating Master Valves. This combination Flow Sensor/controller may also function as a Landscape Water Meter or Submeter.

Friable: A soil condition that is easily crumbled or loosely compacted down to a minimum depth per planting material requirements, whereby the root structure of newly planted material will be allowed to spread unimpeded.

Fuel Modification Plan Guideline: Guidelines from a local fire authority to assist residents and businesses that are developing land or building structures in a fire hazard severity zone.

Hardscape: Any constructed feature in a landscape built of any Pervious or Impervious durable material.

High Water Use Plant: Any species classified as “high” water use by WUCOLS, having a regionally adjusted Plant Factor of 0.7 through 1.0, shall be categorically deemed a High Water Use Plant. The surface area of Water Features is included in the high water use Hydrozone of the Landscape Area.

Hydrozone: A portion of the landscaped area having plants with similar water needs that are served by an Irrigation Valve or set of Irrigation Valves with the same schedule. A Hydrozone may be irrigated or non-irrigated. For example, a naturalized area planted with native vegetation that will not need supplemental irrigation once established is a non-irrigated Hydrozone.

Impervious: Any surface or material that does not allow the passage of water through the material and into the underlying soil.

Invasive Plants: Species of plants not historically found in California that spread outside cultivated areas and can damage environmental or economic resources. Invasive Species may be regulated by agricultural agencies as noxious species. Lists of Invasive Plants are maintained at the California Invasive Plant Inventory and USDA invasive and Noxious Weeds database.

Irrigation Audit: An in-depth evaluation of the performance of an irrigation system conducted by a Certified Landscape Irrigation Auditor. An Irrigation Audit includes, but is not limited to: inspection, system tune-up, system test with Distribution Uniformity or emission uniformity, reporting Overspray or Runoff that causes overland flow, and preparation of an irrigation schedule. The audit must be conducted in a manner consistent with the Irrigation Association’s Landscape Irrigation Auditor Certification program or other U.S. Environmental Protection Agency “WaterSense” labeled auditing program

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

Irrigation Efficiency (IE): The measurement of the amount of water beneficially used divided by the amount of water applied. Irrigation Efficiency is derived from measurements and estimates of irrigation system characteristics and management practices. The IE for purposes of this ordinance are 0.75 for Overhead Spray Devices and 0.81 for Drip Systems.

Irrigation Survey: An evaluation of an irrigation system that is less detailed than an Irrigation Audit. An Irrigation Survey includes, but is not limited to: inspection, system test, and written recommendations to improve irrigation system performance.

Irrigation Valve: A device used to control the flow of water in the irrigation system.

Irrigation Water Use Analysis: An analysis of water use data based on meter readings and billing data.

Landscape Architect: A person who holds a license to practice landscape architecture in California as defined by the California Business and Professions Code, Section 5615.

Landscape Area: All of the planting areas, Turf areas and Water Features in a landscape subject to the Maximum Applied Water Allowance calculation. The Landscape Area does not include footprints of buildings or structures, decks, driveways, sidewalks, gravel or stone walks, parking lots, other Pervious or Impervious Hardscapes and other non-irrigated areas designated for non-Development (e.g., open spaces and existing wildland vegetation).

Landscape Contractor: A person licensed by the State of California to construct, maintain, repair, install, or subcontract the Development of landscape systems.

Landscape Documentation Package: The documents required under Section 23.F.

Landscape Water Meter: an inline device installed at the irrigation supply point that measures the flow of water into the irrigation system and is connected to a totalizer to record water use.

Lateral Line: The water delivery pipeline that supplies water to the Emitters or Spray Heads from the Irrigation Valve.

Low Volume Irrigation: The application of irrigation water through a system of tubing or Lateral Lines and Low-Volume Emitters such as drip and bubblers. Low Volume Irrigation systems are specifically designed to apply small volumes of water slowly at or near the root zones of plants.

Low Water Use Plant: Any species classified as “low water use” by WUCOLS, having a regionally adjusted Plant Factor of 0.1 through 0.3, shall be categorically deemed a Low Water Use plant.

Master Valve: An automatic Valve installed at the irrigation supply point which controls water flow into the irrigation system. When this valve is closed, water will not be supplied to the irrigation system. A Master Valve will greatly reduce any water loss due to a leaky Station valve.

Maximum Applied Water Allowance (MAWA): The upper limit of annual Applied Water for the Established Landscaped Area as specified in Section 23.G., Water Efficient Landscape Worksheet. It is based upon the area’s reference ET, the ETAF, and the size of the landscaped area. The ETWU shall not exceed the MAWA. Special Landscape Areas, including recreation areas, areas permanently and solely dedicated to edible plants such as orchards and vegetable gardens, and areas irrigated with Recycled Water are subject to the MAWA with an ETAF not to exceed 1.0. $MAWA = (ET_o) (0.62) [(ETAF \times LA) + ((1-ETAF) \times SLA)]$.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

Mine Reclamation Projects: Any surface mining operation with a reclamation plan approved in accordance with the Surface Mining and Reclamation Act of 1975.

Moderate Water Use Plant: Any species classified as “moderate” water use by WUCOLS, having a regionally adjusted Plant Factor of 0.4 through 0.6, shall be categorically deemed a Moderate Water Use Plant.

Mulch: Any organic material such as leaves, bark, chipped wood, straw, or inorganic materials such as rocks, pebbles, gravel or decomposed granite left loose and applied to the soil surface to reduce evaporation, suppress weeds, moderate soil temperature and prevent soil erosion.

Native Plant: A plant indigenous to a specific area of consideration. For the purposes of these Rules and Regulations division, the term will refer to plants indigenous to the costal ranges of Central and Northern California, and more specifically to such plants that are suited to the ecology of the present or historic natural community of the project’s vicinity.

New Construction: For the purposes of this ordinance, a new building with a landscape or other new landscape, such as a park, playground, or greenbelt without an associated building.

Noxious Weeds: Any weed designated by the Weed Control Regulations in the Weed Control Act and identified on a Regional District noxious weed control list. Lists of Noxious Weeds are maintained at the California Invasive Plant Inventory and USDA invasive and Noxious Weeds database.

Operating Pressure: The pressure at which a system of Sprinkler Heads is designed to operate, usually indicated at base of each Sprinkler Head.

Overspray: Irrigation water which is delivered beyond the target area.

Parkway: The area between a sidewalk and the curb or traffic lane. It may be planted or unplanted and with or without pedestrian egress.

Pervious: Any surface or material that allows the passage of water through the material and into the underlying soil.

Plant Factor: A factor that, when multiplied by reference ETo, estimates the amount of water needed by plants. Plant Factors in these Rules and Regulations are derived from the publication “Water Use Classification of Landscape Species” (WUCOLS). Plant Factors may also be obtained from horticultural researchers from academic institutions or professional associations as approved by the California Department of Water Resources.

Project Applicant: The individual or entity submitting a Landscape Documentation Package required under Section 23.F to request a Permit, plan check, or design review from the local agency. A Project Applicant may be the property Owner or their designee.

Rain Sensor: A device which automatically shuts off the irrigation system when it rains.

Recreational Areas: Areas excluding private, single family residential areas, designated for active play, recreation, or public assembly in parks, sports fields, school yards, picnic grounds, amphitheaters or golf course tees, fairways, roughs surrounds and greens.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

Reference Evapotranspiration (ET_o): A standard measurement of environmental parameters, which affect the water use of plants. ET_o is given in inches per day, month, or year as represented Appendix A and is an estimate of the ET_o of a large field of four to seven inch (4-7") tall, cool-season grass that is well watered. Reference ET_o is the MAWA so that regional differences in climate can be accommodated.

Regional Water Efficient Landscape Ordinance: A local Ordinance adopted by two or more local agencies, water suppliers and other stakeholders for implementing a consistent set of landscape provisions throughout a geographical region. Regional ordinances are strongly encouraged to provide a consistent framework for the landscape industry and Project Applicants to adhere to.

Rehabilitated Landscape: Any re-landscaping project that requires a Permit, plan check or design review, meets the requirements of Section 23.B. and the modified Landscape Area is equal to or greater than 2,500 square feet..

Residential Landscape: Landscapes surrounding single family homes or multifamily homes where landscapes are managed by individual homeowners.

Soil Moisture Sensor: A device that measures the amount of water in the soil. The device may also initiate or suspend irrigation.

Soil Texture: The classification of soil based on the percentage of sand, silt, and clay in the soil.

Special Landscape Area (SLA): An area of the landscape dedicated solely to edible plants, Recreational Areas, areas irrigated with Recycled Water and, Water Features using Recycled Water.

Static Water Pressure: The pipeline or municipal water supply pressure when water is not flowing.

Station: An area served by one Irrigation Valve or by a set of Irrigation Valves that operate simultaneously.

Stormwater: Rainfall Runoff, snow melt Runoff, surface Runoff, drainage from natural sources; excludes infiltration.

Very Low Water Use Plant: Any species classified as "very low" water use by WUCOLS having a regionally adjusted Plant Factor of <0.1 shall be categorically deemed a Very Low Water Use Plant.

WUCOLS: The Water Use Classification of Landscape Species published by the University of California Cooperative Extension and the Department of Water Resources, 2014 available at:

<https://ccuh.ucdavis.edu/wucols>

23.D COMPLIANCE WITH LANDSCAPE DOCUMENTATION PACKAGE

1. All Landscape Projects identified in Santa Clara City Code Section 18.88, Landscaping Permit, shall include a completed Landscape Documentation Package. Permit Fee is required when submitting a Permit. Prior to construction, the Community Development Planning Department shall:
 - (a) provide the Project Applicant with the Landscape Project Package requirements and procedures for Permits, plan checks of design reviews;

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (b) review the Landscape Documentation Package submitted by the Project Applicant;
 - (c) approve or deny the Landscape Documentation Package ;
 - (d) issue a Permit or approve the plan check or design review that complies with the approved Landscape Documentation Package and;
 - (e) upon approval of the Landscape Documentation Package, submit a copy of the Water Efficient Landscape Worksheet to Water and Sewer Utilities.
- 2. Prior to construction, the Project Applicant shall:
 - (a) submit all portions of the Landscape Documentation Package to the Community Development Department;
 - (b) pay the Landscape Project review fee as required by the schedule of fees established by resolution of the City Council.
- 3. Upon approval of the Landscape Documentation Package by the Community Development Department, the Project Applicant shall:
 - (a) receive a Permit of approval of the plan check or design review and record the date of the Permit in the Certificate of Completion.
 - (b) submit a copy of the approved Landscape Documentation Package along with the Record Drawings, and any other information to the property Owner or their designee; and
 - (c) submit a copy of the Water Efficient Landscape Worksheet to Water & Sewer Utilities.

23.E PENALTIES

Non-compliance with any applicable provision of the Water Service and Use Rules and Regulations shall constitute a violation of the City Code and shall be subject to enforcement action and/or Permit revocation.

23.F COMPONENTS OF THE LANDSCAPE DOCUMENTATION PACKAGE

- 1. The Landscape Documentation Package shall contain the following six (6) items.
 - (a) Project information:
 - (i) date
 - (ii) Project Applicant
 - (iii) project address (if available, parcel and/or lot number(s))
 - (iv) total Landscape Area (square feet)
 - (v) project type (e.g., new, rehabilitated, public, private, cemetery, homeowner-installed) water supply type (e.g., potable, recycled, well) and the City as the Local Retail Water Purveyor if the Project Applicant is not served by a private well
 - (vi) checklist of all documents in Landscape Documentation Package (Appendix E)

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (vii) project contacts including contact information for the Project Applicant and property Owner
- (viii) Project Applicant signature and date with statement, "I agree to comply with the requirements of the water efficient landscape ordinance and submit a complete Landscape Documentation Package."
- (b) Water Efficient Landscape Worksheet
 - (i) Hydrozone information table
 - (ii) water budget calculations
 - (1) Maximum Applied Water Allowance (MAWA)
 - (2) Estimated Total Water Use (ETWU)
- (c) Soil Management Report (Section 23.H);
- (d) Landscape Design Plan (Section 23.I);
- (e) Irrigation Design Plan (Section 23.J); and
- (f) Grading Design Plan

23.G WATER EFFICIENT LANDSCAPE WORKSHEET

1. A Project Applicant shall complete the Water Efficient Landscape Worksheet in Appendix B which contains information on the Plant Factor, irrigation method, IE, and area associated with each Hydrozone. Calculations are then made to show that the ETAF for the Landscape Project does not exceed a factor of 0.55 for residential areas and 0.45 for non-residential areas, exclusive of Special Landscape Areas. The ETAF for a Landscape Project is based on the Plant Factors and irrigation methods selected. The MAWA is calculated based on the maximum ETAF allowed (0.55 for residential areas and 0.45 for non-residential areas) and expressed as annual gallons required. The ETWU is calculated based on the plants used and irrigation method selected for the landscape design. ETWU must be below the MAWA.
 - (a) In calculating the MAWA and ETWU, a Project Applicant shall use the ETo values from the Reference ETo Table in Appendix A.
2. Water budget calculations shall adhere to the following requirements:
 - (a) The Plant Factor shall be from WUCOLS or from horticultural researchers with academic institutions or professional associations as approved by the California Department of Water Resources (DWR).
 - (b) All Water Features shall be included in the high water use Hydrozone and temporarily irrigated areas shall be included in the low water use Hydrozone.
 - (c) All Special Landscape Areas shall be identified and their water use calculated as shown in Appendix B.
 - (d) ETAF for new and existing (non-rehabilitated) Special Landscape Areas shall not exceed 1.0.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

23.H SOIL MANGEMENT REPORT

1. In order to reduce Runoff and encourage healthy plant growth, a soil management report shall be completed by the Project Applicant, or their designee, as follows:
 - (a) Soil samples shall be submitted to a laboratory for analysis and recommendations.
 - (i) Sampling shall be conducted in accordance with laboratory protocol, including protocols regarding adequate sampling depth for the intended plants.
 - (ii) A soil analysis report shall include:
 - (1) Soil Texture
 - (2) Infiltration Rate determined by laboratory test or Soil Texture Infiltration Rate table
 - (3) pH
 - (4) total soluble salts
 - (5) sodium
 - (6) percent organic matter
 - (7) recommendations.
 - (iii) In projects with multiple landscape installations (i.e. production home Developments) a soil sampling rate of 1 in 7 lots or approximately 15% will satisfy this requirement. Large Landscape Projects shall sample at a rate equivalent to 1 in 7 lots.
2. The Project Applicant or their designee shall comply with one of the following:
 - (a) If significant mass grading is not planned, the soil analysis report shall be submitted to the local agency as part of the Landscape Documentation Package; or
 - (b) If significant mass grading is planned, the soil analysis report shall be submitted to the Community Development Building Department as part of the Certificate of Completion.
3. The soil analysis report shall be made available, in a timely manner, to the professionals preparing the landscape design plans and irrigation design plans to make any necessary adjustments to the design plans.
4. The Project Applicant, or their designee, shall submit documentation verifying implementation of soil analysis report recommendations to the Community Development Building Department with the Certificate of Completion.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

23.I LANDSCAPE DESIGN PLAN

1. A Landscape Project shall be designed to achieve water efficiency consistent with the intent of these Rules and Regulations. A landscape design plan meeting the following design criteria shall be submitted as part of the Landscape Documentation Package.
 - (a) Plant Material:
 - (i) 100% of the plants in non-Turf Landscape Areas shall be very low, low or moderate water using plants, or Native Plants, unless the Project Applicant develops a water budget and the ETWU of the landscaped area does not exceed the MAWA. Methods to achieve water efficiency shall include one or more of the following:
 - (1) protection and preservation of native species and natural vegetation;
 - (2) selection of water-conserving plant, tree and Turf species, especially local Native Plants;
 - (3) selection of plants based on local climate suitability, disease, and pest resistance;
 - (4) selection of trees based on applicable local tree ordinances or tree shading guidelines; size at maturity as appropriate for the planting area;
 - (5) selection of plants from local and regional landscape program lists;
 - (6) and selection of plants from local Fuel Modification Plan Guidelines.
 - (ii) Plants with similar water needs shall be grouped within Hydrozones with the exception of Hydrozones with plants of mixed water use, as specified in Section 23.J.1(b)(iv).
 - (iii) Plants shall be chosen and arranged appropriately based upon the site's climate, soil characteristics, sun exposure, wildfire susceptibility and topographical conditions. Methods to achieve water efficiency shall include one or more of the following:
 - (1) use the Sunset Western Climate Zone System which takes into account temperature, humidity, elevation, terrain, latitude, and varying degrees of continental and marine influence on local climate;
 - (2) recognize the horticultural attributes of plants to minimize damage to property or infrastructure, allow for adequate soil volume for healthy root growth; and
 - (3) consider the solar orientation for plant placement to maximize summer shade and winter solar gain.
 - (iv) Turf shall not:

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (1) be planted in Non-Residential Landscapes unless it is Functional Turf. Non-Functional Turf (Decorative Grass) is prohibited in non-residential and multifamily Landscape Projects.
 - (2) be planted on slopes greater than 25% where the toe of the slope is adjacent to an impermeable Hardscape and where 25% means one foot (1') of vertical elevation change for every four feet (4') of horizontal length (rise divided by run x 100 = slope percent)
 - (3) have any portions less than eight feet wide.
 - (4) exceed 25% of the Landscape Area, or 1,250 square feet, whichever is lesser in area.
 - (v) High Water Use Plants are prohibited.
 - (vi) Fire-prone plant materials and highly flammable Mulches are strongly discouraged. In designated wildland urban interface areas, plants shall be selected, arranged and maintained to provide defensible space for wildfire protection per Public Resources Code Section 4291 (a) and (b).
 - (vii) Installation of Invasive Plants such as those listed by the California Invasive Plant Council is prohibited.
 - (1) Existing Invasive Plants and Noxious Weeds within or adjacent to the proposed Landscape Area shall be removed prior to installation, to minimize potential for spread into installation area.
 - (viii) The architectural guidelines, conditions, covenants or restrictions of a Common Interest Development shall not supersede this division. For example, a Common Interest Development may not prohibit Low Water Use Plants, or include conditions that have the effect of restricting the use of Low Water Use Plants.
- (b) Water Features:
- (i) Recirculating water systems shall be used for Water Features.
 - (ii) Where available, Recycled Water shall be used for decorative Water Features.
 - (iii) The surface area of any Water Feature shall be included in the high water use Hydrozone area of the water budget calculation
 - (iv) Swimming Pool and spa covers are required on any newly constructed Swimming Pool or spa.
- (c) Soil Preparation, Mulch and Amendments:
- (i) Prior to planting of any materials, compacted soils shall be transformed to a Friable condition. On engineered slopes, only amended planting holes need meet this requirement.
 - (ii) Soil amendments shall be appropriately added according to the soil conditions at the project site and based on what is appropriate for the selected plants per Section 23.H.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (iii) For landscape installations, Compost at a rate of at least four cubic yards per 1,000 square feet of permeable area shall be incorporated to a depth of six inches (6") into the soil. Soils with greater than 6% organic matter in the top six inches (6") of soil are exempt from adding Compost and tilling.
 - (iv) A minimum three-inch (3") layer of Mulch shall be applied on all exposed soil surfaces of planting areas, except in areas of Turf, creeping or rooting groundcovers or direct seeding application (e.g. hydro-seed). To provide habitat to beneficial insects and wildlife, up to 5% of the Landscape Area may be left without Mulch. Designated insect habitat must be included in the landscape design plan as such.
 - (v) Stabilizing Mulching products shall be used on slopes that meet current engineering Standards.
 - (vi) The Mulching portion of the seed/Mulch slurry in hydro-seeded applications shall meet the Mulching requirement.
 - (vii) Organic Mulch materials made from recycled or post-consumer shall take precedence over inorganic materials or virgin forest products unless recycled or post-consumer material is not locally available. Organic Mulches are not required where prohibited by local Fuel Modification Plan Guidelines or other applicable local ordinance.
2. The landscape design plan, at a minimum, shall:
- (a) Delineate and label each Hydrozone by number to each Irrigation Valve per Appendix B Section A.
 - (b) Identify each Hydrozone as low water, moderate water, high water, or mixed (low/moderate) water use. Temporarily irrigated areas of the landscape shall be included in the low water use Hydrozone for the water budget calculations;
 - (c) Identify Recreational Areas;
 - (d) Identify areas permanently dedicated to edible plants;
 - (e) Identify areas irrigated with Recycled Water;
 - (f) Identify types of Mulch and application depth;
 - (g) Identify soil amendments, type and quantity;
 - (h) Identify type and surface area of Water Features;
 - (i) Identify Hardscapes (Pervious and Impervious)
 - (j) Identify location, installation details and 24-hour retention or infiltration capacity of any applicable Stormwater Best Management Practices that encourage onsite retention and infiltration of Stormwater. Project Applicants shall refer to the City's National Pollutant Discharge Elimination System (NPDES) Stormwater discharge Permit requirements and the Water Quality Control Board for additional applicable Stormwater technical requirements.
 - (k) Identify any applicable rain harvesting or catchment technologies as discussed in Section 23.S and their 24-hour retention or infiltration capacity;

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (l) Identify any applicable Graywater discharge piping, system components and areas of distribution;
- (m) Contain the following statement: "I have complied with the criteria of the Potable and Recycled Water System Rules and Regulations for the Water Efficient Landscape Ordinance and applied them for the efficient use of water in the landscape design plan." and;
- (n) Bear the signature of a licensed Landscape Architect, licensed Landscape Contractor, or any other person authorized by the State of California to design a landscape. (See sections 5500.1, 5615, 5641, 5641.1, 5641.2, 5641.3, 5641.4, 5641.5, 5641.6, 6701, 7027.5 of the Business and Professions Code, Section 832.27 of Title 16 of the California Code of Regulations, and Section 6721 of the Food and Agriculture Code.)

23.J IRRIGATION DESIGN PLAN

1. This section applies to landscaped areas requiring permanent irrigation, not areas that require temporary irrigation solely for the plant Establishment Period. For the efficient use of water, an irrigation system shall meet all of the requirements listed in this section and the manufacturers' recommendations. The irrigation system and its related components shall be planned and designed to allow for proper installation, management and maintenance. An irrigation design plan meeting the following design criteria shall be submitted as part of the Landscape Documentation Package.

(a) System:

- (i) Landscape Water Meters either a dedicated Water Service meter or private Submeter, shall be installed at all non-residential irrigated landscapes of 1,000 square feet but not more than 5,000 square feet (the level at which Water Code 535 applies) and residential irrigation landscapes of 5,000 square feet or larger. A Landscape Water Meter may be either:
 - (1) a Customer service meter dedicated to landscape use provided by the City; or
 - (2) a privately owned meter or Submeter.
- (ii) Automatic Irrigation Controllers utilizing either evapotranspiration or Soil Moisture Sensor data using non-volatile memory shall be required for irrigation scheduling are required in all irrigation systems.
- (iii) If the water pressure is below or exceeds the recommended pressure of the specified irrigation devices, the installation of a pressure regulating device is required to ensure that the dynamic pressure at each emission device is within the manufacturer's recommended pressure range for optimal performance.
 - (1) If the static pressure is above or below the required dynamic pressure of the irrigation system, pressure-regulating devices such as inline pressure regulators, booster pumps, or other devices shall be installed to meet the required dynamic pressure of the irrigation system.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (2) Static Water Pressure, dynamic or Operating Pressure, and flow reading of the water supply shall be measured at the point of connection. These pressure and flow measurements shall be conducted at the design stage. If the measurements are not available at the design stage, the measurements shall be conducted at installation.
- (iv) Sensors (rain, freeze, wind, etc.), either integral or auxiliary, that suspend or alter irrigation operation during unfavorable weather conditions shall be required on all irrigation systems.
- (v) Manual shutoff valves (such as a gate valve, ball valve or butterfly valve) shall be required as close as possible to the point of connection of the water supply, to minimize water loss in case of an emergency or routine repair.
- (vi) Backflow Prevention Devices shall be required to protect the water supply from contamination by the irrigation system. A Project Applicant shall refer to the applicable local agency code (i.e., public health) for additional Backflow prevention requirements.
- (vii) Flow Sensors that detect high flow conditions created by system damage or malfunction are required for Non-Residential Landscapes and Residential Landscapes of 5,000 square feet or larger.
- (viii) Master Valves are required for all projects except landscapes that make use of technologies that allow for the individual control of Spray Heads that are individually pressurized in a system equipped with low pressure shutdown features.
- (ix) The irrigation system shall be designed to prevent Runoff, low head drainage, Overspray, or other similar conditions where irrigation water flows onto non targeted areas such as adjacent property, non-irrigated areas, Hardscapes, roadways or structures.
- (x) Relevant information from the soil management plan, such as soil type and Infiltration Rate, shall be utilized when designing irrigation systems.
- (xi) The design of the irrigation system shall conform to the Hydrozones of the landscape design plan.
- (xii) The irrigation system must be designed and installed to meet, at a minimum, the IE criteria as described in Section 23.G regarding the Maximum Applied Water Allowance.
- (xiii) All irrigation emission devices must meet the requirements set in the ANSI standard, ASABE/ICC 802-2014. "Landscape Irrigation Sprinkler and Emitter Standard," All Sprinkler Heads installed in the landscape must document a Distribution Uniformity low quarter of 0.65 or higher using the protocol defined in ASABE/ICC 802-2014.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (xiv) It is the Project Applicant's responsibility to inquire with the City about peak water operating demands (on the water supply system) and water restrictions that may impact the effectiveness of the irrigation system.
- (xv) In Mulched planting areas, the use of Low Volume Irrigation is required to maximize water infiltration into the root zone.
- (xvi) Sprinkler Heads and other emission devices shall have matched precipitation rates, unless otherwise directed by the manufacturer's recommendations.
- (xvii) Head to head coverage is recommended. However, sprinkler spacing shall be designed to achieve the highest possible Distribution Uniformity using the manufacturer's recommendations.
- (xviii) Swing joints or other riser-protection components are required on all risers subject to damage that are adjacent to Hardscapes or in high traffic areas of Turf.
- (xix) Check Valves or Anti-Drain Valves are required on all Sprinkler Heads where low point drainage could occur.
- (xx) Areas less than ten feet (10') in width in any direction shall be irrigated with subsurface irrigation or other means that produces no Runoff or Overspray.
- (xxi) Overhead Spray Irrigation shall not be permitted within 24 inches (24") of any non-permeable surface. Allowable irrigation within the setback from non-permeable surfaces may include drip, drip line, or other low flow non-spray technology. The setback area may be planted or unplanted. The surfacing of the setback may be Mulch, gravel, or other porous material. These restrictions may be modified if:
 - (1) the Landscape Area is adjacent to permeable surfacing and no Runoff occurs; or
 - (2) the adjacent non-permeable surfaces are designed and constructed to drain entirely to landscaping; or
 - (3) the irrigation designer specifies an alternative design or technology as part of the Landscape Documentation Package and clearly demonstrates strict adherence to irrigation system design criteria in Section 23.J.1(a)(xii). Prevention of Overspray and Runoff must be confirmed during the Irrigation Audit.
- (xxii) Slopes greater than 25% shall not be irrigated with an irrigation system with a application rate exceeding 0.75 inches (0.75") per hour. This restriction may be modified if the landscape designer specifies an alternative design or technology, as part of the Landscape Documentation Package, and clearly demonstrates no Runoff or erosion will occur. Prevention of Runoff and erosion must be confirmed during the Irrigation Audit.

(b) Hydrozones:

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (i) Each Irrigation Valve shall irrigate a Hydrozone with similar site, slope, sun exposure, soil conditions and plant materials with similar water use.
 - (ii) Spray Heads and other emission devices shall be selected based on what is appropriate for the plant type within that Hydrozone.
 - (iii) Where feasible, trees shall be placed on separate Irrigation Valves from shrubs, groundcovers, and other plant types. The mature size and extent of the root zone shall be considered when designing irrigation systems for the tree.
 - (iv) Within a Hydrozone, Low and Moderate Water Use Plants may be mixed, but all plants within that Hydrozone shall be classified as Moderate Water Use Plants for MAWA calculations.
 - (v) High Water Use Plants are prohibited and shall not be mixed with Low or Moderate Water Use Plants.
 - (vi) On the landscape design plan and irrigation design plan, Hydrozone areas shall be designated by number letter or other designation. On the irrigation design plan, designate the areas irrigated by each Irrigation Valve and assign a number to each; use this number in the Hydrozone Information Table (see Appendix B Section A). This table can also assist with the Irrigation Audit and programming the controller.
2. The irrigation design plan, at a minimum, shall contain:
- (a) Location and size of separate water meters for landscape;
 - (b) Location, type and size of all components of the irrigation system, including controllers, Main and Lateral Lines, Irrigation Valves, Sprinkler Heads, Soil Moisture Sensors, rain switches, quick couplers, pressure regulators, and Backflow Prevention Devices;
 - (c) Static Water Pressure at the point of connection to the public water supply;
 - (d) Flow Rate (gallons per minute), application rate (inches per hour), and design Operating Pressure for each Station;
 - (e) Recycled Water irrigation systems as specified in Section 23.Q.
 - (f) The following statement: "I have complied with the criteria of the Water Service and Use Rules and Regulations for Water Conservation in Landscaping and applied them accordingly for the efficient use of water in the irrigation design plan."
 - (g) The signature of a licensed Landscape Architect, Certified Irrigation Designer, licensed Landscape Contractor, or any other person authorized by the State of California to design an irrigation system. (See Sections 5500.1, 5615, 5641, 5641.1, 5641.2, 5641.3, 5641.4, 5641.5, 5641.6, 6701, 7027.5 of the Business and Professions Code, Section 832.27 of Title 16 of the California Code of Regulations, and Section 6721 of the Food and Agricultural Code.)

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

23.K GRADING DESIGN PLAN

1. For the efficient use of water, grading of a project site shall be designed to minimize soil erosion, Runoff and water waste. A grading plan shall be submitted as part of the Landscape Documentation Package. A comprehensive grading plan prepared by a civil engineer for other City Permits satisfies this requirement.
 - (a) The Project Applicant shall submit a landscape grading plan that indicates finished configurations and elevations of the Landscape Area including:
 - (i) height of graded slopes;
 - (ii) drainage patterns;
 - (iii) pad elevations;
 - (iv) finish grade; and
 - (v) Stormwater retention improvements, if applicable.
 - (b) To prevent excessive erosion and Runoff, it is highly recommended that Project Applicants:
 - (i) grade so that all irrigation and normal rainfall remains within property lines and does not drain onto non-permeable Hardscapes;
 - (ii) avoid disruption of natural drainage patterns and undisturbed soil; and
 - (iii) avoid soil compaction in Landscape Areas.
 - (c) Grading shall meet all applicable requirements of the City. A geotechnical engineer shall be consulted prior to the installation of landscaping materials and irrigation hardware on slopes greater than 50%, or in any areas where slope stability may be compromised.
 - (d) Proposed grading. For earthwork exceeding 150 cubic yards, or for cuts or fills exceeding five vertical feet, a grading Permit is required.
 - (e) The grading design plan shall contain the following statement: "I have complied with the criteria of the ordinance and applied them accordingly for the efficient use

23.L CERTIFICATE OF COMPLETION

1. The Certificate of Completion (see Appendix C for sample certificate) shall include the following six (6) elements:
 - (a) Project Information sheet contains:
 - (i) Date
 - (ii) Project name
 - (iii) Project Applicant name, telephone, and mailing address;
 - (iv) Project address and location; and
 - (v) Property Owner name, telephone, and mailing address;

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (b) Certification by either the signer of the landscape design plan, the signer of the irrigation design plan, or the licensed Landscape Contractor that the Landscape Project has been installed per the approved Landscape Documentation Package;
 - (i) Where there have been significant changes made in the field during construction, these “As-Builts” or Record Drawings shall be included with the certification;
 - (ii) A diagram of the irrigation plan showing Hydrozones shall be kept with the irrigation controller for subsequent management purposes.
 - (c) Irrigation scheduling parameters used to set the controller (Section 24.M.);
 - (d) Landscape Irrigation Maintenance Schedule (Section 23.N.);
 - (e) Irrigation Audit, Survey and Water Use Analysis (Section 23.O.);
 - (f) Soil analysis report, if not submitted with Landscape Documentation Package, and documentation verifying implementation of soil report recommendations (Section 23.H.).
2. The Project Applicant shall:
- (a) Submit the signed Certificate of Completion to the Building Department for review;
 - (b) Ensure that copies of the approved Certificate of Completion are submitted to Water & Sewer Utilities and property Owner or their designee.
3. The Building Department shall:
- (a) Receive the signed Certificate of Completion from the Project Applicant;
 - (b) Approve or deny the Certificate of Completion. If the Certificate of Completion is denied, the Building Department shall provide information to the Project Applicant regarding reapplication, appeal; or other assistance.

23.M IRRIGATION SCHEDULING

1. For the efficient use of water, all irrigation schedules shall be developed, managed and evaluated to utilize the minimum amount of water required to maintain plant health. Irrigation schedules shall meet the following criteria:
- (a) Irrigation scheduling shall be regulated by Automatic Controllers.
 - (b) Landscape irrigation shall occur between the hours of 6:00 p.m. and 9:00 a.m., unless climatic conditions or unfavorable weather (e.g. high wind, extreme temperature) prevents it or otherwise renders irrigation unnecessary. Operation of the irrigation system outside the normal watering window is allowed for auditing and system maintenance.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (c) For implementation of the irrigation schedule, particular attention must be paid to irrigation run times, emission devices, Flow Rate, and current ETo, so that Applied Water meets the Estimated Total Water Use. Total annual Applied Water shall be less than or equal to Maximum Applied Water Allowance (MAWA). Actual irrigation schedules shall be regulated by Automatic Irrigation Controllers using current evapotranspiration data (e.g., CIMIS) or Soil Moisture Sensor data.
- (d) Parameters used to set the Automatic Controller shall be developed and submitted for each of the following:
 - (i) plant Establishment Period;
 - (ii) Established Landscape; and
 - (iii) temporarily irrigated areas.
- (e) Each irrigation schedule shall consider for each Station all of the following that apply:
 - (i) irrigation interval;
 - (ii) irrigation run times;
 - (iii) number of cycle starts required for each irrigation event to avoid Runoff;
 - (iv) amount of Applied Water scheduled to be applied on a monthly basis;
 - (v) application rate setting;
 - (vi) root depth setting;
 - (vii) plant type setting;
 - (viii) soil type;
 - (ix) slope factor setting;
 - (x) shade factor setting; and
 - (xi) irrigation uniformity or efficiency setting.

23.N LANDSCAPE AND IRRIGATION MAINTENANCE

1. Landscapes shall be maintained to ensure successful establishment following installation, and to ensure water use efficiency consistent with these Rules and Regulations. A maintenance schedule shall be established and submitted to the City with the Certificate of Completion. Maintenance contract documentation shall be provided to the City if so requested.
2. Maintenance shall include, but not be limited to the following: routine inspection; auditing, pressure testing, adjustment and repair of the irrigation system; aerating and de-thatching Turf areas; replenishing Mulch; fertilizing; pruning; replanting of failed plants; weeding; pest control; and removing obstructions to emission devices. Operation of the irrigation system outside the normal watering window is allowed for auditing and maintenance.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

3. Repair of all irrigation equipment shall be done with the originally installed components or their equivalents or with components with greater efficiency.
4. A Project Applicant is encouraged to implement Established Landscape industry sustainable Best Practices for all landscape maintenance activities.
5. Failed plants shall be replaced with the same or functionally equivalent plants that may be size-adjusted as appropriate for the stage of growth of the overall installation. Failing plants shall either be replaced, or be revived through appropriate adjustments in water, nutrients, pest control or other factors as recommended by a landscaping professional.

23.O IRRIGATION AUDIT, SURVEY AND WATER USE ANALYSIS

1. All landscape Irrigation Audits shall be conducted by a third-party Certified Landscape Irrigation Auditor. Landscape Irrigation Audits shall not be conducted by the person who designed the landscape or installed the landscape. The City shall refer the Landscape Documentation Package to any City department or outside agency whose interests or area of expertise warrants their participation in the review process. Referral agencies may include, but are not limited to, Santa Clara Valley Water District and Santa Clara Fire Department.
2. In large projects or projects with multiple landscape installations (i.e. production home Developments) an auditing rate of 1 in 7 lots or approximately 15% will satisfy this requirement.
3. For New Construction and Rehabilitated Landscape Projects installed after December 1, 2015, as described in Section 23.B:
 - (a) The Project Applicant shall submit an Irrigation Audit Report with the Certificate of Completion to Water & Sewer Utilities that shall include, but is not limited to: inspection to confirm that the landscaping and irrigation system were installed as specified in the landscape and irrigation design plan, system tune-up, system test with Distribution Uniformity, reporting Overspray or Runoff that causes overland flow, and preparation of an irrigation schedule, including configuring irrigation controllers with application rate, soil types, Plant Factors, slope, exposure and any other factors necessary for accurate programming;
 - (b) The City of Santa Clara shall administer ongoing programs that may include, but not be limited to, Irrigation Water Use Analysis, Irrigation Audits, Irrigation Surveys and water budget calculations to evaluate compliance with the MAWA.

23.P IRRIGATION EFFICIENCY

For the purpose of determining Estimated Total Water Use, average IE is assumed to be 0.75 for Overhead Spray Devices and 0.81 for Drip System devices.

23.Q RECYCLED WATER

1. The installation of Recycled Water irrigation systems shall allow for the current and future use of Recycled Water

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

2. All Recycled Water irrigation systems shall be designed and operated in accordance with all applicable local and state laws
3. Landscapes using Recycled Water are considered Special Landscape Areas. The ET Adjustment Factor for new and existing (non-rehabilitated) Special Landscape Areas shall not exceed 1.0

23.R GRAYWATER SYSTEMS

Graywater systems for onsite landscape irrigation promote the efficient use of water and are required for New Construction and shower or laundry additions or alterations for single-family buildings. All Graywater systems shall conform to the California Plumbing Code (Title 24, Part 5, Chapter 16) and any applicable local ordinance Standards. Refer to Section 23.B.3. for the applicability of this ordinance to Landscape Areas less than 2,500 square feet with the ETWU met entirely by Graywater.

23.S STORMWATER MANAGEMENT AND RAINWATER RETENTION

1. Stormwater management practices minimize Runoff and increase infiltration which recharges groundwater and improves water quality. Stormwater Best Management Practices shall be incorporated as appropriate into the landscape installation, the details of which shall be shown on the landscape design plan. Practices that increase rainwater capture and retention are encouraged.
2. Project Applicants shall refer to the City's National Pollutant Discharge Elimination System (NPDES) Stormwater discharge Permit requirements and the Regional Water Quality Control Board for information on any additional applicable Stormwater technical requirements.
3. All planted Landscape Areas are required to have Friable soil to maximize water retention and infiltration. Refer to Section 23.I.1.(c).
4. In addition to the requirements set forth in the NPDES Permit, and where not already mandated, it is strongly recommended that Landscape Areas be designed for capture and infiltration capacity that is sufficient to prevent Runoff from Impervious surfaces (i.e. roof and paved areas) from either: the one-inch (1"), 24-hour rain event or the 85th percentile, 24-hour rain event, and/or additional capacity as required by any applicable local, regional, state or federal regulation.
5. In addition to the requirements set forth in the NPDES Permit, and where not already mandated, it is strongly recommended that Stormwater projects incorporate one or more of the following elements to improve onsite Stormwater and dry weather Runoff capture and use:
 - (a) Grade Impervious surfaces, such as driveways, during construction to drain to vegetated areas.
 - (b) Minimize the area of Impervious surfaces such as paved areas, roof and concrete driveways.
 - (c) Incorporate Pervious or porous surfaces (e.g., gravel, permeable pavers or blocks, Pervious or porous concrete) that minimize Runoff.
 - (d) Direct Runoff from paved surfaces and roof areas into planting beds or landscaped areas to maximize site water capture and reuse.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

- (e) Incorporate rain gardens, cisterns, and other rain harvesting or catchment systems.
- (f) Incorporate infiltration beds, swales, basins and drywells to capture Stormwater and dry weather Runoff and increase percolation into the soil.
- (g) Consider constructed wetlands and ponds that retain water, equalize excess flow, and filter pollutants.

23.T PUBLIC EDUCATION

1. Publications: Education is a critical component to promote the efficient use of water in landscapes. The use of appropriate principles of design, installation, management, and maintenance to save water is encouraged.
 - (a) The City shall provide information to all Project Applicants regarding the design, installation, management and maintenance of water-efficient landscapes and irrigation systems. This shall include, and is not limited to, promoting the use of Recycled Water and the efficient use of water through water conservation incentive programs offered by the City or the Santa Clara Valley Water District.
2. All model homes that are landscaped shall have signs installed that provide information on the principles of water-efficient landscaping described in these Rules and Regulations:
 - (a) Signs shall be used to identify the model as an example of a water efficient landscape featuring elements such as Hydrozones, irrigation equipment, and others that contribute to the overall water efficient theme. Signage shall include information about the site water use as designed per these Rules and Regulations, specify who designed and installed the water efficient landscape, and demonstrate low water use approaches to landscaping such as using Native Plants, Graywater systems, and rainwater catchment systems.
 - (b) Information shall be provided about designing, installing, managing, and maintaining water efficient landscapes.

23.U ENVIRONMENTAL REVIEW

The City must comply with the California Environmental Water Quality (CEQA), as appropriate.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

23.V IRRIGATION AUDIT, SURVEY AND WATER USE ANALYSIS OF EXISTING LANDSCAPES

1. This section shall apply to all existing landscapes that were installed before December 1, 2015 and are over one acre in size. The City shall be authorized to require audits to evaluate water use on existing landscapes larger than one acre. Such audit may be also be initiated as a coordinated effort between the City and a Local Water Purveyor (e.g., Santa Clara Valley Water District, as part of the Water District's established outdoor water conservation programs).
 - (a) For existing landscapes in 23.V.1. that have dedicated irrigation meters, the City shall administer programs that may include, but are not limited to, irrigation water use analyses, Irrigation Surveys, and Irrigation Audits to evaluate water use and provide recommendations as necessary to reduce landscape water use to a level that does not exceed the Maximum Applied Water Allowance for existing landscapes. The maximum Applied Water allowance (MAWA) for existing landscapes shall be calculated as follows: $MAWA = (0.8) (ET_o) (LA) (0.62)$
 - (b) For all landscape in Section 23.V.1. that do not have a meter, the City shall administer programs that may include, but are not limited to, Irrigation Surveys and Irrigation Audits to evaluate water use and provide recommendations as necessary in order to prevent water waste.
 - (c) Following the findings and recommendations of the Certified Landscape Irrigation Auditor, the City may require adjustments to irrigation usage, irrigation hardware, and/or landscape materials to reduce irrigation water use. Landscape renovation or rehabilitation resulting from such audit activity shall be considered a Landscape Project, and shall be subject to applicable document submittal requirements of Section 23.F. Components of Landscape Documentation Package.
2. All landscape Irrigation Audits must be completed by a Certified Landscape Irrigation Auditor.

23.W WATER WASTE PREVENTION

1. The City shall prevent water waste resulting from inefficient landscape irrigation by prohibiting Runoff from leaving the target landscape due to low head drainage, Overspray, or other similar conditions where water flows onto adjacent property, non-irrigated areas, walks, roadways, parking lots, or structures.
2. Restrictions regarding Overspray and Runoff may be modified if:
 - (a) The Landscape Area is adjacent to permeable surfacing and no Runoff occurs; or
 - (b) The adjacent non-permeable surfaces are designed and constructed to drain entirely to landscaping.

23.X EFFECTIVE PRECIPITATION

1. The City or other local agency may consider EPPT (25% of annual precipitation) in tracking water use and may use the following equation to calculate the MAWA:

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

Residential: MAWA = (ET_o - EPPT) (0.62) [(0.55 x LA) + (0.45 x SLA)]

Non-Residential: MAWA = (ET_o - EPPT) (0.62) [(0.45 x LA) + (0.45 x SLA)]

23.Y REPORTING

1. By January 31st of each year, the City shall report on implementation and enforcement of its ordinance to the Department of Water Resources.
2. The City shall address the following:
 - (a) The City has a single agency ordinance, adopted February 9, 2016 and updated November 2024.
 - (b) City reporting will be for the calendar year.
 - (c) The Rules and Regulations are at least as efficient as MWELO and include the following differences: High Water Use Plants are prohibited and Non-Functional Turf (Decorative Grass) is prohibited for non-residential properties.
 - (d) The City of Santa Clara is responsible for implementing the Water Service and Use Rules and Regulations.
 - (e) State number and types of projects subject to the ordinance during the specified reporting period.
 - (f) State the total area (in square feet or acres) subject to the ordinance over the reporting period, if available.
 - (g) Provide the number of new housing starts, new commercial projects, and landscape retrofits during the reporting period.
 - (h) Describe review procedure for projects subject to the ordinance.
 - (i) Describe actions taken to verify compliance. Is a plan check performed; if so, by what entity? Is a site inspection performed; if so, by what entity? Is a post-installation audit required; if so, by whom?
 - (j) Describe enforcement measures.
 - (k) Explain implementation and enforcement challenges.
 - (l) Describe educational and other needs to properly apply the ordinance.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

23.Z APPENDICES

APPENDIX A: REFERENCE ETO TABLE

Appendix A - Reference Evapotranspiration (ET_o) Table*													
<i>County and City</i>	<i>Jan</i>	<i>Feb</i>	<i>Mar</i>	<i>Apr</i>	<i>May</i>	<i>Jun</i>	<i>Jul</i>	<i>Aug</i>	<i>Sep</i>	<i>Oct</i>	<i>Nov</i>	<i>Dec</i>	<i>Annual ET_o</i>
SANTA CLARA													
Gilroy	1.3	1.8	3.1	4.1	5.3	5.6	6.1	5.5	4.7	3.4	1.7	1.1	43.6
Los Gatos	1.5	1.8	2.8	3.9	5.0	5.6	6.2	5.5	4.7	3.2	1.7	1.1	42.9
Morgan Hill	1.5	1.8	3.4	4.2	6.3	7.0	7.1	6.0	5.1	3.7	1.9	1.4	49.5
Palo Alto	1.5	1.8	2.8	3.8	5.2	5.3	6.2	5.6	5.0	3.2	1.7	1.0	43.0
San Jose	1.5	1.8	3.1	4.1	5.5	5.8	6.5	5.9	5.2	3.3	1.8	1.0	45.3
* The values in this table were derived from:													
1) California Irrigation Management Information System (CIMIS);													
2) Reference EvapoTranspiration Zones Map, UC Dept. of Land, Air & Water Resources and California Dept of Water Resources 1999; and													
3) Reference Evapotranspiration for California, University of California, Department of Agriculture and Natural Resources (1987) Bulletin 1922;													
4) Determining Daily Reference Evapotranspiration, Cooperative Extension UC Division of Agriculture and Natural Resources (1987), Publication Leaflet 21426													

POTABLE AND RECYCLED WATER SYSTEM RULES AND REGULATIONS No. 23

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

APPENDIX B: WATER EFFICIENT LANDSCAPE WORKSHEET

This worksheet is filled out by the Project Applicant and it is a required element of the Landscape Documentation Package.

Reference Evapotranspiration (ET_o)

Hydrozone # /Planting Description ^a	Plant Factor (PF)	Irrigation Method ^b	Irrigation Efficiency (IE) ^c	ETAF (PF/IE)	Landscape Area (sq. ft.)	ETAF x Area	Estimated Total Water Use (ETWU) ^d
Regular Landscape Areas							
				Totals	(A)	(B)	
Special Landscape Areas							
				1			
				1			
				1			
				Totals	(C)	(D)	
				ETWU Total			
				Maximum Allowed Water Allowance (MAWA)^e			

^aHydrozone #/Planting Description

E.g

1.) front lawn

2.) low water use plantings

3.) medium water use planting

^bIrrigation Method

overhead spray

or drip

^cIrrigation Efficiency

0.75 for spray head

0.81 for drip

^dETWU (Annual Gallons Required) =

$ET_o \times 0.62 \times ETAF \times Area$

where 0.62 is a conversion factor that converts acre-inches per acre per year to gallons per square foot per year.

^eMAWA (Annual Gallons Allowed) = $(ET_o) (0.62) [(ETAF \times LA) + ((1-ETAF) \times SLA)]$

where 0.62 is a conversion factor that converts acre-inches per acre per year to gallons per square foot per year, LA is the total landscape area in square feet, SLA is the total Special Landscape Area in square feet, and ETAF is .55 for residential areas and 0.45 for non-residential areas.

ETAF Calculations

Regular Landscape Areas

Total ETAF x Area	(B)
Total Area	(A)
Average ETAF	B ÷ A

All Landscape Areas

Total ETAF x Area	(B+D)
Total Area	(A+C)
Sitewide ETAF	(B+D) ÷ (A+C)

Average ETAF for Regular Landscape Areas must be 0.55 or below for residential areas, and 0.45 or below for non-residential areas.

POTABLE AND RECYCLED WATER SYSTEM RULES AND REGULATIONS No. 23

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

APPENDIX C: CERTIFICATE OF COMPLETION

CITY OF SANTA CLARA CERTIFICATE OF COMPLETION & INSTALLATION			
SUBMIT TO THE COMMUNITY DEVELOPMENT DEPARTMENT UPON COMPLETION OF THE LANDSCAPE PROJECT: 1500 WARBURTON AVENUE, SANTA CLARA, CA 95050			
PROJECT INFORMATION			
Name		Date	
Site Address		Parcel, tract or lot number:	
City	State	Zip Code	
APPLICANT INFORMATION			
Name		Tel.	
Title		Email	
Company		Street Address	
City	State	Zip Code	
PROPERTY OWNER or their DESIGNEE (if different from Project Applicant)			
Name		Tel.	
Title		Email	
Company		Street Address	
City	State	Zip Code	
"I/we certify that I/we have received copies of all the documents within the Landscape Documentation Package and the Certificate of Completion and that it is our responsibility to see that the project is maintained in accordance with the Landscape and Irrigation Maintenance Schedule."			
Signature		Date	
DOCUMENT(S)		DATE	
Landscape Documentation Package submitted to Community Development Department			
Landscape Documentation Package approved by Community Development Department			
Water Efficient Landscape Worksheet submitted to Water & Sewer Utilities			
CERTIFICATION OF INSTALLATION ACCORDING TO THE LANDSCAPE DOCUMENTATION PACKAGE			
"I/we certify that based upon periodic site observations, the work has been completed in accordance with the ordinance and that the landscape planting and irrigation installation conform with the criteria and specifications of the approved Landscape Documentation Package."			
Signature*		Date	
*Signer of the landscape design plan, signer of the irrigation plan, or a licensed Landscape Contractor.			
Name		Tel.	
Title		Email Address	
License Number or Certification Number			
Company		Street Address	
City	State	Zip Code	
REQUIRED ATTACHMENTS			
IRRIGATION SCHEDULING		Per Rules and Regulations Section 23.M.	
LANDSCAPE & IRRIGATION MAINTENANCE SCHEDULE		Per Rules and Regulations Section 23.N.	
LANDSCAPE IRRIGATION AUDIT REPORT		Per Rules and Regulations Section 23.O.	
SOIL MANAGEMENT REPORT (if not submitted with the Landscape Documentation Package)		Attach verification that the recommendations from the Soil Analysis Report were implemented, per Rules and Regulations Section 23.I.	

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

APPENDIX D: PRESCRIPTIVE COMPLIANCE OPTION

(a) This appendix contains prescriptive requirements which may be used as a compliance option to the Model Water Efficient Landscape Ordinance.

(b) Compliance with the following items is mandatory and must be documented on a landscape plan in order to use the prescriptive compliance option:

(1) Submit a Landscape Documentation Package which includes the following elements:

- (A) date
- (B) Project Applicant
- (C) project address (if available, parcel and/or lot number(s))
- (D) total Landscape Area (square feet), including a breakdown of Turf and plant material
- (E) project type (e.g., new, rehabilitated, public, private, cemetery, homeowner-installed)
- (F) water supply type (e.g., potable, recycled, well) and identify the Local Retail Water Purveyor if the Project Applicant is not served by a private well
- (G) contact information for the Project Applicant and property Owner
- (H) Project Applicant signature and date with statement, "I agree to comply with the requirements of the prescriptive compliance option to the MWEL0".

(2) Incorporate Compost at a rate of at least four cubic yards per 1,000 square feet to a depth of six inches (6") into Landscape Area (unless contra-indicated by a soil test);

(3) Plant material shall comply with all of the following;

- (A) For residential areas, install climate adapted plants that require occasional, little or no summer water (average WUCOLS Plant Factor 0.3) for 75% of the plant area excluding edibles and areas using Recycled Water; For non-residential areas, install climate adapted plants that require occasional, little or no summer water (average WUCOLS Plant Factor 0.3) for 100% of the plant area excluding edibles and areas using Recycled Water;
- (B) A minimum three-inch (3") layer of Mulch shall be applied on all exposed soil surfaces of planting areas except in Turf areas, creeping or rooting groundcovers, or direct seeding applications where Mulch is contraindicated.

(4) Turf shall comply with all of the following:

- (A) Turf shall not exceed 25% of the Landscape Area in residential areas, and there shall be no Turf in non-residential areas;
- (B) Turf shall not be planted on sloped areas which exceed a slope of one-foot (1') vertical elevation change for every four feet (4') of horizontal length;

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

(C) Turf is prohibited in Parkways less than ten feet (10') wide, unless the Parkway is adjacent to a parking strip and used to enter and exit vehicles. Any Turf in Parkways must be irrigated by sub-surface irrigation or by other technology that creates no Overspray or Runoff.

(5) Irrigation systems shall comply with the following:

(A) Automatic Irrigation Controllers are required and must use evapotranspiration or Soil Moisture Sensor data and utilize a Rain Sensor.

(B) Irrigation controllers shall be of a type which does not lose programming data in the event the primary power source is interrupted.

(C) Pressure regulators shall be installed on the irrigation system to ensure the dynamic pressure of the system is within the manufacturers recommended pressure range.

(D) Manual shutoff valves (such as a gate valve, ball valve, or butterfly valve) shall be installed as close as possible to the point of connection of the water supply.

(E) All irrigation emission devices must meet the requirements set in the ANSI standard, ASABE/ICC 802-2014. "Landscape Irrigation Sprinkler and Emitter Standard," All Sprinkler Heads installed in the landscape must document a Distribution Uniformity low quarter of 0.65 or higher using the protocol defined in ASABE/ICC 802-2014.

(F) Areas less than ten feet (10') in width in any direction shall be irrigated with subsurface irrigation or other means that produces no Runoff or Overspray.

(6) For non-residential projects with Landscape Areas of 1,000 sq. ft. or more, a private Submeter(s) to measure landscape water use shall be installed.

(c) At the time of final inspection, the Project Applicant must provide the Owner of the property with a Certificate of Completion with certification of installation, irrigation schedule and a schedule of landscape and irrigation maintenance.

WATER EFFICIENT LANDSCAPE ORDINANCE (Continued)

APPENDIX E: WELO LANDSCAPE DOCUMENTATION PACKAGE CHECKLIST



**Water Efficient Landscape Ordinance (WELO)
Landscape Documentation Package Checklist**

The following six Landscape Documentation Package components are required by California Code of Regulations, Title 23, Division 2, Chapter 2.7 Model Water Efficient Landscape Ordinance and by the City of Santa Clara Water Service and Use Rules and Regulations.

☐ **1. REQUIRED PROJECT INFORMATION:**

Date		
Project Applicant		
Address & Parcel/Lot #		
Landscape Area	square feet	
Project Type	☐ New ☐ Rehabilitated ☐ Public ☐ Private ☐ Cemetery ☐ Homeowner installed	
Water Supply Type	☐ Potable ☐ Recycled ☐ Well	
Water Purveyor	☐ City of Santa Clara ☐ Valley Water (private well)	
Landscape Documentation Package Checklist		
Contact:	Email	Telephone
Project Applicant		
Property Owner		
Project Applicant Signature Date:		"I agree to comply with the requirements of the water efficient landscape ordinance and submit a complete Landscape Documentation Package."

Attach the following to this Landscape Documentation Package checklist:

- ☐ **2. WATER EFFICIENT LANDSCAPE WORKSHEET**
- ☐ **3. SOIL MANAGEMENT REPORT** (if significant mass grading is not planned)
- ☐ **4. LANDSCAPE DESIGN PLAN**
- ☐ **5. IRRIGATION DESIGN PLAN**
- ☐ **6. GRADING DESIGN PLAN**