

Meeting Date: 4-9-13

# AGENDA REPORT

Agenda Item # 6A.2

City of Santa Clara, California



**Date:** April 2, 2013  
**To:** City Manager for Council Action  
**From:** John C. Roukema, Director of Electric Utility  
**Subject:** Approval for Use of City Forces, Electric Department Estimates

### EXECUTIVE SUMMARY:

It is requested that the City Council find that City Forces, supplemented by Public Works and Contract Labor, if necessary, can best perform the installation of the following electric facilities and approve the use of City Forces, therefore:

Estimate No: 33119  
 Title/Location: Low Voltage Complaint, 1809 Lexington Street  
 Type of Job: Reliability  
 Description of Work: Install one 25kVA 120/240v overhead transformer, two 3K fuses; disconnect jumpers.

Estimated Cost:	\$1,230.38	Customer/Developer Contribution:	\$ 1,230.38
		Salvaged Plant	\$ .00
		Customer Service Charge	\$ .00

Estimate No: 33146  
 Title/Location: Voltage Complaint, 1410 Lexington Street  
 Type of Job: Reliability  
 Description of Work: Remove one 25kVA 120/240V overhead transformer; install two 25kVA 120/240v overhead transformers; four 3k fuses; disconnect jumpers.

Estimated Cost:	\$2,898.28	Customer/Developer Contribution:	\$ .00
		Salvaged Plant	\$ 658.39
		Customer Service Charge	\$ 2,239.89

### RECOMMENDATION:

That Council approve the use of City Electric forces for the installation of facilities at 1809 Lexington Street and 1410 Lexington Street.

  
 John C. Roukema  
 Director of Electric Utility

APPROVED  
  
 Julio J. Fuentes  
 City Manager

*Documents related to this report: None*