

Attachment 5

The table below provides a list of the potential utility crossings and relocations associated with Option 2, the alternative underground route along the Northern Segment.

Utility Conflict #	Existing Utility	Quantity/Size	Approximate Location Along Lafayette ST.
1	Electric	Ductbank with five 5" conduits and one 4" conduit	South of Agnew Rd.
2	Communication	Unknown * typically one or more pipes, each ranging from 1" to 4"	South of Agnew Rd.
3	Communication	Unknown * typically one or more pipes, each ranging from 1" to 4"	South of Agnew Rd.
4	Natural Gas (PG&E)	12"	South of Agnew Rd.
5	Sanitary Sewer	30"	South of Agnew Rd.
6	Natural Gas (PG&E)	6"	South of Agnew Rd.
7	Water	12"	South of Agnew Rd.
8	Natural Gas (SVP)	12"	South of Agnew Rd.
9	Electric	Ductbank with five 5" conduits and one 4" conduit	South of Agnew Rd.
10	Electric	Ductbank with four 5" conduits and one 4" conduit	North of Agnew Rd.
11	Communication	4"	North of Agnew Rd.
12	Natural Gas (PG&E)	6"-24" *	Between Hope Dr. and Agnew Rd.
13	Sanitary Sewer	8"	Between Hope Dr. and Agnew Rd.
14	Storm Drain	15"	South of Hope Dr.
15	Water	12"	Intersection of Hope Dr.
16	Natural Gas (SVP)	12"	Between Eisenhower Dr. and Hope Dr.
17	Natural Gas - Transmission (PG&E)	6"-24" *	Between Eisenhower Dr. and Hope Dr.
18	Electric	1.5" Streetlight conduit *	South of Eisenhower Dr.
19	Electric	1.5" Streetlight conduit *	Intersection of Eisenhower Dr.
20	Sanitary Sewer	21"	North of Eisenhower Dr.
21	Electric	1.5" Streetlight conduit *	North of Hogan Dr.
22	Sanitary Sewer	15"	Between Fairway Glen Dr. and Hogan Dr.
23	Natural Gas (PG&E)	24" *	Between Fairway Glen Dr. and Hogan Dr.
24	Water	8"	Between Fairway Glen Dr. and Hogan Dr.
25	Natural Gas (SVP)	12"	South of Fairway Glen Dr.

* Utility size is estimated, accurate record information is unavailable.