



**BAY AREA
AIR QUALITY
MANAGEMENT
DISTRICT**

ALAMEDA COUNTY

John J. Bauters
(Secretary)
Pauline Russo Cutter
David Haubert
Nate Miley

CONTRA COSTA COUNTY

John Gioia
David Hudson
Karen Mitchoff
(Vice Chair)
Mark Ross

MARIN COUNTY

Katie Rice

NAPA COUNTY

Brad Wagenknecht

SAN FRANCISCO COUNTY

Tyrone Jue
(SF Mayor's Appointee)
Myrna Melgar
Shamann Walton

SAN MATEO COUNTY

David J. Canepa
Carole Groom
Davina Hurt

SANTA CLARA COUNTY

Margaret Abe-Koga
Cindy Chavez
(Chair)
Rich Constantine
Rob Rennie

SOLANO COUNTY

Erin Hannigan
Lori Wilson

SONOMA COUNTY

Teresa Barrett
Lynda Hopkins

Jack P. Broadbent
EXECUTIVE OFFICER/APCO

Connect with the
Bay Area Air District:



August 2, 2021

Tiffany Vien, Assistant Planner
Community Development Department
City of Santa Clara
1500 Warburton Avenue
Santa Clara, CA 95050

RE: Memorex Data Center – Draft Environmental Impact Report

Dear Ms. Vien,

Bay Area Air Quality Management District (Air District) staff has reviewed the Draft Environmental Impact Report (DEIR) for the Memorex Data Center (Project). The Project applicant proposes to demolish the existing buildings on the 9.18-acre site at 1200 Memorex Drive in Santa Clara to construct a four-story, 472,920 square foot data center building with an attached six-story, 87,520 square foot ancillary use office and storage component. To provide an uninterrupted power supply, the Project would include 24 three-megawatt (MW) diesel-fueled generators for the data center, of which 16 generators would be providing 48 MW of backup power generation capacity and eight generators would be providing redundancy, and one 500-kilowatt (kW) diesel-fueled generator for the ancillary use portion of the building.

Since the data center includes backup diesel generators, the Project will require Air District approval of an Authority to Construct and Permit to Operate for the backup diesel generators, and, as such, the Project will be required to comply with all applicable Air District regulations, including, but not limited to, the achieved-in-practice Best Available Control Technology for large emergency backup engines requiring that engines meet U.S. EPA Tier 4 emissions standards. Because diesel combustion produces greenhouse gases (GHGs) and toxic air contaminants (TACs), the Air District encourages the City to go beyond current regulatory requirements and require the project applicant to use cleaner, non-diesel technologies.

Additionally, staff are providing the following recommendations for how the City could enhance its CEQA analysis and minimize emissions from the Project and future proposed data centers.

Consistency with Long-Term State Climate Goals

The DEIR states that “the project would not conflict with plans, policies or regulations adopted for the purpose of reducing the emissions of GHG.” However, the DEIR does not evaluate, disclose, nor discuss the Project's consistency with State policies requiring long-term (i.e., 2045 and 2050) reductions in emissions of GHGs. See *Cleveland Nat'l Forest Foundation v. San Diego Ass'n of Governments* (2017) 3 Cal.5th 497, 516 (CEQA analysis should “compare the [project's] projected greenhouse gas emissions ... from 2020 through 2050 with the Executive Order's goal of reducing emissions to 80 percent below 1990 levels by 2050.”). Air District staff recommends that the GHG analysis be augmented to include an evaluation, disclosure, and discussion of whether the Project will be consistent with the State's policies beyond 2030. Regardless of whether upon further evaluation the City deems that deployment of 25 diesel backup generators is consistent with the State's carbon neutrality target, the Air District recommends that the City compel the project applicant to adopt alternative zero emitting technologies, procure renewable fuel, commit to otherwise mitigate GHG emissions, or a combination of the three.

Non-Testing/Non-Maintenance Operations

The DEIR should include various scenarios of backup power generation operations beyond routine testing and maintenance. Air District staff has reviewed data regarding backup generator usage during non-testing/non-maintenance operations at several Bay Area data centers. Between September 1, 2019, and September 30, 2020, nearly half of the identified data centers in Santa Clara, San Jose, and Sunnyvale operated backup diesel generators for reasons other than routine testing and maintenance. Many of the data centers operated diesel generators during multiple non-testing/non-maintenance events over the course of this period; operation approached 50 hours for one generator for one event; it appears 40 or more generators operated concurrently at two facilities; and one facility ran diesel generators for approximately 400 hours. Please see Attachment 1 for details of the preliminary information on non-testing/non-maintenance operations that the Air District has received from data centers, which demonstrates the need to evaluate these operations. Air District staff recommends that the DEIR include GHG, criteria pollutant, and TAC impacts due to the non-testing/non-maintenance operations of backup power generators. Various scenarios should be considered for non-testing/non-maintenance operations, including non-zero hours of operation and concurrent generator operations.

Recommendations for Achieving Additional Emissions Reductions

To the extent that further analysis concludes the Project's emissions would be cumulatively considerable or inconsistent with the State's climate goals, the Project may need to incorporate mitigation measures to reduce emissions. Even if the revised analysis does not conclude the Project's emissions will be cumulatively considerable, the Air District encourages the City to compel the applicant to incorporate additional emission reduction measures as a condition of approval of the Project. These recommended measures will help ensure the Project's emissions impacts are reduced by the maximum extent possible to achieve the most health protective air quality for Bay Area residents and to achieve climate protection goals established by the State.

The DEIR identifies the predominant source of the Project's GHG emissions as electricity use (75,354 MTCO₂e per year), which would be provided by the city-operated, publicly-owned utility, Silicon Valley Power (SVP). Although the DEIR states that SVP is on track to meet the 2030 GHG emissions reduction target, the Project could significantly reduce GHG emissions by purchasing all its electricity from renewable sources. Specifically, Air District staff recommends that the Project join SVP's Santa Clara Green Power program and thus commit to purchase 100 percent renewable electricity, or otherwise negotiate an electricity contract with SVP for 100 percent renewables.

The Project, as proposed, would use diesel fuel to power the 25 backup generators. To meet State and regional climate goals, the Air District encourages projects to go above and beyond Air District New Source Review permitting requirements. In September 2018, the Air District launched a Diesel Free by '33 campaign to eliminate diesel emissions. Mayor Lisa Gillmor of the City of Santa Clara signed Diesel Free by '33 to pledge the City's commitment to cut diesel use to zero by the end of 2033. To this end, the Air District recommends the City compel the Project applicant to use the cleanest available technologies such as solar battery power, fuel cells, other non-diesel alternatives, or renewable fuels.

Lastly, Air District staff strongly recommends that the City work with SVP, the Air District, State agencies, and the Project proponents for this and similar proposed data center projects to explore alternative options to reduce GHG emissions. For example, the Air District awarded a Climate Protection Grant of \$300,000 to the City of Santa Clara to conduct a pilot project to demonstrate the viability of replacing data center backup diesel generators with electric energy storage systems, and the California Energy Commission has previously provided Electric Program Investment Charge (EPIC) awards for data center microgrids.

We encourage the City to contact Air District staff with any questions and/or to request assistance during the environmental review process. If you have any questions or would like to discuss Air District recommendations further, please contact Josephine Fong, Environmental Planner, at (415) 749-8637 or jfong@baaqmd.gov, or Jakub Zielkiewicz, Advanced Projects Advisor, at (415) 749-8429 or jzielkiewicz@baaqmd.gov.

Sincerely,



Greg Nudd
Deputy Air Pollution Control Officer

Attachment 1: Preliminary Back-Up Diesel Engine Operations (Non-Testing/Non-Maintenance)

cc: BAAQMD Director Margaret Abe-Koga
BAAQMD Chair Cindy Chavez
BAAQMD Director Rich Constantine
BAAQMD Director Rob Rennie

Attachment 1: Preliminary Back-Up Diesel Engine Operations (Non-Testing/Non-Maintenance)

Preliminary back-up diesel engine operations (non-testing/non-maintenance) for select facilities in Santa Clara, Sunnyvale, and San Jose								
September 1, 2019 - September 30, 2020								
Facility operator data, based on facility responses to BAAQMD's 9/25/20 data request and follow-up conversations. Data may be refined and additional information may be available during follow-up discussions.								
Data Center #	Engine #	City	Engine Size (MW)	Hours of operation (non-testing/non-maintenance)	Estimated engine load percentage during each non-testing/non-maintenance operations	Estimated fuel usage during each non-testing/non-maintenance operation (gallons)	Date	Explanation of non-testing/non-maintenance operation
1	1	Santa Clara	2	9	5%	90	8/17/20-8/18/20	State Emergency Load Shedding
1	2	Santa Clara	2	8.8	6%	240	8/17/20-8/18/20	State Emergency Load Shedding
1	2	Santa Clara	2	1.2	5%	29	8/17/20-8/18/20	Human error event
1	3	Santa Clara	2	1	1%	5	8/17/20-8/18/20	Human error event
1	4	Santa Clara	2	8.5	25%	390	8/17/20-8/18/20	State Emergency Load Shedding
1	4	Santa Clara	2	1	26%	58	8/17/20-8/18/20	Human error event
1	5	Santa Clara	2	9.1	31%	400	8/17/20-8/18/20	State Emergency Load Shedding
1	6	Santa Clara	2	8.9	21%	300	8/17/20-8/18/20	State Emergency Load Shedding
1	7	Santa Clara	2	8.8	24%	350	8/17/20-8/18/20	State Emergency Load Shedding
1	8	Santa Clara	2	8.8	25%	350	8/17/20-8/18/20	State Emergency Load Shedding
1	9	Santa Clara	2	8.6	22%	325	8/17/20-8/18/20	State Emergency Load Shedding
1	10	Santa Clara	2	9	19%	300	8/17/20-8/18/20	State Emergency Load Shedding
2	1	Sunnyvale	2	12.6	34%	682	Various	Utility inflicted disturbance
2	2	Sunnyvale	2	14.7	41%	795	Various	Utility inflicted disturbance
2	3	Sunnyvale	2	15.3	30%	828	Various	Utility inflicted disturbance
2	4	Sunnyvale	2	13.8	32%	747	Various	Utility inflicted disturbance
2	5	Sunnyvale	2	20.2	26%	1093	Various	Utility inflicted disturbance
3	1	Santa Clara	2	0.5	1%		8/17/20-8/18/20	State Emergency Load Shedding
3	2	Santa Clara	2	1.4	2%		8/17/20-8/18/20	State Emergency Load Shedding
3	3	Santa Clara	2	36.7	40%		8/17/20-8/18/20	State Emergency Load Shedding
3	4	Santa Clara	2.25	0.2	1%		8/17/20-8/18/20	State Emergency Load Shedding
3	5	Santa Clara	2.25	31.7	36%		8/17/20-8/18/20	State Emergency Load Shedding
3	6	Santa Clara	2.25	37.3	36%		8/17/20-8/18/20	State Emergency Load Shedding
4	1	Santa Clara	2.25	0.4	33%	25	8/16/2020	Lightning strikes to transmission line
4	2	Santa Clara	2.25	0.4	33%	25	8/16/2020	Lightning strikes to transmission line
4	3	Santa Clara	2.25	0.4	33%	25	8/16/2020	Lightning strikes to transmission line
4	4	Santa Clara	2.25	0.4	33%	25	8/16/2020	Lightning strikes to transmission line
4	5	Santa Clara	2.25	0.4	33%	25	8/16/2020	Lightning strikes to transmission line
4	6	Santa Clara	2.25	0.5	33%	32	8/16/2020	Lightning strikes to transmission line
4	7	Santa Clara	2.25	0.5	33%	32	8/16/2020	Lightning strikes to transmission line
4	8	Santa Clara	2.25	0.5	33%	32	8/16/2020	Lightning strikes to transmission line
4	9	Santa Clara	2.25	0.5	33%	32	8/16/2020	Lightning strikes to transmission line
4	10	Santa Clara	2.25	0.5	33%	32	8/16/2020	Lightning strikes to transmission line
4	11	Santa Clara	2.25	0.5	33%	32	8/16/2020	Lightning strikes to transmission line
4	12	Santa Clara	2.25	0.6	33%	38	8/16/2020	Lightning strikes to transmission line

Preliminary back-up diesel engine operations (non-testing/non-maintenance) for select facilities in Santa Clara, Sunnyvale, and San Jose

September 1, 2019 - September 30, 2020

Facility operator data, based on facility responses to BAAQMD's 9/25/20 data request and follow-up conversations. Data may be refined and additional information may be available during follow-up discussions.

Data Center #	Engine #	City	Engine Size (MW)	Hours of operation (non-testing/non-maintenance)	Estimated engine load percentage during each non-testing/non-maintenance operations	Estimated fuel usage during each non-testing/non-maintenance operation (gallons)	Date	Explanation of non-testing/non-maintenance operation
4	13	Santa Clara	2.25	0.6	33%	38	8/16/2020	Lightning strikes to transmission line
4	14	Santa Clara	2.25	0.6	33%	38	8/16/2020	Lightning strikes to transmission line
4	15	Santa Clara	2.25	0.6	33%	38	8/16/2020	Lightning strikes to transmission line
4	16	Santa Clara	2.25	0.6	33%	38	8/16/2020	Lightning strikes to transmission line
4	17	Santa Clara	2.25	0.4	43%	33	8/16/2020	Lightning strikes to transmission line
4	18	Santa Clara	2.25	0.4	43%	33	8/16/2020	Lightning strikes to transmission line
4	19	Santa Clara	2.25	0.4	43%	33	8/16/2020	Lightning strikes to transmission line
4	20	Santa Clara	2.25	0.4	43%	33	8/16/2020	Lightning strikes to transmission line
4	21	Santa Clara	2.25	0.4	43%	33	8/16/2020	Lightning strikes to transmission line
4	22	Santa Clara	2.25	0.5	43%	41	8/16/2020	Lightning strikes to transmission line
4	23	Santa Clara	2.25	0.5	43%	41	8/16/2020	Lightning strikes to transmission line
4	24	Santa Clara	2.25	0.5	43%	41	8/16/2020	Lightning strikes to transmission line
4	25	Santa Clara	2.25	0.5	43%	41	8/16/2020	Lightning strikes to transmission line
4	26	Santa Clara	2.25	0.5	43%	41	8/16/2020	Lightning strikes to transmission line
4	27	Santa Clara	2.25	0.5	43%	41	8/16/2020	Lightning strikes to transmission line
4	28	Santa Clara	2.25	0.6	43%	49	8/16/2020	Lightning strikes to transmission line
4	29	Santa Clara	2.25	0.6	43%	49	8/16/2020	Lightning strikes to transmission line
4	30	Santa Clara	2.25	0.6	43%	49	8/16/2020	Lightning strikes to transmission line
4	31	Santa Clara	2.25	0.6	43%	49	8/16/2020	Lightning strikes to transmission line
4	32	Santa Clara	2.25	0.6	43%	49	8/16/2020	Lightning strikes to transmission line
4	33	Santa Clara	2.25	0.4	52%	34	8/16/2020	Lightning strikes to transmission line
4	34	Santa Clara	2.25	0.4	52%	34	8/16/2020	Lightning strikes to transmission line
4	35	Santa Clara	2.25	0.4	52%	34	8/16/2020	Lightning strikes to transmission line
4	36	Santa Clara	2.25	0.4	52%	34	8/16/2020	Lightning strikes to transmission line
4	37	Santa Clara	2.25	0.4	52%	34	8/16/2020	Lightning strikes to transmission line
4	38	Santa Clara	2.25	0.5	52%	43	8/16/2020	Lightning strikes to transmission line
4	39	Santa Clara	2.25	0.5	52%	43	8/16/2020	Lightning strikes to transmission line
4	40	Santa Clara	2.25	0.5	52%	43	8/16/2020	Lightning strikes to transmission line
4	41	Santa Clara	2.25	0.5	52%	43	8/16/2020	Lightning strikes to transmission line
4	42	Santa Clara	2.25	0.5	52%	43	8/16/2020	Lightning strikes to transmission line
4	43	Santa Clara	2.25	0.5	52%	43	8/16/2020	Lightning strikes to transmission line
4	44	Santa Clara	2.25	0.6	52%	51	8/16/2020	Lightning strikes to transmission line
5	1	Santa Clara	2	5	46%	325	8/17/20-8/18/20	State Emergency Load Shedding
5	2	Santa Clara	2	6	58%	400	8/17/20-8/18/20	State Emergency Load Shedding
6	1	Santa Clara	2	41.9	30%	200	8/17/20-8/18/20	utility outage

Preliminary back-up diesel engine operations (non-testing/non-maintenance) for select facilities in Santa Clara, Sunnyvale, and San Jose

September 1, 2019 - September 30, 2020

Facility operator data, based on facility responses to BAAQMD's 9/25/20 data request and follow-up conversations. Data may be refined and additional information may be available during follow-up discussions.

Data Center #	Engine #	City	Engine Size (MW)	Hours of operation (non-testing/non-maintenance)	Estimated engine load percentage during each non-testing/non-maintenance operations	Estimated fuel usage during each non-testing/non-maintenance operation (gallons)	Date	Explanation of non-testing/non-maintenance operation
6	2	Santa Clara	2	47.7	22%	180	8/17/20-8/18/20	utility outage
6	3	Santa Clara	2	13	2%	20	8/17/20-8/18/20	utility outage
6	4	Santa Clara	2	37.2	54%	500	8/17/20-8/18/20	utility outage
6	5	Santa Clara	2	37.3	38%	250	8/17/20-8/18/20	utility outage
6	6	Santa Clara	2	41.7	0%	20	8/17/20-8/18/20	utility outage
7	1	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	1	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	1	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	2	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	2	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	2	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	3	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	3	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	3	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	4	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	4	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	4	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	5	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	5	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	5	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	6	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	6	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	6	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	7	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	7	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	7	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	8	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	8	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	8	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	9	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	9	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	9	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	10	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	10	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	10	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage

Preliminary back-up diesel engine operations (non-testing/non-maintenance) for select facilities in Santa Clara, Sunnyvale, and San Jose

September 1, 2019 - September 30, 2020

Facility operator data, based on facility responses to BAAQMD's 9/25/20 data request and follow-up conversations. Data may be refined and additional information may be available during follow-up discussions.

Data Center #	Engine #	City	Engine Size (MW)	Hours of operation (non-testing/non-maintenance)	Estimated engine load percentage during each non-testing/non-maintenance operations	Estimated fuel usage during each non-testing/non-maintenance operation (gallons)	Date	Explanation of non-testing/non-maintenance operation
7	11	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	11	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	11	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	12	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	12	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	12	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	13	Santa Clara	2.5	3.5	48%	600	8/18/2020	Power outage
7	13	Santa Clara	2.5	3.5	48%	600	9/6/2020	Power outage
7	13	Santa Clara	2.5	2.5	48%	480	8/14/2020	Power outage
7	14	Santa Clara	2	3.7	45%	220	8/17-8/18	Power outage
7	14	Santa Clara	2	4.9	55%	370	9/6/2020	Power outage
7	15	Santa Clara	2	3.7	45%	210	8/17-8/18	Power outage
7	15	Santa Clara	2	0.4	50%	390	9/6/2020	Power outage
7	16	Santa Clara	2	3.7	45%	220	8/17-8/18	Power outage
7	16	Santa Clara	2	4.9	5%	1.5	9/6/2020	Power outage
7	17	Santa Clara	2	0.2	5%	1.4	8/17-8/18	Power outage
7	17	Santa Clara	2	0.2	5%	0.2	9/6/2020	Power outage
7	18	Santa Clara	2	3.7	40%	210	8/17-8/18	Power outage
7	18	Santa Clara	2	4.9	55%	400	9/6/2020	Power outage
7	19	Santa Clara	2	5.5	50%	360	8/17-8/18	Power outage
7	19	Santa Clara	2	4.9	60%	410	9/6/2020	Power outage
7	20	Santa Clara	2	5.5	50%	370	8/17-8/18	Power outage
7	20	Santa Clara	2	4.9	60%	410	9/6/2020	Power outage
7	21	Santa Clara	2	5.5	50%	370	8/17-8/18	Power outage
7	21	Santa Clara	2	4.9	60%	410	9/6/2020	Power outage
7	22	Santa Clara	2	5.5	50%	370	8/17-8/18	Power outage
7	22	Santa Clara	2	4.9	60%	410	9/6/2020	Power outage
7	23	Santa Clara	2	5.5	20%	150	8/17-8/18	Power outage
7	23	Santa Clara	2	0.7	15%	14	9/6/2020	Power outage
7	24	Santa Clara	2	0.2	5%	1	8/17-8/18	Power outage
7	24	Santa Clara	2	0.1	5%	1	9/6/2020	Power outage
8	1	Santa Clara	2	0.3	5%	2	11/27/2019	System-wide power quality event
8	1	Santa Clara	2	0.2	6%	2	2/15/2020	System-wide power quality event
8	2	Santa Clara	2	0.3	5%	2	11/27/2019	System-wide power quality event
8	2	Santa Clara	2	0.3	5%	2	2/15/2020	System-wide power quality event

Preliminary back-up diesel engine operations (non-testing/non-maintenance) for select facilities in Santa Clara, Sunnyvale, and San Jose

September 1, 2019 - September 30, 2020

Facility operator data, based on facility responses to BAAQMD's 9/25/20 data request and follow-up conversations. Data may be refined and additional information may be available during follow-up discussions.

Data Center #	Engine #	City	Engine Size (MW)	Hours of operation (non-testing/non-maintenance)	Estimated engine load percentage during each non-testing/non-maintenance operations	Estimated fuel usage during each non-testing/non-maintenance operation (gallons)	Date	Explanation of non-testing/non-maintenance operation
8	3	Santa Clara	2	0.3	6%	2	11/27/2019	System-wide power quality event
8	3	Santa Clara	2	0.2	6%	2	2/15/2020	System-wide power quality event
8	4	Santa Clara	2	0.3	7%	2	2/15/2020	System-wide power quality event
8	4	Santa Clara	2	0.2	8%	2	11/27/2019	System-wide power quality event
8	5	Santa Clara	2	0.2	10%	2	11/27/2019	System-wide power quality event
8	5	Santa Clara	2	0.2	8%	2	2/15/2020	System-wide power quality event
8	6	Santa Clara	2	0.2	9%	2	11/27/2019	System-wide power quality event
8	6	Santa Clara	2	0.2	7%	2	2/15/2020	System-wide power quality event
8	7	Santa Clara	2	0.2	15%	2	11/27/2019	System-wide power quality event
8	7	Santa Clara	2	0.2	8%	2	2/15/2020	System-wide power quality event
8	8	Santa Clara	2	0.2	13%	2	11/27/2019	System-wide power quality event
8	8	Santa Clara	2	0.2	6%	2	2/15/2020	System-wide power quality event
8	9	Santa Clara	2	0.2	9%	2	11/27/2019	System-wide power quality event
8	9	Santa Clara	2	0.2	6%	2	2/15/2020	System-wide power quality event
8	10	Santa Clara	2	0.2	12%	2	11/27/2019	System-wide power quality event
8	10	Santa Clara	2	0.2	7%	2	2/15/2020	System-wide power quality event
8	11	Santa Clara	2	0.2	5%	2	11/27/2019	System-wide power quality event
8	11	Santa Clara	2	0.2	6%	2	2/15/2020	System-wide power quality event
8	12	Santa Clara	2	0.2	5%	2	11/27/2019	System-wide power quality event
8	12	Santa Clara	2	0.2	6%	2	2/15/2020	System-wide power quality event
8	13	Santa Clara	2	0.2	6%	2	11/27/2019	System-wide power quality event
8	13	Santa Clara	2	0.2	7%	2	2/15/2020	System-wide power quality event
8	14	Santa Clara	2	0.2	6%	2	11/27/2019	System-wide power quality event
8	14	Santa Clara	2	0.2	7%	2	2/15/2020	System-wide power quality event
8	15	Santa Clara	2	0.2	12%	2	11/27/2019	System-wide power quality event
8	15	Santa Clara	2	0.2	11%	2	2/15/2020	System-wide power quality event
8	16	Santa Clara	2	0.3	10%	2	11/27/2019	System-wide power quality event
8	16	Santa Clara	2	0.2	9%	2	2/15/2020	System-wide power quality event
8	17	Santa Clara	2	0.3	9%	2	11/27/2019	System-wide power quality event
8	17	Santa Clara	2	0.2	9%	2	2/15/2020	System-wide power quality event
8	18	Santa Clara	2	0.2	7%	2	11/27/2019	System-wide power quality event
8	18	Santa Clara	2	0.2	6%	2	2/15/2020	System-wide power quality event
8	19	Santa Clara	2	0.2	10%	2	11/27/2019	System-wide power quality event
8	19	Santa Clara	2	0.2	8%	2	2/15/2020	System-wide power quality event
8	20	Santa Clara	2	0.2	9%	2	11/27/2019	System-wide power quality event

Preliminary back-up diesel engine operations (non-testing/non-maintenance) for select facilities in Santa Clara, Sunnyvale, and San Jose

September 1, 2019 - September 30, 2020

Facility operator data, based on facility responses to BAAQMD's 9/25/20 data request and follow-up conversations. Data may be refined and additional information may be available during follow-up discussions.

Data Center #	Engine #	City	Engine Size (MW)	Hours of operation (non-testing/non-maintenance)	Estimated engine load percentage during each non-testing/non-maintenance operations	Estimated fuel usage during each non-testing/non-maintenance operation (gallons)	Date	Explanation of non-testing/non-maintenance operation
8	20	Santa Clara	2	0.2	7%	2	2/15/2020	System-wide power quality event
8	21	Santa Clara	2	0.2	17%	2	11/27/2019	System-wide power quality event
8	21	Santa Clara	2	0.2	12%	2	2/15/2020	System-wide power quality event
8	22	Santa Clara	2	0.2	8%	2	11/27/2019	System-wide power quality event
8	22	Santa Clara	2	0.2	8%	2	2/15/2020	System-wide power quality event
8	23	Santa Clara	2	0.2	6%	2	11/27/2019	System-wide power quality event
8	23	Santa Clara	2	0.2	5%	2	2/15/2020	System-wide power quality event
8	24	Santa Clara	2	0.2	6%	2	11/27/2019	System-wide power quality event
8	24	Santa Clara	2	0.2	5%	2	2/15/2020	System-wide power quality event
9	1	Santa Clara	2	8.4	65%	524	8/17/20-8/18/20	State Emergency Load Shedding
9	2	Santa Clara	2	5.6	60%	400	8/17/20-8/18/20	State Emergency Load Shedding
9	3	Santa Clara	2	2.6	50%	300	8/17/20-8/18/20	Equipment failure
9	4	Santa Clara	2	2.9	1%	20	8/17/20-8/18/20	State Emergency Load Shedding
9	5	Santa Clara	0.23	6.5	7%	10	8/17/20-8/18/20	State Emergency Load Shedding
10	1	Santa Clara	2	9	50%	256	8/17/20-8/18/20	State Emergency Load Shedding
10	2	Santa Clara	2	9	50%	256	8/17/20-8/18/20	State Emergency Load Shedding
10	3	Santa Clara	2	9	50%	256	8/17/20-8/18/20	State Emergency Load Shedding
10	4	Santa Clara	2.06	4	60%	296	8/17/20-8/18/20	State Emergency Load Shedding
10	5	Santa Clara	2.06	4	60%	296	8/17/20-8/18/20	State Emergency Load Shedding
10	6	Santa Clara	2.06	4	60%	296	8/17/20-8/18/20	State Emergency Load Shedding
10	7	Santa Clara	3	7	40%	1280	8/17/20-8/18/20	State Emergency Load Shedding
10	7	Santa Clara	3	4	40%	731.5	8/17/20-8/18/20	State Emergency Load Shedding
10	8	Santa Clara	3	7	40%	1280	8/17/20-8/18/20	State Emergency Load Shedding
10	8	Santa Clara	3	4	40%	731.5	8/17/20-8/18/20	State Emergency Load Shedding
10	9	Santa Clara	3	7	40%	1280	8/17/20-8/18/20	State Emergency Load Shedding
10	9	Santa Clara	3	4	40%	731.5	8/17/20-8/18/20	State Emergency Load Shedding
10	10	Santa Clara	3	7	40%	1280	8/17/20-8/18/20	State Emergency Load Shedding
10	10	Santa Clara	3	4	40%	731.5	8/17/20-8/18/20	State Emergency Load Shedding
10	11	Santa Clara	3	5	50%	780	8/17/20-8/18/20	State Emergency Load Shedding
10	12	Santa Clara	3	5	50%	780	8/17/20-8/18/20	State Emergency Load Shedding
10	13	Santa Clara	3	5.5	50%	930	8/17/20-8/18/20	State Emergency Load Shedding
10	14	Santa Clara	3	5	50%	780	8/17/20-8/18/20	State Emergency Load Shedding
10	15	Santa Clara	3	5.5	50%	930	8/17/20-8/18/20	State Emergency Load Shedding
10	16	Santa Clara	3	5.5	50%	930	8/17/20-8/18/20	State Emergency Load Shedding
10	17	Santa Clara	2.75	9	70%	625	8/17/20-8/18/20	State Emergency Load Shedding

Preliminary back-up diesel engine operations (non-testing/non-maintenance) for select facilities in Santa Clara, Sunnyvale, and San Jose

September 1, 2019 - September 30, 2020

Facility operator data, based on facility responses to BAAQMD's 9/25/20 data request and follow-up conversations. Data may be refined and additional information may be available during follow-up discussions.

Data Center #	Engine #	City	Engine Size (MW)	Hours of operation (non-testing/non-maintenance)	Estimated engine load percentage during each non-testing/non-maintenance operations	Estimated fuel usage during each non-testing/non-maintenance operation (gallons)	Date	Explanation of non-testing/non-maintenance operation
10	18	Santa Clara	2.75	8.2	70%	525	8/17/20-8/18/20	State Emergency Load Shedding
10	19	Santa Clara	2.75	8.9	70%	615	8/17/20-8/18/20	State Emergency Load Shedding
10	20	Santa Clara	2.75	11.3	70%	975	8/17/20-8/18/20	State Emergency Load Shedding
10	21	Santa Clara	2	4	60%	238	8/17/20-8/18/20	State Emergency Load Shedding
10	22	Santa Clara	3	5.5	50%	930	8/17/20-8/18/20	State Emergency Load Shedding
10	23	Santa Clara	3	5.5	50%	930	8/17/20-8/18/20	State Emergency Load Shedding
10	24	Santa Clara	3	5.5	50%	930	8/17/20-8/18/20	State Emergency Load Shedding
10	25	Santa Clara	2.75	8.3	70%	530	8/17/20-8/18/20	State Emergency Load Shedding
10	26	Santa Clara	2.75	8.3	70%	530	8/17/20-8/18/20	State Emergency Load Shedding
10	27	Santa Clara	2.75	8.3	70%	530	8/17/20-8/18/20	State Emergency Load Shedding
10	28	Santa Clara	2.75	8.3	70%	530	8/17/20-8/18/20	State Emergency Load Shedding
10	29	Santa Clara	3	11.6	60%	1786		Power bump
10	29	Santa Clara	3	4	60%	616		Power bump
10	29	Santa Clara	3	3.5	60%	539	8/17/20-8/18/20	State Emergency Load Shedding
10	29	Santa Clara	3	3	60%	462		Power bump
10	29	Santa Clara	3	2.7	60%	416		Power bump
10	29	Santa Clara	3	1	60%	154		Power bump
10	29	Santa Clara	3	1	60%	154		Utility outage
10	30	Santa Clara	3	10.1	60%	1555		Utility outage
10	30	Santa Clara	3	5.5	60%	847		Power bump
10	30	Santa Clara	3	4	60%	616		Utility outage
10	30	Santa Clara	3	3.7	60%	569.8	8/17/20-8/18/20	State Emergency Load Shedding
10	30	Santa Clara	3	2.8	60%	431		Power bump
10	30	Santa Clara	3	1	60%	154		Utility outage
10	30	Santa Clara	3	1	60%	154		Utility outage
10	31	Santa Clara	3	11.5	60%	1771		Utility outage
10	31	Santa Clara	3	4	60%	616		Utility outage
10	31	Santa Clara	3	3.7	60%	569.8	8/17/20-8/18/20	State Emergency Load Shedding
10	31	Santa Clara	3	3	60%	462		Power bump
10	31	Santa Clara	3	2.7	60%	416		Power bump
10	31	Santa Clara	3	1	60%	154		Utility outage
10	31	Santa Clara	3	1	60%	154		Utility outage
10	32	Santa Clara	3	11.6	60%	1786		Utility outage
10	32	Santa Clara	3	4	60%	616		Utility outage
10	32	Santa Clara	3	3	60%	462		Power bump

Preliminary back-up diesel engine operations (non-testing/non-maintenance) for select facilities in Santa Clara, Sunnyvale, and San Jose

September 1, 2019 - September 30, 2020

Facility operator data, based on facility responses to BAAQMD's 9/25/20 data request and follow-up conversations. Data may be refined and additional information may be available during follow-up discussions.

Data Center #	Engine #	City	Engine Size (MW)	Hours of operation (non-testing/non-maintenance)	Estimated engine load percentage during each non-testing/non-maintenance operations	Estimated fuel usage during each non-testing/non-maintenance operation (gallons)	Date	Explanation of non-testing/non-maintenance operation
10	32	Santa Clara	3	3	60%	462	8/17/20-8/18/20	State Emergency Load Shedding
10	32	Santa Clara	3	2.7	60%	416		Power bump
10	32	Santa Clara	3	1	60%	154		Utility outage
10	32	Santa Clara	3	1	60%	154		Utility outage
10	33	Santa Clara	3	11.6	60%	1786		Utility outage
10	33	Santa Clara	3	4	60%	616		Utility outage
10	33	Santa Clara	3	3.7	60%	569.8	8/17/20-8/18/20	State Emergency Load Shedding
10	33	Santa Clara	3	3	60%	462		Power bump
10	33	Santa Clara	3	2.8	60%	431.2		Power bump
10	33	Santa Clara	3	1	60%	154		Utility outage
10	33	Santa Clara	3	1	60%	154		Utility outage
10	34	Santa Clara	3	11.6	60%	1786		Utility outage
10	34	Santa Clara	3	4	60%	616		Utility outage
10	34	Santa Clara	3	3.7	60%	569.8	8/17/20-8/18/20	State Emergency Load Shedding
10	34	Santa Clara	3	3	60%	462		Power bump
10	34	Santa Clara	3	2.9	60%	447		Power bump
10	34	Santa Clara	3	1	60%	154		Utility outage
10	34	Santa Clara	3	1	60%	154		Utility outage
10	35	Santa Clara	3	6	40%	450	8/17/20-8/18/20	State Emergency Load Shedding
10	36	Santa Clara	3	2	40%	150	8/17/20-8/18/20	State Emergency Load Shedding
10	37	Santa Clara	3	5.5	40%	412	8/17/20-8/18/20	State Emergency Load Shedding
10	38	Santa Clara	3	5.5	40%	412	8/17/20-8/18/20	State Emergency Load Shedding
10	39	Santa Clara	3	5.5	40%	412	8/17/20-8/18/20	State Emergency Load Shedding
10	40	Santa Clara	2.75	8.3	70%	530	8/17/20-8/18/20	State Emergency Load Shedding
11	1	Santa Clara	2	5.8	25%	390	8/17/20-8/18/20	Power supplier request
11	1	Santa Clara	2	4.1	25%	390	8/17/20-8/18/20	Power supplier request
11	2	Santa Clara	2	4.7	31%	280	8/17/20-8/18/20	Power supplier request
11	2	Santa Clara	2	3.9	31%	280	8/17/20-8/18/20	Power supplier request
11	3	Santa Clara	2	5.6	28%	380	8/17/20-8/18/20	Power supplier request
11	3	Santa Clara	2	4.3	28%	380	8/17/20-8/18/20	Power supplier request
11	4	Santa Clara	2	5.4	43%	605	8/17/20-8/18/20	Power supplier request
11	4	Santa Clara	2	3.5	43%	605	8/17/20-8/18/20	Power supplier request
11	5	Santa Clara	0.23	6	17%	27	8/17/20-8/18/20	Power supplier request
11	5	Santa Clara	0.23	3.5	17%	27	8/17/20-8/18/20	Power supplier request
11	6	Santa Clara	2	4.5	17%	75	8/17/20-8/18/20	Power supplier request

Preliminary back-up diesel engine operations (non-testing/non-maintenance) for select facilities in Santa Clara, Sunnyvale, and San Jose

September 1, 2019 - September 30, 2020

Facility operator data, based on facility responses to BAAQMD's 9/25/20 data request and follow-up conversations. Data may be refined and additional information may be available during follow-up discussions.

Data Center #	Engine #	City	Engine Size (MW)	Hours of operation (non-testing/non-maintenance)	Estimated engine load percentage during each non-testing/non-maintenance operations	Estimated fuel usage during each non-testing/non-maintenance operation (gallons)	Date	Explanation of non-testing/non-maintenance operation
11	7	Santa Clara	2	4.7	8%	75	8/17/20-8/18/20	Power supplier request
11	8	Santa Clara	2	4.7	8%	100	8/17/20-8/18/20	Power supplier request
11	9	Santa Clara	2	4.7	9%	100	8/17/20-8/18/20	Power supplier request
11	10	Santa Clara	2	4.8	11%	100	8/17/20-8/18/20	Power supplier request
11	11	Santa Clara	0.23	4.8	7%	30	8/17/20-8/18/20	Power supplier request
12	1	Santa Clara	0.23	2.9	14%	87	8/17/20-8/18/20	Utility outage
12	2	Santa Clara	2	43	8%	160	8/17/20-8/18/20	Utility outage
12	3	Santa Clara	2	42.8	6%	160	8/17/20-8/18/20	Utility outage
12	4	Santa Clara	2	38	15%	420	8/17/20-8/18/20	Utility outage
12	5	Santa Clara	2	24	55%	500	8/17/20-8/18/20	Utility outage
12	6	Santa Clara	2	10	6%	160	8/17/20-8/18/20	Utility outage
12	7	Santa Clara	2	10.4	7%	160	8/17/20-8/18/20	Utility outage
12	8	Santa Clara	2	42.1	30%	250	8/17/20-8/18/20	Utility outage
12	9	Santa Clara	2	41.8	30%	250	8/17/20-8/18/20	Utility outage
12	10	Santa Clara	2	10.3	1%	50	8/17/20-8/18/20	Utility outage
12	11	Santa Clara	2	10	7%	160	8/17/20-8/18/20	Utility outage
13	1	Santa Clara	2	19.8	37%	80.3	Various	Utility power outages; power blips, UPS/board repair
13	2	Santa Clara	2	20.4	37%	82.5	Various	Utility power outages; power blips, UPS/board repair
13	3	Santa Clara	1.25	14.96	43%	527	Various	Utility power outages; power blips, UPS/board repair
13	4	Santa Clara	1.25	14.94	42%	525	Various	Utility power outages; power blips, UPS/board repair
13	5	Santa Clara	1.25	14.92	43%	523	Various	Utility power outages; power blips, UPS/board repair
14	1	Santa Clara	2.7	1.9	22%	90	11/27/2019	Utility sag event
14	2	Santa Clara	2.7	1.9	32%	95	11/27/2019	Utility sag event
14	3	Santa Clara	2.7	1.9	1%	57	11/27/2019	Utility sag event
14	4	Santa Clara	2.7	1.9	34%	99.75	11/27/2019	Utility sag event
14	5	Santa Clara	2.7	4.4	41%	422	8/18/2020	Mandatory load transfer
14	6	Santa Clara	2.7	6.3	32%	445	8/18/2020	Mandatory load transfer
14	7	Santa Clara	2.7	4.7	2%	139	8/18/2020	Mandatory load transfer
14	8	Santa Clara	2.7	4.5	48%	123	8/18/2020	Mandatory load transfer
15	1	Santa Clara	2	14	65%	693		
15	2	Santa Clara	2	14	65%	693		
15	3	Santa Clara	2	14	65%	693		
15	4	Santa Clara	2	14				
15	5	Santa Clara	2	14				
15	6	Santa Clara	2.5	14	19%	486		

Preliminary back-up diesel engine operations (non-testing/non-maintenance) for select facilities in Santa Clara, Sunnyvale, and San Jose

September 1, 2019 - September 30, 2020

Facility operator data, based on facility responses to BAAQMD's 9/25/20 data request and follow-up conversations. Data may be refined and additional information may be available during follow-up discussions.

Data Center #	Engine #	City	Engine Size (MW)	Hours of operation (non-testing/non-maintenance)	Estimated engine load percentage during each non-testing/non-maintenance operations	Estimated fuel usage during each non-testing/non-maintenance operation (gallons)	Date	Explanation of non-testing/non-maintenance operation
15	7	Santa Clara	2.5	14				
16	1	Santa Clara	2	2.4	2%	45.6	7/31/2020	Utility power outage
16	2	Santa Clara	2	2.4	18%	48	7/31/2020	Utility power outage
16	3	Santa Clara	1.5	2.4	30%	40.8	7/31/2020	Utility power outage
16	4	Santa Clara	1.5	2.4	25%	38.4	7/31/2020	Utility power outage
17	1	San Jose	2	2	14%	80	11/26/2019	Commercial power outage
17	2	San Jose	2	2	14%	80	11/26/2019	Commercial power outage
18	1	San Jose	2	1.5	30%	150	8/16/2020	Utility power outage
18	1	San Jose	2	1.5	30%	150	8/25/2020	Utility power outage
18	2	San Jose	2	1.5	30%	150	8/16/2020	Utility power outage
18	2	San Jose	2	1.5	30%	150	8/25/2020	Utility power outage
18	3	San Jose	2	1.5	30%	150	8/16/2020	Utility power outage
18	3	San Jose	2	1.5	30%	150	8/25/2020	Utility power outage
18	4	San Jose	2	1.5	30%	150	8/16/2020	Utility power outage
18	4	San Jose	2	1.5	30%	150	8/25/2020	Utility power outage
18	5	San Jose	2	1.5	30%	150	8/16/2020	Utility power outage
18	5	San Jose	2	1.5	30%	150	8/25/2020	Utility power outage
18	6	San Jose	2	1.5	30%	150	8/16/2020	Utility power outage
18	6	San Jose	2	1.5	30%	150	8/25/2020	Utility power outage
19	1	San Jose	1.5	4	20%	200	8/19/2020	Substation transformer power equipment failure
19	2	San Jose	1.5	4	17%	190	8/19/2020	Substation transformer power equipment failure
19	3	San Jose	1.5	4	50%	290	8/19/2020	Substation transformer power equipment failure
19	4	San Jose	1.5	4	60%	310	8/19/2020	Substation transformer power equipment failure
19	5	San Jose	1.5	4	53%	300	8/19/2020	Substation transformer power equipment failure
19	6	San Jose	1.5	4	40%	280	8/19/2020	Substation transformer power equipment failure
20	1	Santa Clara	3	4.1	42%	410	8/18/2020	State Emergency Load Shedding
20	1	Santa Clara	3	3.5	42%	350	9/7/2020	State Emergency Load Shedding
20	1	Santa Clara	3	1.5	42%	150	8/17/2020	State Emergency Load Shedding
20	2	Santa Clara	3	4.1	37%	410	8/18/2020	State Emergency Load Shedding
20	2	Santa Clara	3	3.6	37%	360	9/7/2020	State Emergency Load Shedding
20	2	Santa Clara	3	2.6	37%	250	8/17/2020	State Emergency Load Shedding
20	3	Santa Clara	3	4.1	40%	410	8/18/2020	State Emergency Load Shedding
20	3	Santa Clara	3	3.6	40%	360	9/7/2020	State Emergency Load Shedding
20	3	Santa Clara	3	1.8	40%	180	8/17/2020	State Emergency Load Shedding
20	4	Santa Clara	3	4.1	38%	410	8/18/2020	State Emergency Load Shedding

Preliminary back-up diesel engine operations (non-testing/non-maintenance) for select facilities in Santa Clara, Sunnyvale, and San Jose

September 1, 2019 - September 30, 2020

Facility operator data, based on facility responses to BAAQMD's 9/25/20 data request and follow-up conversations. Data may be refined and additional information may be available during follow-up discussions.

Data Center #	Engine #	City	Engine Size (MW)	Hours of operation (non-testing/non-maintenance)	Estimated engine load percentage during each non-testing/non-maintenance operations	Estimated fuel usage during each non-testing/non-maintenance operation (gallons)	Date	Explanation of non-testing/non-maintenance operation
20	4	Santa Clara	3	3.6	38%	360	9/7/2020	State Emergency Load Shedding
20	4	Santa Clara	3	1.4	38%	150	8/17/2020	State Emergency Load Shedding
20	5	Santa Clara	3	4.2	20%	410	8/18/2020	State Emergency Load Shedding
20	5	Santa Clara	3	1.1	20%	120	8/17/2020	State Emergency Load Shedding
20	6	Santa Clara	3	4.1	17%	410	8/18/2020	State Emergency Load Shedding
20	6	Santa Clara	3	1.3	17%	130	8/17/2020	State Emergency Load Shedding
20	7	Santa Clara	3	4.1	18%	410	8/18/2020	State Emergency Load Shedding
20	7	Santa Clara	3	1.4	18%	140	8/17/2020	State Emergency Load Shedding
20	8	Santa Clara	3	4.1	19%	410	8/18/2020	State Emergency Load Shedding
20	8	Santa Clara	3	1.4	19%	140	8/17/2020	State Emergency Load Shedding
20	9	Santa Clara	3	4.2	15%	420	8/18/2020	State Emergency Load Shedding
20	9	Santa Clara	3	1.1	15%	110	8/17/2020	State Emergency Load Shedding
20	10	Santa Clara	3	4.1	29%	410	8/18/2020	State Emergency Load Shedding
20	10	Santa Clara	3	1.3	29%	130	8/17/2020	State Emergency Load Shedding
20	11	Santa Clara	3	4.3	18%	430	8/18/2020	State Emergency Load Shedding
20	11	Santa Clara	3	1.4	18%	140	8/17/2020	State Emergency Load Shedding
20	12	Santa Clara	3	4.1	19%	410	8/18/2020	State Emergency Load Shedding
20	12	Santa Clara	3	1.4	19%	140	8/17/2020	State Emergency Load Shedding
20	13	Santa Clara	3	4.1	3%	120	8/18/2020	State Emergency Load Shedding
20	13	Santa Clara	3	1.2	3%	40	8/17/2020	State Emergency Load Shedding
20	14	Santa Clara	3	4	2%	120	8/18/2020	State Emergency Load Shedding
20	14	Santa Clara	3	1.3	2%	40	8/17/2020	State Emergency Load Shedding
20	15	Santa Clara	3	4	2%	160	8/18/2020	State Emergency Load Shedding
20	15	Santa Clara	3	1.3	2%	50	8/17/2020	State Emergency Load Shedding
20	16	Santa Clara	3	2	30%	20	8/17/2020	State Emergency Load Shedding
20	16	Santa Clara	3	1.5	30%	20	8/18/2020	State Emergency Load Shedding
20	17	Santa Clara	3	0.9	10%	20	8/17/2020	State Emergency Load Shedding
20	17	Santa Clara	3	0.8	10%	20	8/18/2020	State Emergency Load Shedding