



Legislation Details (With Text)

File #: 19-727 **Version:** 1 **Name:**

Type: Consent Calendar **Status:** Passed

File created: 5/16/2018 **In control:** City Council and Authorities Concurrent

On agenda: 6/25/2019 **Final action:** 6/25/2019

Title: Action on a Resolution for the Use of City Water Forces at 5302 Betsy Ross Drive and 3096 Mauricia Avenue

Sponsors:

Indexes:

Code sections:

Attachments: 1. Use of City Water Forces Resolution, 2. Resolution No. 19-8719.pdf

Date	Ver.	Action By	Action	Result
6/25/2019	1	City Council and Authorities Concurrent	Adopted	

REPORT TO COUNCIL

SUBJECT

Action on a Resolution for the Use of City Water Forces at 5302 Betsy Ross Drive and 3096 Mauricia Avenue

BACKGROUND

Charter Section 1310 titled Contracts on Public Works states in part “that every contract involving an expenditure of more than one thousand dollars (\$1,000.00) for the construction or improvement, (excluding maintenance and repair), of public buildings, works, streets, drains, sewers, utilities, parks and playgrounds shall be let to the lowest responsible bidder.” The section further states that “the City Council may declare and determine that, in its opinion, the work in question may be performed better or more economically by the City with its own employees, and after the adoption of a resolution to this effect by at least four affirmative votes, it may proceed to have said work done in the manner stated, without further observance of the provisions of this section.”

DISCUSSION

Staff believes that the work described below is best performed with City Forces to complete the limited size and scope of work outline below. The Water Utility has in-house knowledge and trained personnel operating and maintaining water services that can be leveraged to more economically perform this work. Bidding out the work and contracting with a private entity would delay the construction projects. Therefore, staff recommends that the City Council find that City Forces can best perform the installation of the following water services and approve the use of City Forces.

Location: 5302 Betsy Ross Drive

Type of Service: Provide new installation services for new public water improvements.

Description of Work: Upgrade existing (1) - 8" fire service w/ Detector Check Valve with (1) -8" fire service with RPDA backflow prevention device.
Job Number: 592-1423-80300-7054-(i)30656
Cost Estimate: \$ 25,675.14

Location: 3096 Mauricia Avenue
Type of Service: Provide new installation services for new public water improvements.

Description of Work: Upgrade existing (1) - 5/8" water service with (1) -1" water service.

Job Number: 592-1423-80300-7054-(i)30548

Cost Estimate: \$ 25,585.60

ENVIRONMENTAL REVIEW

The actions being considered are exempt from the California Environmental Quality Act ("CEQA") pursuant to CEQA Guidelines sections 15302(c) (Class 2 - Replacement or Reconstruction) because they involve the replacement or reconstruction of existing utility systems and/or facilities involving negligible expansion of capacity, and 15303(d) (Class 3 - New Construction or Conversion of Small Structures), because they involve the construction of new water utility improvements.

FISCAL IMPACT

The funds to support the staff time and materials for the work detailed in this report are budgeted in the Fiscal Year 2018/19 Adopted Budget.

COORDINATION

This report has been coordinated with the Finance Department and City Attorney's Office.

PUBLIC CONTACT

Public contact was made by posting the Council agenda on the City's official-notice bulletin board outside City Hall Council Chambers. A complete agenda packet is available on the City's website and in the City Clerk's Office at least 72 hours prior to a Regular Meeting and 24 hours prior to a Special Meeting. A hard copy of any agenda report may be requested by contacting the City Clerk's Office at (408) 615-2220, email clerk@santaclaraca.gov or at the public information desk at any City of Santa Clara public library.

RECOMMENDATION

Adopt a Resolution approving the use of City Water forces for the service upgrades at 5302 Betsy Ross Drive and 3096 Mauricia Avenue.

Reviewed by: Gary Welling, Director, Water & Sewer Utilities Department

Approved by: Deanna Santana, City Manager

ATTACHMENTS

1. Use of City Water Forces Resolution