



Legislation Details (With Text)

File #: 20-168 **Version:** 1 **Name:**

Type: Department Report **Status:** Agenda Ready

File created: 1/24/2020 **In control:** Council and Authorities Concurrent Meeting

On agenda: 3/17/2020 **Final action:**

Title: Action on a Resolution for the Use of City Water Forces at 809 Aldo Avenue [Council Pillar: Deliver and Enhance High Quality Efficient Services and Infrastructure]

Sponsors:

Indexes:

Code sections:

Attachments: 1. Use of City Forces Resolution.pdf

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------

REPORT TO COUNCIL

SUBJECT

Action on a Resolution for the Use of City Water Forces at 809 Aldo Avenue [Council Pillar: Deliver and Enhance High Quality Efficient Services and Infrastructure]

BACKGROUND

Charter Section 1310 titled Contracts on Public Works states in part “that every contract involving an expenditure of more than one thousand dollars (\$1,000.00) for the construction or improvement, (excluding maintenance and repair), of public buildings, works, streets, drains, sewers, utilities, parks and playgrounds shall be let to the lowest responsible bidder.” The section further states that “the City Council may declare and determine that, in its opinion, the work in question may be performed better or more economically by the City with its own employees, and after the adoption of a resolution to this effect by at least four affirmative votes, it may proceed to have said work done in the manner stated, without further observance of the provisions of this section.”

DISCUSSION

Staff believes that the work described below is best performed with City Forces to complete the limited size and scope of work outline below. The Water Utility has in-house knowledge and trained personnel operating and maintaining water services that can be leveraged to more economically perform this work. Bidding out the work and contracting with a private entity would delay the construction projects. Therefore, staff recommends that the City Council find that City Forces can best perform the installation of the following water services and approve the use of City Forces.

Location: 809 Aldo Avenue
Type of Service: Provide installation services for new public water improvements.

Description of Work:	Upgrade existing (1) - 8" fire service w/ Detector Check Valve with (1) - 8" fire service with RPDA backflow prevention device and upgrade of existing (1) - 2" water service with reduced pressure backflow prevention device
Job Number:	592-1423-80300-7054-(i)30704
Cost Estimate	\$ 30,450.00
Appropriation	Water Utility Fund (592) Distribution System Replacement/Restoration

ENVIRONMENTAL REVIEW

The actions being considered are exempt from the California Environmental Quality Act ("CEQA") pursuant to CEQA Guidelines sections 15302(c) (Class 2 - Replacement or Reconstruction) because they involve the replacement or reconstruction of existing utility systems and/or facilities involving negligible expansion of capacity, and 15303(d) (Class 3 - New Construction or Conversion of Small Structures), because they involve the construction of new water utility extensions.

FISCAL IMPACT

The funds to support the staff time for the work detailed in this report are budgeted in the Fiscal Year 2019/20 Adopted Budget.

COORDINATION

This report has been coordinated with the Finance Department and City Attorney's Office.

PUBLIC CONTACT

Public contact was made by posting the Council agenda on the City's official-notice bulletin board outside City Hall Council Chambers. A complete agenda packet is available on the City's website and in the City Clerk's Office at least 72 hours prior to a Regular Meeting and 24 hours prior to a Special Meeting. A hard copy of any agenda report may be requested by contacting the City Clerk's Office at (408) 615-2220, email clerk@santaclaraca.gov <<mailto:clerk@santaclaraca.gov>> or at the public information desk at any City of Santa Clara public library.

RECOMMENDATION

Adopt a Resolution approving the use of City Water forces for water and fire service upgrades at 809 Aldo Avenue.

Reviewed by: Gary Welling, Director of Water and Sewer Utilities

Approved by: Deanna J. Santana, City Manager

ATTACHMENTS

1. Use of City Forces Resolution.